

NORTH BEND ELEMENTARY SCHOOL  
CENTRAL PLANT/FIRE ALARM REPLACEMENT

**ADDENDUM NO. 4**

DATE: February 27, 2020

ENGINEER: Gipe Associates  
1220 East Joppa Road, Suite 223  
Baltimore, Maryland 21286  
Phone: (410) 832-2420

OWNER: Harford County Public Schools

PROJECT: North Bend Elementary School  
1445 N. Bend Rd.  
Jarrettsville, Maryland 21084  
Gipe Project No. 19072

TO: All Prospective Bidders

The following changes are made a part of the Drawings and Specifications for the subject project, dated January 31, 2020. Receipt of this Addendum is to be acknowledged, in the space provided in the Bid Form. Failure to do so may subject the Bid to be considered as non-responsive.

**A. CHANGES TO SPECIFICATIONS**

- None.

**B. CHANGES TO DRAWINGS**

**1. CIVIL DRAWINGS**

- DRAWING C0.3 SITE PLAN & DETAILS:** Delete the two bollards indicated inside the chiller enclosure at the corner adjacent to the loading area.

**2. ARCHITECTURAL DRAWINGS**

- None.

**3. MECHANICAL DRAWINGS**

- None.

**C. RFI QUESTIONS/ANSWERS**

- Is there a detail for the water heater, And what are the sizes of the existing pipe connections for the water heater. I don't see any plumbing piping on the drawings. Please advise. **The Cold Water shall be 1-1/2", the Hot Water shall be 2" and the Hot Water Return shall be 1-1/4-inches.**

**D. ATTACHMENTS**

- None.

**END OF ADDENDUM NO. 4**