



Feasibility Study October 2022

GRIMM + PARKER

Creative Collaboration Sustainable Solutions Engaging Environments







contributors

Design Team

Grimm + Parker Architects

Kieran Wilmes
Laura Smyles
Kat Schooley
Zachary Klee
Grimm + Parker Architects
Grimm + Parker Architects
Grimm + Parker Architects
Grimm + Parker Architects

Civil Engineers

Peter Soprano Site Resources
Kate Heil Site Resources
Jennifer Harrington Site Resources

Mechanical, Plumbing, Electrical, Fire Protection Engineers, AV

Andy Endres BKM Engineering Matthew D. Sol BKM Engineering

Harford County Public Schools Sean Bulson, Ed. D., Superintendent

Patti Jo Beard, Exec Director of Facilities Management, Planning & Construction

Christopher Morton, Supervisor of Planning & Construction

Missy Valentino, Facilities Planner

Harry Miller, Assistant Supervisor of Planning and Construction

Randy Geyer, Harford Academy Principal

Jennifer Drumgoole, Elementary School Principal

Kimberly B. Marine, Assistant Principal

Heather Kutcher, Director of Curriculum, Instruction, and Assessment

Mary Nasuta, Supervisor of Health Services

Melissa Romano, Coordinator-Infants and Toddlers

Renee Villareal, Executive Director of Elementary School Instruction and Performance

Dyann Mack, Director of Elementary School Instruction and Performance

Mike Thatcher, Director of Special Education

Colleen Sasdelli, Director of Special Education

Buck Hennigan, Executive Director of Student Support Services

Katie Ridgeway, Director of Strategic Initiatives


Vicki Jones, Talent Pathways Project Manager

Harford County Parks and Recreation

Paul Magness, Deputy Director


Angie Hoover, Civil Engineer/Project Manager

Dave Goodwin, Engineering Associate V/Project Manager




contents

Contributors		5	5	preliminary design floor and site plans	
1	executive summary			Campus Hills Site Analysis Stakeholder Engagement Summary of Options	31 53 56
	Executive Summary	9	6	life cycle cost comparisons	
2	summary of educational specification			Life Cycle Cost Options	79
	Introduction Proposed Program Summary	15 18	7	recommendation	
				Board Action Recommendation	83
3	proposed budget + schedu	ule			
	Proposed Project Budget	21	8	appendix	
	Proposed Project Timeline	21		Preliminary Hydrogeologic Feasibility Evaluation Exhibit 1	86 99
4	existing facility inventory	data		Exhibit 2	110
	Existing Facility Feasibility Waiver	25		Exhibit 3 Exhibit 4 Exhibit 5	218 242 245







Executive Summary



Project Background

Harford County Public Schools is committed to providing all students with physical and cognitive challenges with a comprehensive public education in the least restrictive environment and to ensure that a full spectrum of services are available to all students enrolled in the school system. The original Harford Academy facility was built in 1971 on the Harford Technical High School campus that is also shared with Prospect Mill Elementary School. The increase in enrollment justified the need to build an addition in 1979 to expand the facility with a current enrollment of 136.

The existing Harford Academy does not sufficiently support the needs severely challenged student population. The existing building does not provide for accessibility for disabled students and needs to meet current ADA standards. There is no emergency generator except for select emergency lights throughout the building. Back-up power is critical for uninterrupted utility services required for HVAC, air conditioning and other power outlets that provide medically necessary equipment to students. The HVAC system has air quality concerns due to insufficient ventilation; temperature control for both heating and air conditioning, and the building does not have sufficient windows for air exchange.

Programmatically, the existing facility does not provide the spatial considerations necessary to adequately provide medical and other supervisory needs to the severely challenged student population. Further, there is no space to allow for growing educational opportunities or increasing administrative, instructional, and volunteer support.

Reusing the existing Harford Academy site presented many challenges. Not only is there limited area for additions due to physical and septic constraints, but all construction would have been phased-occupied due to the lack of swing space. The project would have required costly portable units and supporting utilities which is especially prohibitive given the fragility of this unique student population. Ultimately, it was decided that creating a new facility would provide many enhanced opportunities to support the Harford Academy community.

Harford County Public Schools plans to seek a waiver to maintain the existing building for a future purpose while seeking a new site for development of the replacement school.

Campus Hills Site

Harford County Public Schools engaged several stakeholders to evaluate seven sites in the county for the new Harford Academy. After an extensive search, Campus Hills Site was selected for a myriad of benefits including:

- Centralized location within the county to offer county-wise services.
- Current transportation routing can remain in place.
- Adjacent Parks and Recreation development of Shucks Regional Park, including "Miracle Field" and "Sensory Trail" for use students.
- Proximity to Harford Technical High School and Harford Community College for partnership opportunities.

Executive Summary


A Combined Facility


HCPS sought to develop a new campus on the Campus Hills site that accommodates Harford Academy, a new elementary school to help balance the enrollment needs of the Bel Air district, and a Lab School component to support the county's professional development and retention. This approach provides new opportunities to leverage unique educational experiences for students, teachers, and families and create a cohesive whole that is greater than the sum of its parts.

Multiple stakeholders were engaged throughout the feasibility study process to develop priorities and spatial requirements. The new school will include new and improved program space requirements to meet the needs of the current Harford Academy students, new elementary school capacity, lab school components, and shared program spaces to provide an enriched, single school community experience.

Working with stakeholders, Grimm + Parker Architects, Inc. explored several concepts that resulted in the three (3) site options.









Option 1 "Bridge"

 All shared spaces, and programspecific specialty spaces which could potentially be shared, are centralized in plan to maximize inclusion opportunities.

Option 2 "Loop"

- Main shared spaces are centralized in plan to maximize inclusion opportunities.
- Program-specific specialty spaces are separated, located within Elementary and Harford Academy academic zones.

Option 3 "Cluster"

- Main shared spaces are centralized in plan to maximize inclusion opportunities.
- Program-specific specialty spaces are separated, located within Elementary and Harford Academy academic zones.
- Cluster organization creates smaller learning communities within Elementary and Harford Academy academic zones.


Details	
Square Footage	202,000 gsf
Total Estimated Project Cost	\$123,050,137
40-year Life Cycle Cost	\$289,696,148

Details	
Square Footage	196,000 gsf
Total Estimated Project Cost	\$118,434,136
40-year Life Cycle Cost	\$279,366,053

Details	
Square Footage	201,000 gsf
Total Estimated Project Cost	\$124,262,749
40-year Life Cycle Cost	\$292,245,192

Executive Summary

Option 3 *"Cluster"*




- HARFORD ACADEMY (HA)
- SHARED PROGRAM
- ELEMENTARY SCHOOL (ES)

The Superintendent of Schools recommends that the Board of Education approve Option #3, with a gross square footage of 201,000.

This option would build a new school, Harford Academy at Campus Hills, in a cluster configuration to replace the current Harford Academy public separate day school and add new elementary school capacity (598 state rated capacity) within Harford County Public Schools.







Introduction

Program School Organization

The goal for Harford Academy at Campus Hills is to fully recognize synergies between all programs and students, including: the existing Harford Academy population, a comprehensive elementary school, and Lab School. While each of the programs will have a distinct identity, their immediate proximity introduces a desirable overlap for new experiences.

Multiple stakeholders were engaged throughout the feasibility study process to develop priorities and spatial requirements for the ongoing education specification for the facility. A series of guiding principles were developed to create the program summary – with an intent to develop spatial requirements for each separate community and potential shared spaces for instruction, play, and engagement. This approach allowed the leadership team to not only review program location and adjacencies, but evaluate potential operational challenges and opportunities as part of each scheme.

Proposed Enrollment Data

School Name	SRC
Harford Academy	150
New Elementary School	567
Total	717



Program Summary

SCHOOL	PROGRAM SPACE	ED SPEC				
3011002	PROGRAMI SPACE		#	UNIT SF	TOTAL SF	
	ADMINISTRATION Administrative Suite					
НА					3,130	
	Secure Lobby	0	1	400	400	
	General Office and Reception Area	0	1	800	800	
	Principal Office	0	1	300	300	
	Assistant Principal Office Education Evaluator Office	0	2	200 150	400 150	
	IEP Meeting Room (Corridor Access)	0	1	600	600	
	Unisex Restroom	l ő	i	80	80	
	Secure Storage	lő	1	150	150	
	Records Room	ō	1	250	250	
ES					2,550	
LO	Secure Lobby	0	1	250	250	
	General Office and Reception Area	0	1	650	650	
	Principal	0	1	300	300	
	Assistant Principal	0	2	200	400	
	Large Conference Room (IEP)	0	1	600	600	
	Unisex Restroom	0	1	50	50	
	Secure Storage Records Room	0	1 1	150 150	150 150	
	Records Room	l ۳	1	150	150	
SHARED					1,050	
	Work Room/Mail Room Conference Room	0	1	450 300	450 600	
	Conference Room	ľ	2	300	000	
	NSF				6,730	
	Instructional Support					
HA					1350	
	Paraeducator Office	0	1	250	250	
	Teacher Work Room	0	4	250	1000	
	Storage	0	1	100	100	
ES					1000	
	Teacher Work Room	0	4	250	1000	
SHARED					1640	
	Unisex Toilets	0	2	80	160	
	Privacy Room	0	1	80	80	
	Volunteer Work Room/PTA Storage	0	1	600	600	
	Faculty Lounge/Staff Lavatory	0	1	800	800	
	NSF				3,990	
	STUDENT SERVICES Guidance + Counciling					
HA	Guidance + Counseling	1			550	
ПА	Counseling Office	0	1	200	200	
	Behavior Specialist Office	0	1	150	150	
	Behavior Resource Suite	l ŏ	1	200	200	
	Dollario Proceduce Carlo	ľ	·	200	200	
ES					550	
	School Counseling Office	0	2	200	400	
	School-based Mental Health Office	0	1	150	150	
SHARED					1,170	
	Testing Suites	0	2	90	180	
	Testing Storage Closet	0	1	90	90	
	Psychologist Office	0	1	150	150	
	Itinerant Office	0	1	250	250	
	Carall Contagon Doors	0	1	200	200	
	Small Conference Room					
	Large Conference Room	ő	1	300	300	
			1	300	300 2,270	

SCHOOL	PROGRAM SPACE		ED SPE			:C	
SCHOOL	PROGRAMI SPACE		TS	#	UNIT SF	TOTAL SF	
	Health Suite						
НА	Office Rest Area Waiting Area Exam/Isolation Room Storage / Supplies Room Unisex Toilet Unisex Toilets (Shower in Toilet)		0 0 0 0 0	1 1 1 1 1 1	250 600 250 100 150 100	1,610 250 600 250 100 150 100	
ES						925	
	Reception, Waiting, Treatment Area Isolation Room Nurse's Office Rest Area Unisex Toilet Unisex Toilet - shower Storage Closet	NGE	0 0 0 0 0	1 1 1 1 1 1	200 100 200 200 50 75 100	200 100 200 200 50 75 100	
		NSF				2,535	
OUADES	Speech					4 700	
SHARED	Speech Pathologist Office ADL Classroom Unisex Toilet Speech Therapy Rooms Storage	NSF	0 2 0 0 0	4 1 1 2 1	150 500 100 200 100	1,700 600 500 100 400 100	
	OT/PT		ļ				
НА	OT/PT Activity Room OT/PT Office OT/PT Storage	NSF	1 0 0	1 1 1	1200 400 300	1,900 1200 400 300 1,900	
	Related Services						
SHARED	Vision Services Hearing Services Audiology Assistive Technology	NSF	0 0 0	1 1 1 1	250 250 250 250 250	1,000 250 250 250 250 250	
	Partnership Suites						
SHARED	Dental Suite Health Specialist Cosmotology Specialist	NSF				800	
	ACADEMIC AREAS						
НА	Classrooms STRIVE Pre Primary		3 3	3	1000 1000	25,000 3000 3000	

Program Summary

SCHOOL	PROGRAM SPACE		ED SPEC				
3CHOOL	FROGRAM SPACE	TS	#	UNIT SF	TOTAL SF		
	Elementary + Middle High School Flex	11 7 1	11 7 1	1000 1000 1000	11000 7000 1000		
ES					22,000		
	Pre-K – including a toilet Kindergarten – including a toilet Primary Grades 1-2 - including Toilet Intermediate Grades 3-4-5	1 4 8 12	1 4 8 12	1000 850	1000 4000 6800 10200		
	ACADEMIC SUPPORT						
HA	Lavatories	0	25	160	8,400 4000		
	Storage Equipment Parking Lot Multi-Sensory Room Area	0 0	4 10 2	400 200 400	1600 2000 800		
ES	Facilities		,	500	5,400		
	Enrichment Reading Resource Reading Storage Math Resource Resource/Pull Out Storage	0 0 0 0	1 1 1 1 7	500 600 200 600 500	500 600 200 600 3500		
	NSF				13,800		
	SPECIAL EDUCATION / PROGRAMS Independent Living						
НА	macpenaem Eving				1,300		
	Life Skills Lab Home Ec Room Storage Unisex Toilet	1 1 0 0	1	1200 1200 200 100	0 1200 0 100		
	NSF				1,300		
	Regional Special Education						
ES	Early Intervention: Early Learners Classroom Early Intervention: Learning Together Classroom Early Intervention: Co-taught Pre-K Regional Program Workroom Sensory Room Calming Space	0 0 0 0 0	1 1 1 1 1	1000 1000 1000 400 400 100	3,900 1000 1000 1000 400 400 100		
	LAB SCHOOL						
НА	Observation	0	6	200	1,200 1200		
		0	8	200	1,600		
ES	Observation	"	•	200			
SHARED	Observation Welcome Center	0	1	1200	1,200 1200		


MEDIA CENTER Media Center Media Center Harford Academy 1,150	SCHOOL	PROGRAM SPACE			ED SPEC	
Media Center	3CHOOL	FROGRAM SPACE	TS	#	UNIT SF	TOTAL SF
Media Center - Harford Academy Circulation Deak						
Media Center - Harford Academy 0	шл	Media Cerilei				1 150
Circulation Deak	ПА	Media Center - Harford Academy	0	1	1000	
Maker Space 1 700						
Maker Space 1 700	ES					1,150
Media Office Media Storage Circutation Desk Stacks + Collection 0 1 450 450 450 150 150 150 150 150 150 150 150 150 1						
Media Office Media Storage Circutation Desk Stacks + Collection 0 1 450 450 450 150 150 150 150 150 150 150 150 150 1	SHARED		1			5 250
Media Storage	0.0.0.0	Media Office	0	1	750	
Stacks + Collection Storytelling		Media Storage	0			
Storytelling						
Instructional Area						
SPECIALS Horticulture Area 1850						
SPECIALS		instructional Area	l ۲	- 1	650	850
HA		NSF				7,550
HA						
Classroom Lab 1 1 800 800 800 Storage 0 1 1 950 950 95	шл	noniculture Area				1050
Creenhouse Storage 0 1 950 950 Storage 1 100 100 100	ПА	Classroom I ab	1	1	800	
Storage 0 1 100 10						
HA						
HA						
Classroom		Technical Education				
Lab 0 1 900 900 900 Finishing Room 0 1 100	HA	21			000	
Finishing Room 0						
Storage 0						
Career/Vocational Area						
HA		9-				
Laboratory Storage Room Recycling Room Office NSF FINE ARTS Arts HA Art Classroom Art Classroom Storage/Teacher Planning Music Music Classroom Music Storage Vocal Music NSF A 1 1000 1 150 150 150 160 1 120 120 120 1 180 180 180 180 180 180 180 180 180 180		Career/Vocational Area				
Storage Room 0 1 150 150 Recycling Room 0 1 120 120 120 Office NSF 4,900	HA				4000	
Recycling Room Office						
Office NSF 4,900 FINE ARTS Arts 2000 Art Classroom 2 2 1000 2000 ES Art Classrooms 1 1 1000 1000 SHARED Kiln Room 1 1 100 100 Storage/Teacher Planning NSF 3,400 Music NSF 3,400 Music NSF 1 100 100 Music Classroom 2 2 2 700 1400 100 Music Storage 2 2 700 1400 100 100 ES Cocal Music 1 1 800 800						
NSF						
FINE ARTS Arts HA Art Classroom Art Classroom Art Classroom Art Classroom ES Art Classroom Art Cla			-			- 1
Arts		NSF				4,900
Arts						
HA						
ES 1000 Art Classrooms 1 1 1000 1000 SHARED Kiln Room 1 100 100 Storage/Teacher Planning NSF 3,400 NSF 3,400 Music HA 100 100 Music Classroom 2 2 700 1400 Music Storage 0 1 100 100 ES 100 1 100 800 Vocal Music 1 1 800 800	HA					2000
Art Classrooms 1 1 1 1000 1000 SHARED Kiln Room Storage/Teacher Planning 1 100 100 NSF 3,400 Music HA Music Classroom Music Storage 1 100 1500 Music Storage 1 100 1500 ES Vocal Music 1 100 100 1 1 1 100 100 1 1 1 1 800 800		Art Classroom	2	2	1000	2000
Art Classrooms 1 1 1 1000 1000 SHARED Kiln Room Storage/Teacher Planning 1 100 100 NSF 3,400 Music HA Music Classroom Music Storage 1 100 1500 Music Storage 1 100 1500 ES Vocal Music 1 100 100 1 1 1 100 100 1 1 1 1 800 800						
SHARED	ES	Art Classesses	,		1000	
Kiln Room Storage/Teacher Planning 1 100 100 100 100 100 100 100 100 100 1		Art Classicoms	1	7	1000	1000
Kiln Room Storage/Teacher Planning 1 100 100 100 100 100 100 100 100 100 1	SHARED					400
Storage/Teacher Planning		Kiln Room		1	100	
Music HA 1500 Music Classroom 2 2 700 1400 Music Storage 0 1 100 100 ES 1800 Vocal Music 1 1 800 800		Storage/Teacher Planning		1	300	300
Music HA 1500 Music Classroom 2 2 700 1400 Music Storage 0 1 100 100 ES 1800 Vocal Music 1 1 800 800						
HA 1500 Music Classroom 2 2 700 1400 Music Storage 0 1 100 100 ES 1800 Vocal Music 1 1 800 800		NSF				3,400
HA 1500 Music Classroom 2 2 700 1400 Music Storage 0 1 100 100 ES 1800 Vocal Music 1 1 800 800						
Music Classroom Music Storage 2 2 700 1400 100 ES 1800 1 1 800 800 Vocal Music 1 1 800 800	U A	MUSIC				4500
Music Storage 0 1 100 100 ES 1800 1 1 800 800 Vocal Music 1 1 800 800	пА	Music Classroom	2	2	700	
ES 1800 Vocal Music 1 1 800 800						
Vocal Music 1 1 800 800			ľ			.00
	ES					
Instrumental Music 1 1 1000 1000						
		Instrumental Music	I 1	1	1000	1000

Program Summary

SCHOOL	PROGRAM SPACE	ED SPEC			
SCHOOL	FROGRAMI SPACE		#	UNIT SF	TOTAL SF
	NSF				3300
	PHYSICAL EDUCATION				
	Gymnasium				
НА	Fitness Lab / Physical Therapy Fitness Lab / Physical Therapy Storage Adaptive Gymnasium	1 0 1	1		3450 1300 250 1600
	Adaptive Gynmasium Storage	0	1	300	300
SHARED					9,450
	Gymnasium PE Indoor Storage PE Outdoor Storage Chair Storage PE Office PE Office Toilet + Shower Room P+R Storage Group Restrooms Performance Platform Platform Storage		1 1 1 1 1 1 2 1	300 500 200 200 100 400 300	6000 300 500 200 200 100 400 600 1000
	NSF				12,900
НА	Aquatics				6500
ПА	Therapy Pool Locker + Shower Rooms Pool Office Pool Unisex Toilet Room Pool Storage HA Pool Storage P+R Laundry Chemical Storage Mechanical Pump Room for Pool	1 0 0 0 0 0 0 0	1 1 1 1 1	950 120 100 200 200	3400 1900 120 100 200 200 80 100 400
	FOOD SERVICES Cafeteria				
НА					2950
	Dining Commons Furniture Storage Serving Line	0 0 0	1	150	2400 150 400
ES	Dining Comments			2000	3550
	Dining Commons Serving Line After School Storage		1 2 1	200	3000 400 150
	NSF				6500
	Kitchen				
НА	Puree Food Prep Dishwashing Office	0 0 0	1	100 150 100	350 100 150 100
ES	Office		1	100	2730 100
	Office Kitchen Freezer Refrigerator Dry Kitchen Storage Toilet + Locker Area		1 1 1 1 1	1600 150 150 250	1600 1600 150 150 250 180

relicol	DDOCDAM CDACE			ED SPE	C
SCHOOL	PROGRAM SPACE	TS	#	UNIT SF	TOTAL SF
	Trash		1	100	100
	Dishwashing		1	150	150
	Custodial Closet		1	50	50
	NSF				3080
	BUILDING SERVICES				
	Building Services				1900
	Service Closet / Equip. Storage		8	50	400
	Mechanical Area		1	1200	1200
	Communications Distribution Room		1	300	300
	Custodial Services				930
	Office		1	150	150
	Locker/Lavatory Area		1	180	180
	Grounds Equipment Storage		1	250	250
	Receiving Areas General Storage Area		1	100 250	100 250
	General Storage Area		'	230	250
	NSF	1			2830
	TOTAL NSF				141,885
	EFFICIENCY FACTOR				42,566
	TOTAL GSF				184,451





Project Data




Proposed Project Budget


Current Anticipated Budget: \$161,541,000

Proposed Project Timeline

	3	
2022	September 19 September 22 October 5 October - December	Feasibility Study to BOE Annual LEA meeting with the State at current Harford Academy Request Local Planning Approval from the State with CIP request Ed Spec Meetings
2023	January - April May 22 June July - September September – November November - December	Ed Spec Meetings Ed Spec to BOE Design Contract Schematic Design (SD) Design Development Documents (DD) Construction Documents (CD)
2024	January - February March / April Summer	Construction Documents (CD) Bid for construction Construction Begins
2025	Spring	Elementary Redistricting Process Begins
2026	February September	Elementary Redistricting Process Concludes Harford Academy at Campus Hills opens New elementary boundaries implemented







Existing Facility Feasibility - Waiver Request



Sean W. Bulson, Ed.D., Superintendent of Schools 102 S. Hickory Avenue, Bel Air, Maryland 21014 Office: 410-838-7300 • www.hcps.org • fax: 410-893-2478

October 7, 2022

Alex Donahue, JD
Acting Executive Director
Interagency Commission on School Construction
200 West Baltimore Street
Baltimore, Maryland 21201

RE: Harford Academy Feasibly Waiver

Dear Mr. Donahue:

Harford County Public Schools respectfully requests that the Interagency Commission on School Construction, approve a waiver of the requirement to evaluate a renovation/ addition option for the feasibility study for the Harford Academy Project due to the medically fragile students at the school and the existing site limitations. On June 13, 2022, the Board of Education (BOE) voted to change the name of the John Archer School to the Harford Academy (HA); for clarity throughout this letter, the school will be referred to by the current name as HA.

Built in 1971, the HA is the only Public Separate Day School serving students ages three to twenty-one with severe and profound disabilities within Harford County. In 2009, Smolen & Emr Associates completed a scope study to assess the current building condition, safety, and educational program efficiency of the HA facility. It was determined that the existing building had reached a point where components and systems needed to be replaced. The scope study also concluded that the instructional needs, as well as the support service requirements of the students attending the school, have changed since the construction of the original building. Due to the medical fragile nature of the students attending HA, modernizing the facility through a phased occupied renovation is not an option.

The HA currently shares an 80.33-acre site with Harford Technical High School and Prospect Mill Elementary School. This site is not served by public utilities. While the site is adequate for the current facilities, it is limited to potential location and size to build a new facility. At the time of the original scope study, it was determined that the Bel Air campus was the most feasible site for the relocation and placement of the HA.

Due to fiscal constraints, the HA project was deferred. Thirteen years have passed since the original scope study, and the HA Project is now the highest major capital priority. On August 10, 2020, the BOE approved a contract with FLO Analytics for the Balancing Enrollment project and an update of the site location study for HA. FLO Analytics partnered with Banta Campbell Architects to conduct a site location study as part of the overall Balancing Enrollment project.

The HA serves our most medically fragile and severely disabled students countywide; therefore, determining the best location for a replacement school is crucial for travel times and student's access to services and programs. The site location study considered seven sites for the relocation of HA. Three of the sites do not currently have an existing building.

RE: Harford Academy Feasibility Waiver Request October 7, 2022 Page 2 of 2

Four of the sites are existing school facility properties. Data was gathered for each of the sites considering proximity to the Town of Bel Air, Upper Chesapeake Medical Center, and travel distances from edge points of Harford County like White Hall, Whiteford, and Havre de Grace. At the BOE business meeting on August 16, 2021, the BOE voted in favor of completely replacing the school and build the replacement school on the Campus Hills site, located at 301 Schuck's Road. Please find the final site study report attached.

At the business meeting on February 14, 2022; the BOE of Harford County approved a Balancing Enrollment plan for HCPS that included adding an elementary school to the HA project to increase elementary capacity within the County's growth envelope and help meet the needs related to expansion of Pre-Kindergarten and Special Education programs. Building a combined special education and elementary school facility would:

- assist with addressing current and future capacity issues within elementary schools.
- keep HCPS in line with the current county administration funding trends of completing one major capital project at a time.
- prevent the current major capital priorities from being deferred.
- provide HA students direct access to learning opportunities with their typical developing peers.
- potential lab school for current HCPS students aspiring to be teachers.

Due to the nature of the medically fragile conditions of the student's attending HA and the current site limitations, HCPS respectfully requests a waiver of the requirement to evaluate a renovation/addition option for the feasibility study for the Harford Academy Project. Please advise us if additional information is needed to evaluate this request.

Sincerely,

Christopher L. Morton

Supervisor of Facilities Management

cc: Mr. Sean W. Bulson, Ed.D., Superintendent of Schools, HCPS

Mr. Eric Davis, Chief of Administration, HCPS

Mr. Cornell S. Brown, Assistant Superintendent for Operations, HCPS


Ms. Patti Jo Beard, Executive Directive of Facilities Management, HCPS

Mr. Harry Miller, Assistant Supervisor of Planning & Construction, HCPS


Mr. Jaime Bridges, Regional Facilities Manager, IAC

Ms. Arabia Davis, Funding Program Manager, IAC


Ms. Eileen Gladd, P.E., Regional Facilities Manager, IAC








Vicinity Map



Site Analysis





Site Analysis





Civil Narrative

34



1.1 Site Description

The existing Harford Academy is located at 100 Thomas Run Road in Bel Air, Maryland. The proposed school will be relocated to a site located at 119 Schucks Road in Bel Air, Maryland and combined with a proposed new elementary school. The 31.15± acre site is owned by the Harford County Board of Education (BOE) and is currently leased to a farmer to be used agriculturally. The site is located just south of the intersection of East Churchville Road (Maryland Route 22) and Schucks Road in central Harford County. Per recorded Maryland Real Property data, the site is Parcel 43 located on Tax Map 42 and is recorded among the land records of Harford County, Maryland Liber 8255 at Folio 281. The site is bounded by Schucks Regional Park to the south and east, Schucks Road to the west, and commercial developments to the north.

1.2 Site Circulation and Parking

On the southern side of the site, a 36 foot paved driveway serves as the main vehicular access point to the property from Schucks Road. This driveway is shared with the neighboring Schucks Regional Park via an Access and Sign Easement. There is also an existing 25 foot paved driveway that is shared with the commercial developments to the north via a Common Driveway Easement. This driveway could potentially serve as a secondary vehicular access point to the property; however, the existing Easement Agreement and Declaration of Covenants will require revision. Harford County Board of Education would need to involve an attorney to amend this agreement, which would require the adjoining property owners' consent. Harford County may require acceleration and deceleration lanes and/or a dedicated left turn lanes be provided in Schucks Road for any additional entrances added for access to the school property due to the increased traffic demands. Widening Schucks Road for a secondary entrance located along the common driveway would likely require the acquisition of a portion of one of the adjoining property owner's land and would likely also require the relocation of several existing utility poles.

Fire truck Access will be feasible for the site and reviewed with Harford County Fire Marshall's office early on in the design process to confirm requirements.

The design team will need to coordinate with the existing Harford Academy school staff to confirm what special site accommodations are required for the new Harford Academy in relation to site circulation, separate drop-off areas or designated play areas. Additional ADA spaces and site circulation will likely be required in addition to minimum requirements.

Civil Narrative

Adjacent to the site is the existing Schucks Regional Park. The existing park is equipped with multiple baseball/softball fields, multi-purpose play field areas, playgrounds, pavilion, Miracle League adaptive baseball field and audio/visual sensory stations along the parks circulation path. The student population of both the new Harford Academy and the new elementary school will benefit from having direct access to Schucks Regional Park. The Miracle Leagues adaptive baseball field was designed specifically to allow children and adults with disabilities the chance to play baseball on the specially designed rubberized fields. Access to the park could be provided via a pedestrian bridge crossing of Broad Run at the northwest corner of the existing park. A joint permit application through MDE and Army Corps of Engineers would be required for these improvements to receive approval during the design phase.

1.3 Site Traffic

Harford Academy School Existing Traffic Conditions

Harford Academy is located at 100 Thomas Run Road in the Bel Air section of Harford County. Specifically, the site is situated on the west side of the roadway, north of MD 22 (Churchville Road). The property features two points of access to Thomas Run Road. To the north, there is an inbound only movement to serve all vehicular and bus traffic. The southern access is situated approximately 400 ft north of Thomas Run Road and facilitates both inbound and outbound movements. There are also available connections to Harford Technical High School to the north and Oak Grove Baptist Church to the south. The single point of egress to Thomas Run Road currently operates under stop control. Figure 1 includes an aerial photograph depicting the current location of the site.

The current Harford Academy facility opened in 1971 with additions and renovations occurring in 1981. The HCPS website lists capacity as 210 with a 2020 enrollment of 136 students. Fifty-eight classroom teachers worked at the school as of 2019. Some of the existing signing and pavement markings have severely deteriorated and are no longer functional. Consideration should be given to providing minor short-term enhancements to signing and pavement markings to ensure safe traffic operations on site.

Harford Academy serves a unique population of students within Harford County. Grades Pre Kindergarten through 12th attend the school, and generally all students are provided bus transportation to the facility. Students attend from throughout Harford County. In addition, the faculty staff ratio to students is very low at this facility due to the needs of the students.

Harford Academy - Future Location

The purpose of this feasibility study is to review the potential relocation of Harford Academy to a parcel within Schucks Regional Park, which is situated on the east side of Schucks Road south of MD 22, approximately one-half mile south of the current facility. Additional photographs from the proposed site location can be found in Appendix B.

In addition to Harford Academy, a new Elementary School is being considered for the same site. It would feature a capacity of approximately 628 students.

Schucks Regional Park features one access point to Schucks Road, which is situated approximately 1,900 ft south of MD 22. The access point features a separate left turn lane in the southbound direction of Schucks Road. The site access approach facilitates separate left and right turn lanes. Currently, access is provided exclusively to Schucks Regional Park, which is owned by Harford County Department of Parks and Recreation.

Harford County owns and maintains Schucks Road. It is classified as a Minor Rural Collector extending from MD 22 southward for a distance of approximately 3.09 miles to MD 136. In the vicinity of this site, Schucks Road generally features one travel lane in each direction divided by a double yellow line. The posted speed limit is 30 mph. There are no existing pedestrian facilities along the length of Schucks Road.

Civil Narrative

Figure 3 contains a summary of the existing lane use at the Schucks Regional Park access at Schucks Road.

For the purpose of reviewing the feasibility of this site, turning movement counts were collected in May 2022 at the Schucks Road/Schucks Regional Park access. The AM and PM peak hour data is summarized in Figure 4. As expected, the AM volume into and out of the regional park is minimal. During the PM peak hour, the volumes are slightly higher. Details on the traffic volumes summarized in 15-minute intervals can be found in Appendix C.

Thru traffic along Schucks Road is relatively low during both peak periods, which is consistent with the roadway's classification.

Figure 3. Existing Lane Use and Traffic Control





Figure 4. Existing Peak Hour Traffic Volumes



Schucks Road Planning

HarfordNEXT A Master Plan for the Next Generation was reviewed to determine if Harford County has any future plans for Schucks Road. The roadway is identified within HarfordNEXT as a Rural Minor Collector, as mentioned above. There is no further mention of the roadway within the plan, which indicates that no future widening or other projects are currently being contemplated by Harford County.

The Harford County Bicycle and Pedestrian Master Plan was also reviewed for the Schucks Road corridor. As shown in Figure 5, there are no proposed projects for bicycles or pedestrians along the Schucks Road corridor.

While the subject site does not have direct frontage to MD 22, the MDOT SHA Project Portal and MDOT Consolidated Transportation Plan (CTP) were both reviewed to determine if any projects are planned in the area. A review of both resources shows no current funded projects are planned or under construction for MD 22.




Figure 5-BIKE PED MASTER PLAN.png

Proposed Use

Figure 6 shows only one potential schematic sketch plan option of the potential site and is sufficient for a standard feasibility study traffic analysis. For the new Elementary School, Figure 6 shows a potential bus loop off of the access drive in magenta and a separate car drop off with direct access to Schucks Road. Due to the high volume of vehicle traffic during arrival and dismissal periods at the ES car drop off, police control or signalization will be required at the ES car drop off Schucks Road entrance. However, this would likely not be the case if the locations of the ES car drop off and the ES Bus drop off were interchanged. The proposed roundabout and queuing along the existing access drive would help alleviate stop control concerns for vehicular access to the site during peak hours. Therefore, the following narrative is based on the assumption and recommendation that the ES bus drop off be moved to a right in/ right out entrance along Schucks Road and the ES car drop off be moved so it is along the main access drive.

The main access point to the new school will be from the existing Schucks Regional Park, with the intention of facilitating a one way loop to the new elementary school during arrival and dismissal periods. Vehicular traffic would access the site to the east and exit to the west, providing additional space for queued vehicles picking up and dropping off children. A roundabout is proposed for the access point at Schucks Road.

Bus traffic to the site would utilize a right-in/right-out to Schucks Road, or an auxiliary driveway within the park access. An additional access point for Harford Academy vehicular traffic is proposed to the north along Schucks Road.

For the purpose of the Traffic Analysis several different options were considered. They include:

- Option 1 -Main Access, 2nd Full Access for Harford Academy and Right-in/Right-out for Buses
- Option 2 Main Access Only and Right-in/Right-out for Buses




Figure 6-SCHEMATIC PLAN OF SITE.png

Future Traffic

Historic traffic volumes along Schucks Road from 2011 through 2020 were reviewed. The results are shown in Figure 7. The 2020 volume is a significant decrease from 2019 because of the COVID-19 pandemic. As a result, the volumes from 2020 were not used in the calculation of the average growth. The resulting average growth from 2011 to 2019 is 2.49%. To present a conservative estimate for future traffic, a 3% annual growth rate was applied for 3 years. Figure 8 shows the 2025 base peak hour traffic volumes.

As previously stated, the current population for Harford Academy is unique. Most students arrive by buses. In the future, 15 school buses are projected for the site. One hundred staff members will use the facility. To project AM and PM peak hour trips, the number of school buses and staff members was considered. Specifically, it is projected conservatively that 90% of the staff members will arrive during the peak period. In addition, 20% miscellaneous trips were also accounted for during the peak hour, which could account for deliveries, service trips, or parents arriving at the school. As shown in Table 1, a total of 156 AM and 156 PM trips are projected for the site.

To account for the new elementary school, the Institute of Transportation Engineers (ITE) Trip Generation (11th Edition) was utilized. Land Use Code 520 (Elementary School) provides a trip rate of 0.75 trips per student during the AM peak hour and 0.45 trips per student during the PM peak hour. This data, collected at similar sites throughout the country, incorporates the fact that bus transportation is available and carpools will occur. A total of 489 AM trips and 289 PM trips are projected.

Figure 7. Historical Traffic for Schucks Rd


Average Growth: 2.49%

Mathematical Growth: 2.4%

	Year	ADT Volume	Vol. increase	% increase	Average %
	2011	5,620		•	
	2012	5,571	-49	-0.87%	-0.87%
	2013	5,592	21	0.38%	-0.25%
	2014	5,523	-69	-1.23%	-0.58%
	2015	5,684	161	2.92%	0.30%
	2016	5,805	121	2.13%	0.66%
	2017	6,600	795	13.70%	2.84%
	2018	6,541	-59	-0.89%	2.30%
	2019	6,792	251	3.84%	2.49%
	2020	5,642	-1,150	-16.93%	Not to Use
	8,000 _				
	7,000				
"	6,000				
ADT Volumes	5,000				
	4,000				
	3,000				
	2,000				
	1,000				
	0 2011	2012 2013 2	2014 2015 201	6 2017 2018	2019 2020

Year

Figure 8. 2025 Base Peak Hour Traffic Volumes



The site trips were distributed and assigned to the road network as shown in Figures 9A to 9F below. Recall, Option 1 accounts for two full-movement access points to Schucks Road in addition to a right-in/right-out for buses. Option 2 eliminates the northern full-movement access.

Figure 9A details the projected trip assignment associated with Harford Academy – Option 1, whereas Figure 9B shows Harford Academy – Option 2's trip assignment. Similarly, the trip assignment for the new elementary school is detailed in Figures 9C and 9D for Options 1 and 2, respectively. Figures 9E and 9F provide the combined trip assignment for Options 1 and 2.

Table 1. Trip Generation for Proposed Schools

•						
Total Trina	AM Peak Hour		PM Peak Hour			
Total Trips	In	Out	Total	In	Out	Total
Harford Academy (HA)						
15 School Buses						
Assuming All Buses in Use	15	15	30	15	15	30
100 Staff Members						
90% Come in Peak Hour	90	10	100	10	90	100
138 Students						
Assuming All Come by Buses	0	0	0	0	0	0
Miscellane ous Trips						
Assuming 20% More	21	5	26	5	21	26
Total Proposed HA Trips	126	30	156	30	126	156
New Elementary School (ES)						
Elementary School (students, ITE-520)	- School Pe	ak Hours	NOT	E: ITE Trip G	eneration 1	1th Edition
AM School Peak Hour Trips = 0.75 x Stu	ıdents		In	/Out: 54/4	6	
PM School Peak Hour Trips = 0.45 x Stu	idents		In	/Out: 46/5	4	
ITE Total ES Trips (ITE-520)			NOTE	: ITE Trip G	eneration 1	1th Edition
700 students	283	242	525	145	170	315
18 School Buses						
Assuming All Buses in Use	18	18	36	18	18	36
Non-Bus ES Trips	265	224	489	127	152	279

Figure 9A. Trip Assignment for proposed HA - Option 1




Figure 9C. Trip Assignment for proposed ES - Option 1




Figure 9E. Combined Trip Assignment for HA & ES - Option 1




Figure 9B. Trip Assignment for proposed HA - Option 2




Figure 9D. Trip Assignment for proposed ES - Option 2




Figure 9F. Combined Trip Assignment for HA & ES - Option 2




Figure 10A. 2025 Total Peak Hour Traffic Volumes - Option 1





Figure 10B. 2025 Total Peak Hour Traffic Volumes - Option 2



Adding the site trips to the base peak hour traffic volumes results in the 2025 peak hour traffic volumes as shown in Figure 10A for Option 1 and Figure 10B for Option 2.

Intersection Capacity Analysis

Highway Capacity Manual (HCM) analysis was reviewed for the site access point for the existing condition and for all proposed access points for the total condition. The results are shown in Table 2. When considering the existing stop control, the site currently operates at Level of Service "B." Details on all analysis can be found in Appendix D.

It is important to recognize the stop control level of service is a report of the minor approach delay only. Since mainline Schucks Road would operate under free-flow conditions, no delay would be experienced.

For the total condition, both Option 1 and Option 2 were assessed using HCM. In both cases, acceptable levels of service were found at all intersections, with the exception of the main site access point. The addition of the site traffic results in unacceptable delay during both peak periods. To mitigate site impact, a roundabout was considered as a geometric improvement. Level of Service "A" could be achieved under both existing and total conditions using the HCM methodology. A Conceptual Plan detailing potential dimensions for the roundabout is included as Figure 11.

The introduction of a roundabout would be beneficial in that both safety and operations would be improved. Existing driveways on the west side of Schucks Road are shown to be modified to permit access to the roadway in advance of the roundabout which would maintain the ability of residents to turn left or right into and out of the driveway in the future.

The proposed north access for Harford Academy was reviewed with a southbound left turn lane along Schucks Road. A left turn lane is recommended to eliminate queuing and backing that could occur in the southbound direction as vehicles queue to enter the site. A lane shift may be required to accommodate the left turn lane and right-of-way should be investigated to ensure constructability.

Bus access via the proposed right-in/right-out does not have a significant impact on traffic operations. Levels of service at the bus access and other access locations are acceptable as described above with or without the access. If the bus access is constructed, sight distance must be evaluated to ensure adequate spacing from the roundabout.

Table 2. Results of Intersection Capacity Analysis

	AM PEAK HOUR	PM PEAK HOUR	
2022 Existing			
1. Schucks Rd & Schucks Regional Park (Stop Control)	B/12.2	B/14.9	
2025 Total Option 1 1/			
1. Schucks Rd & South Access (Stop Control)	F/76.8	E/48.6	
Schucks Rd & South Access (Roundabout)	A/8.7	A/7.9	
2. Schucks Rd & Bus Access (Stop Control)	B/11.3	B/11.4	
3. Schucks Rd & North Access (Stop Control)	B/14.8	C/16.5	
2025 Total Option 2 ^{2/}			
1. Schucks Rd & South Access (Stop Control)	F/172.1	F/78.8	
Schucks Rd & South Access (Roundabout)	A/10.0	A/8.8	
2. Schucks Rd & Bus Access (Stop Control)	B/11.0	B/12.0	

NOTE:

- 1. Option 1 has 3 access points on Schucks Rd (south access, bus access and north access).
- 2. Option 2 has 2 access points on Schucks Rd (south access and bus access).
- 3. Reported are HCM LOS/worst movement delays in seconds for stop control and HCM LOS/Worst Approach Delays in Seconds for roundabout.

Summary and Conclusions

Traffic along Schucks Road is relatively light during both peak periods. Similarly, traffic accessing existing Schucks Regional Park is also minimal. The addition of Harford Academy and a new elementary school to this site would have minimal impact on traffic operations. The introduction of a roundabout is recommended to mitigate site impact and provide an acceptable level of service. A separate left turn lane is recommended if a northern access is pursued for Harford Academy.



1.4 Zoning Information and Permit Processing

The parcel is located in Harford County and is zoned AG, Agriculture.

Bulk Zoning Regulations		
Maximum Lot size	2 acres	
Maximum Height	3 stories	
Maximum lot width at building line	100 feet	
Minimum setback from adjacent residential lot	50 feet	
Minimum setbacks for principal structures:		
Front lot line	50 feet	
Rear lot line	80 feet	
Side lot lines	40 feet	

Parking Requirements

- Vehicular Parking: 5 per classroom, plus 1 per 8 seats in assembly hall
- The maximum parking spaces permitted shall not exceed 130% of the minimum number of spaces required. Accessible parking space requirements will be determined from the Code of Maryland Regulations and the Americans with Disability Act Accessibility Guidelines based on the total parking provided. Additional accessible parking spaces may be required to meet the program requirements of the school due to the nature of the students in attendance at Harford Academy. The vehicular parking spaces required shown above are per the Harford County Zoning Standards for a high school to be more conservative, however, the elementary / middle school requirements may be more appropriate.
- Bicycle Parking: Bicycle parking is recommended for the project if desired by HCPS.
 It is recommended that thoughtful connections be made to Schucks Road Regional Park and adjacent properties to the extent practical. Bicycle parking spaces may also support LEED design criteria goals.

For school uses located within the AG district a Special Exception pursuant to Article IX of the Harford County Zoning Code is required; however, Harford County Public Schools appears exempt from this requirement and Board of Appeals approval may not be required.

Because this project is expected to generate more than 250 traffic trips per day, the below standard Harford County processes will be required in order to receive permits for construction:

- Community Input Meeting (CIM): Comments made by the public are not required to be addressed by the developer / design team
- Preliminary site plan sent to the Harford County Planning & Zoning to serve as official notice of the proposed project
- Traffic Impact Analysis (TIA): Any negative impact the proposed project has on existing intersections identified by Harford County Planning and Zoning must be identified and mitigated such that it meets industry standards and must be approved by traffic professionals in both local and state agencies. The initial concept traffic analysis performed for this feasibility study will help develop the TIA; however, the County will dictate specific requirements during the initial scoping meeting that will determine TIA scope.
- Stormwater Management and forestation plans must be reviewed and approved by the appropriate agencies
- Development Advisory Committee (DAC): DAC is comprised of county, state, federal, and utility agencies and will advise the director of planning for large-scale developments such as these. DAC will provide oral or written comments expressing the agency's recommendation or opinion of the development plan. The general public will also be allowed a time during the meeting to express input on the development plan. In order to apply for DAC review, the following items must be submitted to DAC at least four weeks prior to the DAC meeting, which is held on the first and third Wednesdays of each month:
 - DAC Site Plan
 - Landscape Plan / Lighting Plan / Buffer Plan and checklist
 - Traffic Impact Analysis (TIA)
 - Declaration of Intent (DOI)
 - Forest Conservation Plan (FCP)
 - Stormwater Management Concept Plan submitted to DPW for review
 - List of adjacent property owners
 - DPW Fee Authorization Letter
 - Appropriate fees

Additionally, a sign must be posted on the subject property at least two weeks prior to the DAC meeting providing the date, time, and location of the DAC meeting. Notice must also be published in two publications once a week for two consecutive weeks prior to the DAC meeting.

Following DAC plan approval, Harford County will issue a Preliminary Site Plan Approval letter outlining project specific requirements to be met in order to obtain permits. These approval items typically include stormwater management (SWM), erosion and sediment control (ESC), Landscape and photometric, adjacent public road and offsite road improvements (if required), Forest Conservation, Harford County Health Dept (HCHD), MDE/HCHD approval for well & septic design, MDE/Army Corps of Engineers for stream/wetland impacts etc. Once all of the written requirements in the site plan approval letter are met and final site plan approval is granted, building permits may be applied for and approved. Once building, grading and SWM permits are received, the contractor may begin construction.

1.5 Site Soils

According to information provided by the USDA-NRCS Web Soil Survey, five (5) soil types exist on the property including:

AdB - Aldino Silt Loam, (3-8% slopes), Moderate Erodibility

GcB2 - Glenelg Loam, (3-8% slopes), Moderate Erodibility

CcB2 - Chester Silt Loam (3-8% slopes), Moderate Erodibility

GcC - Glenelg Loam (8-15% slopes), Moderate Erodibility

WaA - Watchung Silt Loam (0-3% slopes), Severely Hydric

Hydrologic soil groups are rated "A" through "D" indicating a range of good to poor infiltration properties. "A" type soils have the best infiltration while soils rated as "D" have the worst. Hydrologic soil group classifications are important variables used when stormwater engineers determine the types of environmentally-sensitive design (ESD) alternatives that are practical for a given site. The majority of this site falls within the "B" and "C" hydrologic soil groups. This means the overall site has moderate to poor infiltration rates and any SWM practice will likely require underdrains pending a geotechnical study. Geotechnical borings are the best technique for documenting existing subsurface conditions because they more precisely identify soil types, infiltration rates, water table levels, and geologic anomalies. A thorough geotechnical study is recommended for any proposed development.

1.6 Site Topography

The Campus Hills property generally drains from northwest to southeast. The topography of the site is fairly consistently sloped towards the southeast at approximately 4%. The elevations range from approximately 337 to 388 feet above sea level. The high point of the site is located in the northwest corner of the site while the low point is located in the southeast corner of the site.

Due to the existing topography onsite, it is anticipated that the site will likely require large quantities of fill in order to construct the new development. Additionally, the proposed development will likely require several large retaining walls in order to meet the existing grades along the perimeter of the site while also providing the required programming requirements of the schools.

1.7 Utilities

Well + Septic

The site is located outside Harford County's Development Envelope, meaning public water and sewer utilities are not provided nearby. It is possible that Harford County may expand their development envelope in the future; so the proposed development should be designed to accommodate said future connections. However, expansion of the Development Envelope is not anticipated prior to the construction of this project; therefore, well and septic will be required for the proposed development.

The Harford County Public School System (HCPS) plans to improve the Site with a private non-transient non-community (NTNC) supply well and large groundwater discharge septic system serving the future Harford Academy and new Elementary School. This new combined school building will serve a mainstream student population known formerly as "Campus Hills Elementary School" and serve special needs students presently enrolled at Harford Academy.

Prior Evaluations and Permits

Initial plans to develop the Site as a residential subdivision date back to 2009, at which time the residential housing market no longer supported the developers plan and HCPS purchased the property. HCPS consultants performed evaluations to support developing the Site as "Campus Hills Elementary School," with about 628 mainstream students planned.

In response to the Groundwater Discharge Permit (GDP) application for Campus Hills ES, MDE issued GDP-17-DP-3666 around 2010 for a design flow of 11,500 gallons per day (GPD) and an average daily flow of 5,750 GPD. The GDP permit was met with resistance from the community and a public hearing was held in response, though the permit was issued shortly after. HCPS has maintained the discharge permit through two renewal cycles (See Appendix, Exhibit 2).

In response to an application for Campus Hills ES Groundwater Appropriation Permit (GAP), MDE also issued a Notice of Exemption, dated February 2009, reducing the requested allocation to 8,200 GPD month of maximum use (e.g. average daily use over highest water use month) and 4,600 GPD average daily flow. No permit or renewals were required for the groundwater allocation (See Appendix, Exhibit 3).

Several existing wells are located throughout the site; however, it is likely all of the existing wells will be required to be abandoned in order to make way for the proposed development. Harford Academy will require a therapy pool and showers to meet the school programming requirements, which will increase the demands for both water and sewer services. At least one and possibly two supply wells will be required to meet the estimated demands of the proposed school. A new GAP will be required for the proposed wells due to the increase in supply demand for the new combined school. It is likely that HCPS will need to own or control lands possessing sufficient groundwater recharge to support water demands per MDE policy.

The water system for this project is designated as a NTNC Water System meaning that it is a water system that regularly supplies water to at least 25 of the same people at least six months per year. Non-Transient Non-Community (NTNC) Water Systems must comply with current regulations:

- New impervious surfaces are prohibited within 100' of the new well(s).
- The well(s) and the 100' radii must fall within the limits of the property
- Pervious area buffers are required and their location(s) must be coordinated with Harford County Health Department
- Proposed well locations shall be reviewed and approved by Harford County Health Department

All proposed wells must be located according to the following setback requirements per Code of Maryland Regulations (COMAR) 26.04.04.04 or as a matter of MDE policy:

- 10 feet from property lines
- 15 feet from Right-of-Way
- 30 feet from building foundations
- 100 feet from all septic systems and septic reserve areas including those located on neighboring properties
- At least 200 feet from all septic systems and septic reserve areas if the well is located at a lower elevation than said septic systems and septic reserve areas

Similarly, all proposed septic systems and septic reserve areas must be located according to the following setback requirements:

- 15 feet from property lines, Rights-of-Way, and dedicated easements
- 25 feet from steep slopes at 25% grade change or higher
- 100 feet from wells or neighboring supply wells
- 100 feet from any stream or body of water
- Must be located outside of Forest Retention or Critical Areas
- The septic tank must be located at least 20 feet from house connection or permanent structures
- Drain fields and septic reserve areas must be located a minimum of 30 feet from all permanent structures

There are two existing septic field reserve areas associated with the active groundwater discharge permit. The septic reserve areas are located on either side of the main vehicular access drive to Schucks Regional Park. These septic reserves were designed and approved under a previous project to construct a new elementary school on this site known as Campus Hill Elementary School; however, this school was never constructed. These existing septic field reserves in combination with a proposed equalization septic tank and proposed waste water treatment plant will likely not be sufficient for the demand of the proposed school. It is highly likely additional septic field areas, water reuse and low flow or flow reducing plumbing fixtures will be required. However, the full extent of these requirements are pending further hydrogeological testing of the site. This testing is required during the wet weather season months, which is not during the time this feasibility study was conducted. It is recommended this wet weather season testing be performed as soon as possible during the 2023 hydrogeological wet season, typically during the first and second quarters of a given year. Additional soil testing spanning the wet season percolation testing period, typically February 1 through April 30 also may be required.

The wastewater/gray water reclamation/reuse solution would help reduce the MDE required septic field area onsite and maximize available site area for school programming needs. New and efficient low flow plumbing fixtures are required for this project, including sensor-based hand wash sink faucets if possible. Additional solutions for maximizing the available septic reserve areas is to incorporate drip irrigation and thereby increase redundant capacity.

The existing septic reserve areas must remain in place with minimal grading impacts. At a minimum, grading shall not impact the top two feet above the designed percolation layer. A force main will be required to pump the sanitary services from the building to the existing and proposed septic field areas. Similarly, if the owner elects to utilize the wastewater reuse option, a lift station will be required to pump treated wastewater back to the building for reuse.

It is recommended that the existing Harford Academy install daily flow data monitoring equipment to help capture more accurate peak flow data from the existing school. Obtaining this daily flow data may help reduce septic reserve area requirements as it will show more accurate daily demands for the existing school. The data provided for review for this study had inconsistent information that would be clarified with new information. Additionally, it is recommended that the proposed Harford Academy and new school include daily monitoring flow data equipment so HCPS can proactively identify leaks or maintenance issues.

An equalization septic tank and wastewater treatment plant will also be required to treat wastewater before it is discharged to septic field areas. These will require a lift station and force main to pump to all septic field and septic reserve areas. Additional septic reserve areas will be required as a redundant measure in the event that the septic areas malfunction at some point during the lifespan of the building. Redundant areas using drip irrigation will need to set-aside space for 30 days of wastewater storage (e.g. elevated tower plan placeholder). These additional areas will need to be incorporated into the site during the design period. Additionally, at least two or three new discharge permit monitoring wells will be required. An underground fire system suppression tank will also be required to meet fire service requirements for the site.

Overall Well + Septic Findings + Summary

The Site is most limited by hydrologic balance/Darcy's Laws and groundwater mounding (septic discharge) and secondarily limited by the groundwater recharge capacity (supply wells). Please refer to Appendix for the complete detailed analysis and additional information. The hydrologic balance/Darcy's Law and groundwater mounding may be addressed by revising analyses using new site-specific hydrogeologic input parameters via onsite testing, which may then support feasibility to increase the septic capacity. These input parameters would be obtained primarily during wet season hydrogeological testing of the site (via monitoring wells) and secondarily during wet season percolation testing of soils (via excavated test pits) during the project's design phase as previously mentioned.

Overall, maximum occupant population goals of approximately 950 for the combined schools does not appear to be supported under the current MDE groundwater discharge permit or by the site constraints. It is highly probable expansion of the current design or reduction in maximum occupant population goals will be required in order for well and septic design to be feasible on this site. However, this cannot be confirmed without the following information.

- Septic Discharge:
 - Further hydrogeological evaluation/soil percolation testing during the wet season (first and second quarter of a given year)
 - Adjusted design flow factors from daily empirical data obtained from existing Harford Academy
 - Meeting with HCHD and MDE to confirm design flow factors and site specific requirements
- Well Supply:
 - · Final acres of proposed impervious surfaces
 - Verification of water use and demand
 - Applying for a new MDE groundwater appropriation permit to confirm water demand and site specific requirements

Current available data suggests that the following solutions, at a minimum, are required for the project's proposed well and septic systems.

- Septic
 - Increased septic field areas. Including areas beneath grass play areas where feasible and use of drip irrigation for redundant capacity
 - Implement wastewater reuse methods
 - Use flow equalization septic tank and wastewater treatment
 - Propose low flow and sensor-based plumbing fixtures
 - Educate facility staff on best management practices for septic system and wastewater treatment system maintenance. Some examples below:
 - Handling and use of cleaning and resin chemicals
 - Monitoring daily flows to assess leaks to fix promptly
 - Incorporate discharge of pool backwash water into the stormwater management design or permit discharge separately from the septic
 - Contract a certified wastewater treatment plant operator

Well

- Drill new well(s) and demonstrate via testing they have sufficient capacity and water quality
- Acquire recharge easements from property owners within the same watershed.
 This process will require BOE land use attorney involvement for recording/
 establishing the necessary Deed and covenant restrictions against future
 development.
- Contract a certified water treatment plant operator

Storm Drain

Other than at the property entrance and the Broad Run culvert, there is currently no proposed storm drainage systems located onsite. The proposed development will include storm drains necessary for suitable outfalls to onsite SWM facilities and ultimate outfalls to Broad Run.

Gas & Electric

A permanent Drainage and Utility Easement exists along Schucks Road on either side of the existing primary vehicular access drive and along the north side of that drive. Overhead electric lines, utility poles, and telecommunications services exist adjacent to the site along Schucks Road. Existing utilities may need to be relocated or upgraded depending on the proposed layout of the site. Additionally, some low hanging wires may require relocation for construction purposes. BGE will be coordinated with during design to confirm location of proposed power service to the new building.

BGE will also confirm location and extents of proposed gas service if required because there is not an existing gas service to the project site.

1.8 Stormwater Management (SWM)

The proposed development of this site will require both quality and quantity management in order to meet the current stormwater management regulations adopted by the State of Maryland in 2009. There are existing SWM facilities onsite that were provided to treat the SWM requirements for the Schucks Regional Park development which was designed and approved in 2011, which means that these existing facilities were likely designed to meet the current SWM regulations. There are three existing grass swales that are located along the existing driveway entrance to Schucks Regional Park and along Schucks Road on either side of the entrance. These three grass swales along with additional bypass area drain to an existing quantity pond located in the southwest corner of the site. This quantity pond collects drainage from approximately six acres of the site including a portion of Schucks Road. The grass swales provide a portion of the quality management that was required for the Schucks Regional Park development. Similarly, the quantity pond provides the quantity management that was required for this particular drainage area of the Schucks Regional Park development. These grass swales will likely be required to be relocated to accommodate the proposed roundabout. If these facilities cannot be relocated and instead require removal for the proposed development, then additional treatment will need to be provided elsewhere onsite in order to maintain the quality credit that was provided within those grass swales.

The entirety of the site drains to the Bush River watershed and drains to one Point of Investigation (POI) located at the southeast corner of the site. Environmental Site Design (ESD) practices must be implemented to the maximum extent practicable (MEP) to provide sufficient water quality and recharge provisions. This ESD methodology encourages the use of small-scale stormwater practices and nonstructural techniques, conserving natural drainage patterns, and minimizing impacts of land development on water resources. Micro-scale practices will be provided as necessary to meet water quality requirements for the proposed development. Management of the 100-year storm event is not required in the Bush River watershed. The site is also not located in a Tier II watershed; therefore, the additional review processes and erosion and sediment control measures necessary for Tier II watersheds are not required for this site.

SWM will be provided onsite to comply with the "Stormwater Management Act of 2007" (Act) and the Maryland Stormwater Management Guidelines for State and Federal Projects, February 2015.

The SWM design must include the following aspects:

- Water quality control (WQv) to limit pollutants in stormwater runoff. Impervious surfaces located within the project site will require treatment
- Groundwater recharge volume to approximate existing hydrologic conditions
- Channel Protection volume storage to prevent deterioration of downstream channels and erosion
- Manage the ten-year peak discharge to pre-developed conditions

All stormwater management practices must be located a minimum of 25 feet from any existing septic areas and a minimum of 30 feet from any supply wells. Additionally, infiltration facilities must be located a minimum of 100 feet from supply wells. In addition to the existing septic fields located on site there is an existing septic field in close proximity to the site on the neighboring property to the north.

In order to meet the minimum SWM quality and quantity requirements for the site, at least 25 micro-scale quality management facilities, green roof, at least two large above or underground quantity management storage devices, and at least two or three large combination quality and quantity pond facilities. The micro-scale facilities provided may include proprietary SWM practices, which require a smaller footprint, but cost significantly more than standard practices. These practices may be necessary in areas where there is limited available site area or site constraints.

1.9 Floodplains, Wetlands, and Waterways

Per FEMA FIRM map 24025C0166E, there are no 100-year floodplains located on the site. There is an existing perennial stream that runs along the property line on the northeastern side of the site, which drains into the main branch of Broad Run along the property line on the southeastern side of the site. Wetlands also exist along these streams. ADA Pedestrian bridges across these streams may be desired to provide pedestrian access to the adjacent Schucks Regional Park and, if so, a floodplain study will likely be required to prove that the bridge and culvert design is sufficient for the 100-year flood elevation levels. Disturbance within stream and wetland areas or buffers will require a joint permit with MDE and the Army Corps of Engineers prior to receive grading and SWM permits.

1.10 Landscape, Trees, and Forest Conservation

The existing site is currently used agriculturally as a farm field and subsequently there are few trees located on the site; however, there are wooded areas and forest buffers located along eastern property line adjacent to the stream beds. Mitigation will be required for any impact within the critical root zone of a specimen tree, which is defined by a tree with a diameter at breast height equal to or larger than 30 inches. During design, the design team will need to determine if there are any rare, threatened, or endangered species located on this site per the Maryland Natural Heritage Program report and list appropriate measures that will need to be taken if there are these species onsite here. The proposed development will require a Forest Stand Delineation Plan, Forest Conservation Plan, and an Environmental Impact Assessment Report to be approved by Harford County.

Proposed plantings will be provided to match the existing conditions and those native to the area. A landscape plan will be provided and will meet the current requirements for Harford County for planting counts and screening requirements. Similarly, SWM facilities will have a separate planting plan reviewed and approved by Harford County. In general, plant material will be selected and arranged to augment adjacent native ecosystems and provide aesthetic complement to the building and surrounding campus while maintaining clear open views throughout the campus for security. The design team recommends utilization of plant material to complement education programming such as ecology, pollination, and stormwater management.

1.11 Play Structures / Athletic Fields / Athletic Courts

The proposed school programming will require several play structures, athletic fields, and hard surface athletic courts. A playground consultant should be engaged early in design to ensure that the play structures proposed for this project will be inclusive of all the students who will use them. In order to accommodate the needs of the student population of this school, the play areas may require additional space than that of a typical play area at an ordinary school and it may be necessary to provide fencing of approximately six feet in height around these play areas to ensure the safety of the students.

1.12 Site Security

Site lighting and security cameras are primary security considerations. It is recommended that site lighting and visibly mounted security cameras are provided throughout the site to increase visibility and site security. The design team should coordinate with HCPS during the design phase to determine what additional site security measures will be required for the new Harford Academy.

1.13 Site Signage

There is an existing wooden double post sign for Schucks Regional Park along Schucks Road near the main driveway entrance. This sign will likely need to be removed and relocated or replaced to accommodate the proposed development. There are also several existing signs pointing to existing wells located throughout the site. Some of these signs may need to be removed for the proposed development; however, these signs should remain in place or be replaced as part of this project for any existing wells to remain. Additional signage will be required along Schucks Road to direct traffic towards the school and park entrances. Wayfinding signage will be necessary to inform drivers of the directions of the school and the park once they enter the site. Signage designating the handicapped accessible routes will also be required. Directional wayfinding signage will also be required to direct traffic to separate new Elementary School areas and separate Harford Academy site areas.

1.14 Proposed Site Concepts

Option 1: Bridge

The Bridge option features three separate entrances to the site, the first via the proposed roundabout located at the existing entrance to Schucks Regional Park and two additional entrances located along Schucks Road. The first entrance provides access to the proposed bus parking lot for the elementary school, to Schucks Regional Park, and to the access drive that wraps around the east side of the building to connect the other parking lots on site as well as the service area located east of the proposed building. The second entrance is located on Schucks Road and enters directly into a car drop-off loop and parking lot primarily for the elementary school students and their families. The third entrance is also located along Schucks Road and provides access to the proposed bus loop for Harford Academy, visitor and staff parking lots, and the access drive that wraps around the east side of the building. We highly recommend moving bus traffic to the second entrance and having the primary access for students, visitors and their families be at the first entrance noted with the roundabout. Otherwise, significant additional traffic control measures or signalization will likely be required along Schucks road.

This option also features a courtyard within the building to provide a safe play area for Harford Academy students, as well as additional hard and soft surface play areas located on the south side of the building for the elementary school students. In addition to these play areas, a multi-purpose athletic field will be provided on the east side of the building and a garden area will be provided north of the school for outdoor educational purposes.

Option 2: Loop

The Loop option features two separate entrances to the site. The first entrance is in the same location as the bridge option via the proposed roundabout and provides access to a car drop-off and parking lot as well as the bus loop and parking lot serving the elementary school. This entrance also provides access to Schucks Regional Park and an access drive that wraps around the east side of the building. The second entrance to the site is located on the north side of the site from Schucks Road and provides access to the Harford Academy bus drop-off loop, the access drive around the building, and visitor and staff parking lots.

Similar to the Bridge option the Loop option also features a courtyard within the building to provide a safe play area for Harford Academy students and hard and soft surface play areas and a multi-purpose athletic field all located around the building for the elementary school students. There is also a small area within the courtyard dedicated to a garden area.

Option 3: Cluster

The Cluster option features three separate entrances to the site. Similar to the other two options, the first entrance is via the proposed roundabout. This entrance provides access to the car drop-off and parking area and to Schucks Regional Park. The second entrance is located along Schucks Road and provides access to the bus drop-off loop for Harford Academy and small staff parking lot. This bus drop-off also connects to the third entrance which is located further north along Schucks Road. The third entrance provides access to the bus parking lot for the elementary school and the service area. This option does not have the access drive that wraps around the building that the other two options provide due to site grading constraints.


The Harford Academy play areas for this option are located within two separate courtyard areas, however, these courtyards are not completely enclosed within the building and are open to the site on one side. Fences would likely be required along this open side to ensure the safety of the students. This option does, however, feature a fully enclosed courtyard to be shared between Harford Academy and the elementary school. This courtyard would include a garden area for outdoor learning. Similar to the other two options, this option also features a multi-purpose athletic field and hard and soft surface play areas for the elementary school students located around the building.

The Harford Academy play areas closest to the Schucks road are a concern for maintaining positive drainage away from the proposed building during storm events. Should this option be selected, careful attention during design to maintain overland drainage flow away from the proposed building is critical. If adequate overland flow cannot be attained, then it is recommended the building footprint and site design be revised to accommodate the site constraints.

Site Program Requirements

Harford Academy

- 18 stacked busses
- 120 Parking Spaces
- Alpha Playground
- Beta Playground
- Garden/Green Space
- 8,500 sf Hard Surface Play





Elementary School

- 16 buses
- 100 Parking Spaces
- PK-K Play Area
- Upper Grades?
- Multi-purpose field
- 1,000 sf K Hard Surface Play
- 7,000 sf Hard Surface Play

Potential Shared Use

- Parking
- Fields





Stakeholder Engagement

Visioning Process

At the start of the feasibility study, an engagement process was designed, in collaboration with HCPS, to fully harness the energy and vision for the project. Activities such as open visioning sessions, stakeholder engagement workshops, and existing and benchmark facility tours were held to inspire and goal-set for the new facility. Online surveys and visioning boards were also created to encourage participation outside of traditional meeting times, which allowed heightened engagement from the community.

Each of these activities informed project understanding and a series of guiding principles to shape the program, site, and building approach for each option. Multiple stakeholders were included throughout the process to continue to develop and refine priorities and spatial requirements. We have included particular stakeholder feedback to each design option for review, in addition to design team evaluation.


Partnership Exploration

Beyond programmatic elements, as part of the process for the design of the new facility, an ongoing study has been undertaken to seek out strategic connections within the local and regional community to amplify the impact of this new, state-of-the-art facility. Meaningful partnerships have been sought out and evaluated through programmatic and operational lenses - including recreation, healthcare, education, and social services. This study will continue through design to engage the community to maximize resources and promote inclusion for all stakeholders.


















Guiding Principles

Learning Happens Everywhere.

"Every space is a learning space. Every space." Encourage Independence Integrate Lab School + Observation

Spaces Where Students Belong

Shared Experience, Shared Spaces
Inclusion + Equity
Universal Access + Barrier Free

Quality of Environment

Connection to Nature + Daylighting Spaces make students feel like they matter Inspiring and Energetic Whole Child Wellness

Building a Support Network

Sharing Resources


Parent + Community Support


Professional Development / Retention


"Front Door" to Special Education Services

Summary of Options

HARFORD ACADEMY (HA)
SHARED PROGRAM
ELEMENTARY SCHOOL (ES)







Option 1 "Bridge"

 All shared spaces, and programspecific specialty spaces which could potentially be shared, are centralized in plan to maximize inclusion opportunities.

Option 2 "Loop"

- Main shared spaces are centralized in plan to maximize inclusion opportunities.
- Program-specific specialty spaces are separated, located within Elementary and Harford Academy academic zones.


Option 3 "Cluster"

- Main shared spaces are centralized in plan to maximize inclusion opportunities.
- Program-specific specialty spaces are separated, located within Elementary and Harford Academy academic zones.
- Cluster organization creates smaller learning communities within Elementary and Harford Academy academic zones.

Details	
Square Footage	202,000 gsf
Total Estimated Project Cost	\$123,050,137
40-year Life Cycle Cost	\$289,696,148

Details	
Square Footage	196,000 gsf
Total Estimated Project Cost	\$118,434,136
40-year Life Cycle Cost	\$279,366,053

Details	
Square Footage	201,000 gsf
Total Estimated Project Cost	\$124,262,749
40-year Life Cycle Cost	\$292,245,192



Zoning Approach

Bus


- Separate bus drop off for HA and ES
- HA 18 bus stacking length, students can enter into classroom bar or front entry
- ES 16 buses enter directly into cluster or

Cars

- Separate, distinct arrival lobby for HA + ES
- Car dropoff accessed from Schucks Rd

Play

- Play areas located directly outside of Academic zones
- Multipurpose Field size dependent on SWM facilities
- Harford Academy Play Areas contained in central courtyard or directly accessible from classrooms



Site Approach

Bus

- Separate bus drop off for HA and ES
- HA 18 bus stacking length, students can enter into classroom bar or front entry
- ES 16 buses enter directly into cluster or

Cars

- Separate, distinct arrival lobby for HA + ES
- Car dropoff accessed from Schucks Rd

Play

- Play areas located directly outside of Academic zones
- Multipurpose Field size dependent on SWM facilities
- Harford Academy Play Areas contained in central courtyard or directly accessible from classrooms

Building Approach

Harford Academy

- Dining Area centrally located for each school, but distinctly separate spaces
- Contiguous arrangement of classrooms allows for flexibility of programming over time.
- Bus drop off with continuous canopy directly into classroom clusters
- Centralized courtyard dedicated to HA
- CTE + Specialty programs grouped together to activate corridor and create destination for easy wayfinding
- Career and Vocational program located for possible public access and interaction
- One-story configuration

Elementary School

- Separate PK/early intervention cluster allows for supervision and potential dedicated drop off area.
- Linear arrangement for all elementary school classrooms allows for flexibility over time.
- Open and enclosed Resource/Pull-out areas offer choice and flexibility
- Two-story configuration

Shared Use

- Shared administrative suite for HA and Elementary School.
- Dining, Media, Physical Education spaces centralized to allow inclusion where possible for all students

First Floor 177,000 sf



Department Legend



Building Approach

Elementary School

- Linear arrangement for all elementary school classrooms allows for flexibility over time.
- Centralized stair and collaborative area activate classroom cluster and reduces cluster through-traffic
- · Distributed workrooms
- Centralized toilet location for 3rd/4th/5th grade
- Open and enclosed Resource/Pull-out areas offer choice and flexibility

Second Floor 25,000 sf



Department Legend



Design Team Evaluation

Site

- Separate bus loop/parent drop-off areas for Harford Academy and ES
- ✓ Shared front entry and plaza on Schucks Road
- Bus loops situated to allow option for student entry through main entry or directly into academic areas
- Full perimeter access around building for bus exit, service/delivery access and emergency vehicles
- ✓ Secure HA play area within internal courtyard
- ✓ Distinct pool entrance for ease of after-hours/shared use
- ✓ Dedicated service/pool parking area
- ✓ School has a strong community presence along Schucks Rd

Building

- Centralized courtyard creates strong sense of orientation and wayfinding, and provides safe, secure play area
- Physical Education, Dining, and Media program positioned to maximize engagement and sharing of resources.
- Adaptive Gym and Fitness configured to allow for operable partition between and expansion of activity space
- ✓ Instrumental Music directly adjacent to performance space
- Open Observation spaces double as open resource areas and direct courtyard connections from HA classroom areas
- Contiguous arrangement of classrooms allows for flexibility of programming over time
- ✓ Career program location allows for possible public access and interaction
- All major program elements are centrally located for easy access for both HA and ES

- × HA buses and cars utilize same site entrance.
- **x** Requires earthwork, grading, and clearing for new fields.
- ✗ Outdoor play areas less proximate to gymnasium areas
- **X** ES bus loop distant from building access
- Instrumental and Vocal music classrooms are separate

Stakeholder Comments

Site

- ✓ Bus loop for HA feeds directly into classroom hallways
- Separate bus and car lots

Building


- Building organization allows for each school to have a separate identity with ease of inclusive spaces for sharing without being forced upon either population.
- Shared program spaces centrally located
- ✓ Ample play area, fully enclosed
- HA Observation spaces double as courtyard connections
- Centralized Administration suite
- Classrooms located acoustically separate from loud group areas/program zones
- Separate building entrances with clear circulation patterns for each school
- 2-story ES configuration

Site

- × No courtyard for ES
- ★ Staff parking is remote from ES programming
- x Increase in required canopy area for two bus drop offs and main entry area.

Building

- ★ Compact, linear arrangement of classrooms in ES
- ★ No open common space in ES
- × No courtyard for ES
- **X** Design feels separate and not much opportunity for inclusion.
- ★ 2nd grade classrooms located on upper level



Site Approach

Bus


- Separate bus drop off for HA and ES
- HA 18 bus stacking length, able to enter into either entrance to academic cluster
- ES 16 buses -enter directly into academic cluster

Cars

- Separate, distinct arrival lobby for HA + ES
- Separate parking lot for HA + ES

Play

- Play areas located directly outside of Academic zones, visible from Schucks Rd
- Harford Academy Play areas contained in central courtyard



Site Approach

Bus

- Separate bus drop off for HA and ES
- HA 18 bus stacking length, able to enter into either entrance to academic cluster
- ES 16 buses –enter directly into academic cluster

Cars

- Separate, distinct arrival lobby for HA + ES
- Separate parking lot for HA + ES

Play

- Play areas located directly outside of Academic zones, visible from Schucks Rd
- Harford Academy Play areas contained in central courtyard

Building Approach

First Floor 168,000 sf

Harford Academy


- Loop corridor provides protected corridor for continual access to all learning spaces in HA program
- Directly adjacent Dining spaces maximize opportunities for inclusion
- Contiguous arrangement of classrooms allows for flexibility of programming over time
- Bus drop off location allows direct entry into cluster
- 1 centralized, interior courtyard dedicated to Harford Academy
- CTE + Specialty programs grouped together to activate corridor and create destination for easy wayfinding
- One-story configuration

Elementary School

- Linear and adjacent cluster arrangement for all ES classrooms allow flexibility over time
- 2-story configuration

Shared Use

- Shared administrative suite for HA and ES
- Centralized Media enables inclusion opportunities





Building Approach

Elementary School

- Linear and adjacent cluster arrangement for all ES classrooms allow flexibility over time
- Centralized toilet location for 3rd/4th/5th grade
- Open and enclosed Resource/Pull-Out areas offer choice and flexibility

Second Floor 28,000 sf



Department Legend



Design Considerations

Site

- Separate ES bus loop and parent drop-off areas.
- ✓ Potentially reduced grading impacts due to compact footprint
- ✓ Playground areas visible from Schucks Rd for safety and security
- Full perimeter access around building for bus exit, service/delivery access and emergency vehicles
- Combined receiving/loading area for Building Services and Kitchen
- Secure HA play area with internal courtyard
- ✓ School has a strong community presence along Schucks Rd

Building

- Centralized courtyard creates strong sense of orientation and wayfinding, and provides safe, secure play area
- OT/PT and Fitness configured to allow for operable partition between and expansion of activity space
- Dining areas co-located and directly adjacent to maximize opportunities for inclusion
- Centrally located counseling suite
- ✓ Instrumental Music directly adjacent to performance space

Site

- **X** ES buses and cars still utilize same site entrance.
- × Potentially long travel distant for HA students from buses to classrooms

Building

- × HA Career program spaces not easily accessible to public
- X Gym is remote from HA program, not conducive to shared use
- × Adaptive Gym and Fitness are fully separate, distinct spaces
- ★ Counseling suite has no access to daylight
- **X** ES Dining has no daylight or views
- **★** ES Art located upstairs, isolated for other Arts and Specials
- X Students may need to travel through one or more clusters to reach their classrooms/grade level communities

Stakeholder Considerations

Site

- Ample play area
- Simple bus circulation
- Separate car and bus drop off

Building


- 2-story ES configuration
- Building organization allows for each school to have a separate identity with ease of inclusive spaces for sharing without being forced upon either population.
- Centralized counseling suite
- ✓ Fully enclosed play space for HA
- → HA Music and art clustered together

Site

- Only one dedicated play space for HA which does not allow for differentiation between elementary and secondary
- × No courtyard access for ES

Building

- **★** Classroom placements are not conducive to departmental organization
- × Concerned about acoustics given classroom proximity to large group areas
- × Art located upstairs
- Prefer special areas to be consolidated in a public realm and not as closely connected with classrooms
- Atypical room shapes can be challenging to furnish and adequately support teaching/learning activities



Site Approach

Bus

- Separate bus drop off for HA and ES
- HA bus drop off students directly to academic clusters
- ES buses drop off at pool entrance

Cars

Shared HA/ES drop off and parking

Play

- HA play areas proximate to classrooms, fenced and directly outside of learning communities
- ES play areas located on lower level, directly outside of academic wings



Site Approach

Bus

- Separate bus drop off for HA and ES
- HA bus drop off students directly to academic clusters
- ES buses drop off at pool entrance

Cars

Shared HA/ES drop off and parking

Play

- HA play areas proximate to classrooms, fenced and directly outside of learning communities
- ES play areas located on lower level, directly outside of academic wings

Building Approach

First Floor 173,000 sf

Harford Academy

- Clustered arrangement of classrooms creates smaller learning communities
- Bus drop off location allows direct entry into any learning community
- CTE + Specialty spaces grouped together to activate primary HA corridor
- One-story configuration

Elementary School

- Separate PK/K/Early Intervention cluster situated closest to Administrative suite
- Open and enclosed Resource/Pull-Out areas offer choice and flexibility
- Clustered arrangement for all ES classrooms creates smaller, 1-2 grade learning communities centerered around a collaborative/resource area
- 2-story configuration steps down with grade to absorb topography

Shared Use

- Shared administrative suite and primary entrance for HA and ES
- Centralized Media enables inclusion where possible
- 1 centralized, interior courtyard to be shared by entire school community for multiple uses and programming



ACADEMIC AREAS

MEDIA

PHYSICAL EDUCATION

Building Approach

Elementary School

- Clustered arrangement for all ES classrooms creates smaller learning communities centerered around a collaborative/resource area
- Resource rooms centrally located between clusters on lower level
- Play areas accessed directly from lower level classroom clusters
- Open central stair to connect lower level academic zones and special programming on first floor level

Ground Floor 28,000 sf



Department Legend



Option 3 "Cluster"

Design Considerations

Site

✓ Two-story ES classroom wings built into existing grades

Building

- ADL/Speech distributed to allow for easy access across HA learning communities
- Adaptive Gym and Fitness configured to allow for operable partition between and expansion of activity space
- Shared courtyard can maximize opportunities for inclusion and provide a safe outdoor space for both schools
- Centralized Media enables inclusion where possible

Site

- ★ No perimeter access/service drive
- × HA play area not fully enclosed in courtyard
- × Play areas are obscured behind building and grade
- **X** Double stacked bus chevron could be problematic in case of bus failure
- X Youngest students must go downstairs to access play areas, resource rooms

Building

- X Distinct HA clusters may limit flexibility as age levels and classroom groupings change over time
- ★ Shared admin area is remote from HA program
- **X** ES bus riders must walk a significant distance through HA specific program areas to get to their academic zones
- **X** HA classroom cluster configurations do not align with current classroom counts by age group
- **★** Career program is fairly remote from front door/public access
- $oldsymbol{\mathsf{X}}$ Gym is remote from HA program, not conducive to shared use

Option 3 "Cluster"

Stakeholder Considerations

Site

- Distinct bus and car separation
- Bus drop off directly into HA clusters
- Multiple play areas for HA

Building

- Shared courtyard to promote inclusion and provide an outdoor amenity to both HA and ES
- ✓ Consolidated wellness programming in its own wing
- ✓ Like the idea of the ES having a "lower floor" rather than an "upper level"
- ✓ Direct access to different play areas for HA
- Cluster configuration of classrooms
- Classrooms located acoustically separate from loud group areas/program zones
- Building organiztion allows for each school to have a separate identity with ease of inclusive spaces for sharing without being forced upon either population


Site

× Combined drop off


Building

- ★ Complicated building massing
- **X** ES classroom configuration
- Long walk distance for ES bus riders to get to their dedicated programmed areas, through HA specific zones
- **x** Younger students have to travel up and down on a daily basis to access required services
- × Elementary entry points are very remote
- **x** Early childhood playground should be on same level as classrooms
- Narrow hallways don't allow for a lot of open gathering space

Summary of Options







Option 1 "Bridge"

 All shared spaces, and programspecific specialty spaces which could potentially be shared, are centralized in plan to maximize inclusion opportunities.

Option 2 "Loop"

- Main shared spaces are centralized in plan to maximize inclusion opportunities.
- Program-specific specialty spaces are separated, located within Elementary and Harford Academy academic zones.


Option 3 "Cluster"

- Main shared spaces are centralized in plan to maximize inclusion opportunities.
- Program-specific specialty spaces are separated, located within Elementary and Harford Academy academic zones.
- Cluster organization creates smaller learning communities within Elementary and Harford Academy academic zones.


Details	
Square Footage	202,000 gsf
Total Estimated Project Cost	\$123,050,137
40-year Life Cycle Cost	\$289,696,148

Details	
Square Footage	196,000 gsf
Total Estimated Project Cost	\$118,434,136
40-year Life Cycle Cost	\$279,366,053


Details	
Square Footage	201,000 gsf
Total Estimated Project Cost	\$124,262,749
40-year Life Cycle Cost	\$292,245,192









Summary of Options









Option 1 – Bridge	Cost
I. First Costs	
Estimated Project Cost	\$ 102,907,508
II. Maintenance & Operations	
Uniform Present Value of O&M Life Cycle Expenditures	\$ 67,429,562
Uniform Present Value of Utilities Life Cycle Expenditures	\$ 13,142,009
Uniform Present Value of Environmental Health & Safety Expenditures	\$ 958,016
III. Capital Renewal	
Present Value Capital Maintenance Repairs and Replacement	\$ 105,259,053
Total	\$ 289,696,148

Option 2 – Loop	Cost
I. First Costs	
Estimated Project Cost	\$ 99,047,121
II. Maintenance & Operations	
Uniform Present Value of O&M Life Cycle Expenditures	\$ 65,426,704
Uniform Present Value of Utilities Life Cycle Expenditures	\$ 12,751,653
Uniform Present Value of Environmental Health & Safety Expenditures	\$ 929,560
III. Capital Renewal	
Present Value Capital Maintenance Repairs and Replacement	\$ 101,211,016
Total	\$ 279,366,053

Option 3 - Cluster	Cost
I. First Costs	
Estimated Project Cost	\$ 103,921,623
II. Maintenance & Operations	
Uniform Present Value of O&M Life Cycle Expenditures	\$ 67,095,753
Uniform Present Value of Utilities Life Cycle Expenditures	\$ 13,076,950
Uniform Present Value of Environmental Health & Safety Expenditures	\$ 953,273
III. Capital Renewal	
Present Value Capital Maintenance Repairs and Replacement	\$ 107,197,593
Total	\$ 292,245,192








Recommendation


Option 3 *"Cluster"*




- HARFORD ACADEMY (HA)
- SHARED PROGRAM
- **ELEMENTARY SCHOOL (ES)**

The Superintendent of Schools recommends that the Board of Education approve Option #3, with a gross square footage of 201,000.

This option would build a new school, Harford Academy at Campus Hills, in a cluster configuration to replace the current Harford Academy public separate day school and add new elementary school capacity (598 state rated capacity) within Harford County Public Schools.







section 8

appendix

Preliminary Hydrogeologic Feasibility Evaluation

Exhibit 1

Exhibit 2

Exhibit 3

Exhibit 4

Exhibit 5



September 13, 2022

Peter Soprano, P.E. Site Resources, Inc. 14315 Jarrettsville Pike PO Box 249 Phoenix, MD 21131

Re: Harford Academy School Preliminary Hydrogeologic Feasibility Evaluation

File: 2420.003.001

Dear Mr. Soprano:

Barton & Loguidice ("B&L") was retained by Site Resources, Inc. ("SRI") to perform a preliminary hydrogeologic feasibility evaluation of proposed on-premises groundwater supply well and septic system (a.k.a. groundwater discharge systems) at the future site of Harford Academy School (Site). This letter report is intended as an attachment to the SRI overall feasibility report. Readers of this letter report area assumed to have familiarity with the SRI report.

This letter report was prepared and completed in accordance with B&L Proposal No. P708.6049, approved by SRI and Grimm and Parker Architects (G+P) through email Notice-to-Proceed on May 4, 2022, and via a signed agreement on August 9, 2022.

B&L Approach

B&L has performed this preliminary hydrogeologic feasibility evaluation to assess the potential to develop Harford Academy with private well water and septic sanitary facilities in step-wise fashion:

- 1. Review of prior County Health Department and MDE records provided by public agencies, SRI and HCPS.
- 2. Determine feasibility of the Site to support an increase in the well water withdrawal and septic discharges within the existing permitted area.
- 3. Provide SRI recommendations necessary to support approval of an increase in the groundwater discharge permit and a new groundwater appropriation permit.





4. Prepare a memo summarizing work. Answer questions regarding existing site conditions, particularly on the fate of existing supply wells and monitoring wells, and site options concept.

Site Location and History

The Site is the former Lands of Blevins / Schucks Corner proposed residential subdivision. It is located south of the intersection of MD-22 and Schucks Road, south of Harford Community College and Campus Commons shopping center, and east of Bel Air, in Harford County, Maryland (Exhibit 1). Site records on the existing Groundwater Discharge Permit and Groundwater Appropriation Permit exemption history are in Exhibit 2 and Exhibit 3.

Hydrogeologic and Environmental Setting

The Site is underlain by Port Deposit Gneiss. This is a moderately to strongly deformed complex made of gneissic biotite-quartz diorite, hornblende-biotite-quartz diorite, and biotite granodiorite (MGS, 1968).

Soils underlying the Site are identified as mostly Chester Silt Loam and Aldino Silt Loam, with Glenelg loams, Hatboro silt loam and Watchung silt loam seen in a much smaller presence around the border of the Site. Soil classifications in percolation tested areas are described as well drained to moderately well drained. Those in lower lying areas near wetlands and streams, Hatboro and Watchung silt loams, are classified as poorly drained (USDA NRCS, 2022). Aldino and Watchung soils are both listed as restricted wet season soils, and were not percolation tested (Exhibit 4).

Water Use and Population

B&L assessed future water use (wells) and discharge characteristics (septic) using metered flow data at John Archer School (JAS) and data from the past permits and applications, site plans, and information provided by HCPS, G+P architects and SRI on student and faculty population and intended facility use (Exhibit 5). The current JAS population make-up is 138 students and 100 staff.

The HCPS goal for Harford Academy is to have 700 mainstream elementary students and staff and 250 special needs students and staff (**Exhibit 5**) for a total population projection of 950 occupants. Other lower population projections were cited in emails between SRI, G+P Architects and HCPS. Herein we discuss the feasibility of achieving the highest population goals.

Key Harford Academy facility details that influence flow factors for water use (wells) and groundwater discharge (septic) include:



- A therapy pool will be used by special needs students and their support staff. JAS
 currently uses a therapy pool at an off-site location, the intention is for the Harford
 Academy to support a therapy pool on the campus. This pool would also be available to
 outside groups for occupational and physical therapy programs after school hours. To
 our knowledge, during and after school hours, pool use is restricted to individuals with
 special needs and their care providers.
- 2. A shower room will be available for groups using the pool. Mainstream students are not going to use the therapy pool or showers.
- 3. Gym and athletic facilities (aside from the pool) will not have shower facilities.
- 4. A warming kitchen will be used in lieu of a commercial kitchen.
- 5. Outdoor ballfields will not be irrigated.

Table 1. Summary of JAS supply well flow meter data collected monthly in 2019 (no pool included)

Date	Reading	Gallons	Average Use GPD/Person (Students and Staff)
01/03/19	5,770,700		
02/05/19	5,938,300	167,600	21.34
03/08/19	5,979,600	41,300	5.60
04/03/19	6,007,800	28,200	4.56
05/01/19	6,101,100	93,300	14.00
06/04/19	6,229,500	128,400	15.87
07/10/19	6,375,400	145,900	17.03
08/08/19	6,597,300	221,900	32.15
09/04/19	6,804,900	207,600	32.31
10/01/19			
11/05/19	7,201,500	396,600	26.88
12/02/19	7,248,300	46,800	7.28
01/02/20	7,263,700	15,400	2.09

Table 2: JAS 2019 flowmeter data statistics

Statistic	GPD/Person (Student and Staff)	Potential Design Flow @ 1.5 Multiplier (GPD/Person)	Potential Design Flow @ 2.0 Multiplier (GPD/Person)
Minimum	2.09		
Maximum	32.31		
Average	16.28	24.42	32.56
Median	15.87	23.80	31.74



The flowmeter data from JAS (currently without a pool) support a population per capita water use that exceeds previously permitted per capita usage estimates. Former per capita water use approved by MDE for the discharge and groundwater appropriation permits are detailed in *Tables 3, 4 and 5*. The concern with JAS data from 2019 is the frequency in which it was collected and range in per capita use (2 gpd/person to 32 gpd/person), which leads us to question whether this data set is reliable. Thus the previously permitted (discharge to septic) or MDE-approved (well appropriation permit exemption) data sets were relied upon for estimating future flows and assessing feasibility. Subsequent JAS water supply flow meter readings taken on more frequent and preferably daily basis during periods when the school is open may change findings significantly, accordingly.

Table 3. Existing Permitted Capacity and Mainstream Student Per Capita Discharge/Withdrawal

Population and Use Information	MDE Issued Groundwater Discharge Permit (septic)	Application for Groundwater Appropriation Permit (supply well)	MDE Issued Groundwater Appropriation Exemption (supply well)
Mainstream student population	676	696 students + 80 staff	696 students + 80 staff
Average discharge (septic) or annualized average withdrawal (supply well)	5,750 gpd 8.5 gpd/mainstream student	15,520 gpd 20 gpd/mainstream combined student and staff	4,600 gpd 6 gpd/mainstream combined student and staff
Design flow (septic) or month of maximum use (MMU) flow (supply well)	11,500 gpd 17 gpd/mainstream student	19,400 gpd 25 gpd/mainstream combined student and staff	8,200 gpd 11 gpd/ mainstream combined student and staff

Note: Staff to student ratio for mainstream is approximately 1:9, or one staff per every 9 students.



Table 4. Projected Septic Design Flows for MDE Groundwater Discharge Permit Increase

Population	Design Flow Factor*	Notes
Mainstream students	17 gpd/student	From past permits. MDE factors staff use into the student factor.
Special needs students + staff	27 gpd/student + staff	MDE does not factor in staff use, due to a higher staff to student ratio.

^{*}B&L added pool and shower consumptive use per MDE (2011) to the baseline from past discharge permit. The special needs student / staff consumptive use projection is approximately 1.6 times the mainstream.

Table 5. Projected Average and Month of Maximum Use Flows for MDE Groundwater Appropriation Permit Increase

Population	MMU Flow	AVG Flow
Mainstream students	11 gpd/student	6 gpd/student
Special needs students +	22 gpd/student + staff	12 gpd/student + staff
staff* plus water for pool	(assume 2.0 mainstream student	(assume 2.0 mainstream student
p301	multiplier)	multiplier)

^{*}The septic design flow ratio for special needs to mainstream students was increased from 1.6 to 2.0 to account for the pool make-up water usage.

MDE Groundwater Discharge Permit Modification Feasibility

Currently, the proposed septic system for the Site is designed based off numerous previous percolation testing results and past groundwater discharge evaluation. The location of the proposed future septic field is shown in **Exhibit 1**.

Based on the previous percolation testing by Harford County Health Department, with review from MDE, the soil loading rate was assigned to the permitted septic area (Exhibit 2). COMAR 26.04.02.05K allows a loading rate increase from 1.2 gpd/sf to 1.6 gpd/sf or 2.0 gpd/sf, if treatment is upgraded to a Membrane Bioreactor (MBR). MBR effluent requires BOD5 (biochemical oxygen demand) to be less than 3 mg/L, TSS (total suspended solids) less than 1 mg/L and TN (total nitrogen) less than 3 mg/L. Site septic capacity may be increased by a factor of 1.3 to 1.6 using treatment credits alone, and if demonstrated to be hydrogeologically feasible and supported by the past percolation tests. Within these Site constraints, and assuming 250 special needs students and staff, B&L estimates the population, which may be supported by the potential Site septic capacity, in the confines of the previously tested and approved and permitted area (*Table 6*).



Table 6. Site Septic Capacity Constraints with Increased Loading Rate.

Soil Loading Rate	Estimated Potential Site Septic Capacity	Estimated Potential Student + Staff Capacity	Estimated Total Population Supported by Existing Septic Area Soils w/ Increased Loading
1.6 gpd/sf	14,950 gpd	250 special needs students + staff 482 mainstream students + 53 staff, assuming 1:9 ratio	785
2.0 gpd/sf	19,170 gpd	250 special needs student + staff 730 mainstream students + 81 staff	1061

Based on the percolation tests results it appears only portions of the permitted septic area may support a 2.0 gpd/sf loading rate capacity, but not the septic area as a whole. This is because the average Site percolation rate is approximately 7 minutes per inch. Thus, a 2.0 gpd/sf projected population of 1061 does not appear supported by the site constraints. The average percolation rate appears to support use of a 1.6 gpd/sf loading rate and possibly more in certain areas only. Without further detailed analysis, it is our opinion the Site septic capacity limits the population to approximately 785 and one less than the target maximum goal.

Nitrogen Loading and Hydrologic Balance

B&L prepared analyses of hydrologic balance and nitrogen loading analysis of the previously approved septic area using Chesapeake Environmental Management (CEM) 2009 hydrogeological report inputs (**Exhibit 2**). In the prior hydrologic balance/Darcy's Law analyses we identified a calculation error in the reporting. An updated hydrologic balance is in *Table 7* and does not provide hydrogeological support to increase septic discharges at a 1.6 gpd/sf loading rate or 2.0 gpd/sf loading rate. However, hydrogeological inputs may be modified using additional site-specific data collected in a different manner. If proven to align with the hydrogeological inputs from other sites in the vicinity, this could lead to a different (and possibly more favorable) outcome.

The prior nitrogen dilution demonstrated a need for the wastewater to be pre-treated. Because the permitted treatment level is planned to at least 8 mg/L, an updated nitrogen dilution was not needed. However, the discharge permit establishes a yearly nitrogen loading limit of 140 pounds. Site septic capacity increase to the 1.6 gpd/sf loading would require nitrogen treatment to approximately 6 mg/L to meet the existing permit limit. An increase to 2.0 gpd/sf



loading would require nitrogen treatment to 3 mg/L to meet the code requirement as shown in *Table 8*.

Table 7. Hydrologic Balance Analysis

1. Determine the flow (Q_{avg}) that can be transmitted by	the surfi	cial aquifer	
1. Q _{avg} (gpd) = K*i*A * 7.481gal/ft			
Variables	CEM (2009) Site Inputs Reserve Area 1	CEM (2009) Site Inputs Reserve Area 2	
K = horizontal hydraulic conductivity (ft/day)	К	1.7	1.7
i = hydraulic gradient	i	0.03	0.03
A = area normal to flow = b*w (s.f.)	Α	16728	9433
Q _{avg} = average flow (gpd)	Q _{avg}	6382	3599
2. Determine the groundwater recharge (Ravg) due to interest to the second seco	iltration	<u> </u>	1
2. R _{avg} (gpd) = GW * DA / 365 days * 7.481 gal/ft ³			
Variables			
R _{avg} = average recharge to groundwater (gpd)	1930	1822	
3. Determine wastewater flow (Savg) aquifer is capable of	of transm	itting	I
S_{avg} (gpd) = Q_{avg} - R_{avg}			
Variables			
Q _{avg} = average flow (gpd)	Qavg	6382	3599
R _{avg} = average recharge to groundwater (gpd)	1930	1822	
S _{avg} = average allowable wastewater flow (gpd)	4452	1777	
S _{avgtotal} = total average allowable wastewater flow (gpd)	6229		
4. Potential average wastewater flow at 1.6 gpd/sf (gpd)	7475	
5. Potential average wastewater flow at 2.0 gpd/sf (gpd)		9855	
Hydrologic Balance is limiting (Y/N)		Y for 1.6 gpd/sf loading, Y for 2.0 gpd/sf	



Table 8. Wastewater Total Nitrogen Treatment Requirements

Groundwater Discharge Permit Scenario	Design Flow (gpd)	Average Flow (gpd)	Total Nitrogen (mg/L)	Nitrogen Load (Lbs/Day)	Nitrogen Load (Lbs/Year)
Existing GDP Permit at 1.2 gpd/sf	11,500	5,750	8	0.38	140
Modified GDP Permit at 1.6 gpd/sf	14,950	7,475	6.1	0.38	139
Modified GDP Permit at 2.0 gpd/sf*	19,710	9,855	4.6*	0.38	138
* requires 3.0 mg/L TN per code.					

Previous Hydrogeological Analyses for Groundwater Discharge

The Site has past evaluations supporting discharge permits and a limited evaluation of water demand only to support the appropriation permit exemptions. Analysis of the discharge permit evaluations is invaluable to planning for future evaluations to support an increase to the Site permitted capacity. We offered these additional analyses in good faith and at no added expense to SRI, G+P and HCPS.

B&L analyzed past hydrogeological evaluations of the Site and from projects located very close to the Site. A description of the three evaluations follows:

- Study A: Chesapeake Environmental Management (CEM) evaluation discussed previously.
- Study B: A recent (2021-2022) project by B&L at a property adjacent to the Site.
- Study C: A Harford Community College project completed by ALWI (our firm prior to acquisition by B&L)

The following tables (*Tables 9, 10, 11, and 12*) summarize input parameters and results from these prior evaluations, comparing the evaluation methods used at the Site to the current MDE (2015) standard. Specifically for the Site, B&L identifies if, based on our review, further fieldwork is recommended.



Table 9. Slug Testing & Horizontal Hydraulic Conductivity (Kh) Analysis

Study	'Kh' Value	'Kh' Source	Agency Expectation	Recommend Fieldwork or Further Site Analysis?	
A (2009)	12.8 gpd/sf (1.7 ft/day)	Falling head slug tests completed on or around Jan 15, 2009 in 7 temporary piezometers completed in the septic area and of unknown construction and depth	Slug tests following methods outlined by Butler (1997), per MDE (2015) in wells penetrating the receiving aquifer (saprolite)	Slug tests following methods outlined by Butler (1997), per MDE (2015) in wells compared to surarea, possibly du partially screen water table aquishallow piezor	Yes. Low Kh value compared to surrounding area, possibly due to only partially screening the water table aquifer in shallow piezometers
B (2021)	5.9 ft/day	Slug tests, multiple trials, in monitoring wells using methods by Butler (1997)		and/or not using Butler (1997) field methods. Existing monitoring wells can be used for new tests.	
C (2000s)	8.8 ft/day	ft/day Campbell & Nolan Associates, Inc., 2004.		can be used for flew tests.	

Table 10. Hydraulic Gradient (i) Analysis

Study	Hydraulic Gradient	Hydraulic Gradient Source	Agency Expectation	Recommend Fieldwork or Further Analysis?
A (2009)	0.030	Springtime water levels in the temporary piezometers and approximately 50 test pits completed in May 2002, 2004, 2006 and March 2008.	Groundwater contour map based on measurements collected from monitoring wells	Yes, per MDE at Study Site B, wet season water levels from percolation tests are not acceptable for this purpose or to use as a baseline for groundwater mounding analysis. Also MDE requires a groundwater contour flow map, and piezometer locations and
B (2021)	0.017	from monitoring wells during January-July	during the hydrologic wet	levels are not provided in the records. Also the date of
C (2000s)	0.07	Estimate based on land surface	season	measurements are not provided other than they were measured in "spring". Existing monitoring wells can be used for wet season monitoring.



Table 11. Aquifer Thickness (b) Analysis

Study	ʻb'	Thickness Source	Agency Expectation	Recommend Fieldwork or Further Analysis?
A (2009)	Reserve Area 1: 41 ft Reserve Area 2: 30.6 ft	Data from installation of piezometers and test pits	Hollow stem	Yes, supplement data from logs of new hollow stem augered monitoring wells (to replace those being abandoned), plus
B (2021)	37 ft	Water levels and lithologic data from onsite monitoring wells and nearby drilled wells.	auger drilling logs and groundwater level data.	existing monitoring wells in the vicinity. No additional fieldwork required beyond drilling already needed to accommodate the replacement of "to be
C (2000s)	Water levels and lithologic data from onsite monitoring wells and nearby drilled wells.		abandoned" monitoring wells for the site facility plan (e.g. roads).	

Table 12. Mounding Analysis

Study	Result	Source	Agency Expectation	Recommend Fieldwork or Further Analysis?
A (2009)	Reserve Area 1: 2.73 ft; Reserve Area 2: 3.26 ft	Hantush (1967) Method Hantush (1967),		Yes, using input parameters from new hydrogeologic testing. The mounding analysis
B (2021)	1.5 ft	Hantush (1967) Method	per MDE (2015).	with existing parameters (low K) could be problematic.
C (2000s)	3.2 ft	Other GDPs		could be problematic.

The prior hydrologic balance/Darcy's Law analyses would need to be revisited to support a Site capacity increase using new data developed from the Site. Likewise and assuming mounding may increase linearly by a factor of 1.3 to 1.6 due to higher soil loading rates, we project a potential to violate the four foot treatment zone beneath the proposed trenches. Groundwater mounding using different aquifer inputs (e.g. higher Kh) if demonstrated by additional testing, could support a more favorable outcome and thus also are a recommended next step.



Groundwater Appropriation Permit Feasibility

MDE estimates the groundwater recharge associated with an area, using hydrologic budgets developed for, and base flow separation analyses computed from, flow data from nearby streams (Carpenter, 1983). B&L estimated an annual average groundwater recharge rate of 13.6 inches per year based on hydrograph data for the USGS Deer Creek Station as is described by Rutledge (1993). For the Site, B&L estimated a 1-year-in-10 drought-level unit groundwater recharge rate of 319 gpd/acre based on hydrograph data for the USGS Deer Creek Station. The estimated impervious land will be approximately 38% (Exhibit 5) of the total 31.29 acre property. A summary of the water balance for the Site is in *Table 13*.

Table 13. Water Balance

Description	Property Boundary
Property Acreage [1]	31.3
Net Pervious Area [2]	19.5
Total Maximum Allocability (gpd) using 319 gpd/acre [3]	6217.3

^[1] Acreage and square footage was provided by SRI by way of email correspondence and CAD files.

B&L estimates the Site capacity is limited by groundwater appropriation to an average use (supply well) of 6,217 gpd. At this Site cap, and assuming 250 special needs students and staff, B&L estimates 536 mainstream students and staff may be accommodated by the Site. At a 1 to 9 staff to student ratio, the Site appears to support approximately 477 mainstream students (plus roughly 59 staff).

To achieve a higher population likely would require the acquisition of groundwater recharge easements or a relaxation of flow factors or reduction in impervious or some combination of these factors.

A summary of on-Site supply well construction and pumping test results are below in *Table 14*. The concept is to not use these wells as they interfered with the school facility building plans. However, locations for two new wells are planned in areas downgradient of the school facility. We suggest existing wells be monitored during pumping tests of the newly drilled supplies. Existing wells may be abandoned but only after testing, evaluation and permitting are complete.

^[2] Present MDE Source Protection and Appropriation Division policy is to subtract for estimated post-development impervious surfaces.

^[3] Based on an unpublished MDE hydrographic separation analysis performed on Deer Creek.





Table 14. Existing Supply Well Summary

Well	Total Depth (ft)	Well Diameter (in)	Grouted	Casing Depth	Completion Yield (gpm)	Source
HA-95-1542	500	6	Yes	63	30	6 hour pumping test
HA-94-3848	200	6	Yes	48	10	3 hour pumping test
HA-93-0206	400	6	Yes	50	23	6 hour pumping test
HA-93-0754	265	6	Yes	63	15	3 hour pumping test
HA-95-1564	500	6	Yes	26	2	1 hour pumping test

Overall Findings & Recommendations

Our overall finding of well and septic feasibility is summarized in the SRI report. Findings are subject to change pending review and incorporation of new and/or additional information.

Overall, additional fieldwork and analyses are recommended to support an increase in the groundwater discharge permit and issuance of a water appropriation permit for the intended population goal. Future evaluations would need to align with present MDE allocation and groundwater discharge permit practices (MDE, 2015), which were not necessarily in effect at the time MDE issued the initial groundwater discharge permit and groundwater allocation exemption.

Respectfully submitted, BARTON & LOGUIDICE, D.P.C.

Amy M. Parrish, P.G., LEHS Senior Managing Hydrogeologist

AMP/DJK/tmj

David J. Kerr, P.E., B.C.E.E.

Associate

B & **L**

Peter Soprano Harford Academy Hydrogeologic Feasibility Evaluation September 13, 2022 Page 13

Exhibit 1: Site Maps and Concept Drawings

Exhibit 2: Groundwater Discharge Permit Information

Exhibit 3: Groundwater Appropriation Permit Information

Exhibit 4: USDA Mapped Soils Series

Exhibit 5: Emails regarding Water Appropriation and Population Use

References

Advanced Land and Water, Inc. 2009. Preliminary Groundwater Discharge Evaluation Harford Community College; Bel Air, Harford County, Maryland.

Barton & Loguidice, D.P.C. 2022. Confidential hydrogeological analysis of nearby Site.

- Butler, James J., Jr. 1997. The Design, Performance and Analysis of Slug Test. Lewis Publishers, 252 pps. ISBN 9781566702300.
- Carpenter, D.H. 1983. Characteristics of Stream Flow in Maryland. Maryland Geological Survey Report of Investigations No. 35, 237 p.
- Chesapeake Environmental Management (CEM). 2009. Hydrogeologic Analyses in Support of a ground-Water Discharge Permit Application for the Proposed Schucks Road School (C0804).
- Hantush, M. S. 1967. Growth and Decay of Groundwater Mounds in Response to Uniform Percolation. Water Resource Res., 3: 227-234.
- Maryland Department of the Environment (MDE). 2011. Decision Framework for Evaluating Project Flows utilizing OnSite Systems.
- Maryland Department of the Environment (MDE). 2015. Guidelines for Large On-Site Sewage Disposal Systems with a Maximum Accumulative Flows > 5000 Gallons Per Day.
- Maryland Department of Planning GIS. 2017. Maryland Geology Maryland Geologic Formations.

 Maryland Government. Retrieved from https://data.imap.maryland.gov/datasets/maryland-geology-geologic-formations/explore?location=38.791742%2C-77.240600%2C8.95
- Maryland Geological Survey (MGS). 1968. Geologic Map of Harford Map.
- Rutledge, A. T. 1993. Computer programs for describing the recession of ground-water discharge and for estimating mean ground-water recharge and discharge from streamflow record. USGS. Water-Resources Investigations Report 93-4121.
- United States Department of Agriculture (USDA) Natural Resources Conservation Service (NRCS). 2022. Web Soil Survey Harford County, Maryland.

Option 1 — Zoning + Site Approach

Bus

Separate bus loop drop off for HA and ES

HA 18 stacking length, go into one/any cluster

ES 18 busses – go into cluster

Cars


Separate, distinct arrival lobby for HA + ES

Separate parking lot

Play

Play zones located directly outside of Academic Zones

Harford Academy Play Areas contained in central courtyard



Option 2 — Zoning + Site Approach

Bus

Separate bus loop drop off for HA and ES

HA 18 stacking length, go into one/any cluster

ES 18 busses – go into cluster

Cars


Separate, distinct arrival lobby for HA + ES

Separate parking lot

Play

Play zones located directly outside of Academic Zones

Harford Academy Play Areas contained in central courtyard



Bus

Separate bus loop drop off for HA and ES

HA 18 stacking length, go into one/any cluster

ES 18 busses – go into cluster

Cars

Separate, distinct arrival lobby for HA + ES

Separate parking lot

Play

Play zones located directly outside of Academic Zones

Harford Academy Play Areas contained in central courtyard









100 THOMAS RUN RD BEL AIR, MD 21015





C1.01






















14315 Jarrettsville Pike P.O. Box 249 Phoenix, MD 21131-0249 (410) 683-3388 (410) 683-3389 Fax

LETTER OF TRANSMITTAL

To: Attn: Re:	Customer Service of 1800 Washington I Baltimore, Marylan Craig Williams	Boulevard, Suite 735	Road E.S.) (Date: SRI Project SRI Billing of SRI Phase: Groundwater	Group:		on
We are ser	nding you:	☐ Shop Drawings ☐ Electronic Files	☐ Prints ☐ Report		fications oted Below	⊠ Plans	
COPIES			DESCRIPTION	ON			
1	Application for Grou	ındwater Discharge Permit					
1	Facility Location Ma	ap					
				14		ALCOHOL MANAGEMENT OF THE PARTY	
				52-U/C.			
These are	These are transmitted: Approved As Submitted For Approval Returned for Corrections As Requested For Review & Comment Resubmit						
Remarks: Craig – The Hydrogeologic Report has been submitted under separate cover by Chesapeake Environmental Management as we discussed on the phone. Please let me know when you receive that report. Also, as discussed, this project is to be included in the Water & Sewer Master Plan tentatively scheduled for the second Tuesday in April 2009. We will send verification of this when that occurs.							
Cc:	Kevin Barnaba, Harf	ord Co. Health Dept.	Signed:	Jennifer I	Harringto	Xdrrendo, n, P.E.	h_
Delivery N	Aethod: Same	e Day Next Day	AM PM	2 nd Day	U.S.	Mail 🔲 In House	
Delivery E				Time:			
	ay one and a second a						

CONFIDENTIALITY NOTICE: The information herein is confidential and is intended for the use of the individual to whom this cover is addressed. Any use of this information by other than the addressee is prohibited. If you receive this transmission in error, please contact us immediately to arrange the return of this material.



1800 Washington Boulevard • Baltimore MD 21230 410-537-3000 • 1-800-633-6101 • http://www.mde.state.md.us

APPLICATION FOR A STATE GROUNDWATER DISCHARGE PERMIT FOR DOMESTIC WASTEWATER

SECTION A: FACILITY & APPLICANT INFORMATION

1.	Facility Location: (name and address	of facility prod	ducing discharge	or potential dischar	ge)	
	Name: Schucks Elementary School					-
	Audiess					5
	City: Bel Air	County:	Harford		_ Zip:21015	-
	Legislative District: 35A	Co	ouncil District:	В	_	
	Latitude (Deg., Min., Sec.): 39° 33	05"	Longitude	e (Deg., Min., Sec.):	76° 17' 05"	_
2.	Applicant Information (name and ad	dress of respo	nsible person or	organization applyir	ng for the permit)	
	Name: Harford County Pub					
	Address: 102 South Hickory	Avenue				_
	City: Bel Air	County: _	Harford		Zip:21014	
	Telephone No.: 410.809.6124	F	ax No.: _	410.638.3165		
	Workers' Compensation Insurance	Binder/Po	licy Number:			
	Insurance Provider Name:		Policy	Expiration Date:		
	Organization's Federal Tax Identifi	cation or Indiv	idual's Social Se	curity Number:		-
				(Required for renewal or	f permit, see Privacy Act Notice on	page 4
				12 112	V (2)	
3.	Property Owner Information (name	and address of	of property owne	r, if different from ap	oplicant)	
	Name:					
	Address:				1	-
	C ity:	County: _			Zip:	
	Telephone No.:		F ax No.:			

全部和高级特别是视识代	PERICEONIV	
- Service of the light of the service of the servic	IDE USE ONLY	
Assistation in the second		胡椒碱排泄
Application	Number	
APPICATION	The second second second second	STATES AND ASSESSED.
Date Receiv	ed:	
	WHILE COMPONENT OF STREET	of the second of the second
[30][32][32][3][3][3][3][3][3][3][3][3][3][3][3][3]	并是这种的是现在的,并是有一种是一种的人的。	展開開時間開開時

ECTI	ON B: TYPE OF DISCHARGE AND TREATMENT FACILITY
. De	scribe Business and Treatment Facility: (include Standard Indústrial Classification or NAICS Code):
	Elementary School (611117)
. Me	thod(s) of Wastewater Discharge: (Check all applicable spaces)
	Land Application (via Spray Irrigation): [] Overland Flow: [] Subsurface Absorption (via Intiltration Basin): []
	Drain Field: [x] Seepage Pit: [] Injection Well (under pressure): [] Injection Well (dry): []
	Other (including recirculation with no discharge, describe):
•	Method(s) of Wastewater Treatment: (Check all applicable spaces)
3.	Conventional Septic System: [X] Advanced Septic System. [] Lagour System. [] Advanced Septic System.
	Extended Aeration: [] Contact Stabilization: [] SBR: [] RBC: [] Oxidation Ditch: [] Sand Filter: []
	Trickling Filter: [] Other (describe):
4.	Other Potential Sources of Discharge at Facility: (Check all applicable spaces) Holding, storage or treatment ponds/lagoons: [] Aquaculture ponds/tanks: [] Stockpiles and/or waste piles: []
	Mining Activities: [] Salt piles: []
	Landfill [] describe types of wastes received:
	Other: [] (describe):
	CTION C: NATURE OF WASTE, WASTEWATER OR POTENTIAL POLLUTANT
SEC	
1.	Types of Wastewater: (Check all applicable spaces)
	Sanitary [x] Industrial [] Cooling Water [] Water Treatment: [] Sludges [] Process wastewater []
	Aquaculture wastewater []
	Briefly describe how wastewater is generated: Discharge from Elementary School
2.	Quantity of Wastewater and Residuals: Liquids: avg. gal/day:11,500* max. gal/day:11,500*
	a little or Cludge; avg. tons/ day: max. tons/ day:
	Period of Discharge or Operation (mm/dd/yyyy) From:
	Population served: 676 students
	Population Served. One Stadeshie
3.	If aquaculture pond: lbs. of fish per pond:
	Source of Water Supply: Groundwater (wells) [x] Public Supply [] Surface water [] No water used []
	*676 students x 17 gallon/day/student = 11,500 gal/day
	"070 students x 17 ganotifacty states."

Form Number: MDE/WMA/PER.014 Revision Date: January 25, 2005 TTY Users 1-800-735-2258

SECTION D: FACILITY LOCATION MAP & SUPPORTING DOCUMENTS

The application, to be considered complete, must be accompanied by a U.S. Geological Survey topographic map or road map or similar map, at a sufficient scale to adequately show the exact location of the facility which discharges or may discharge, and the exact location of the area used to dispose of any wastewaters generated. Documents necessary to demonstrate the feasibility of the proposed facility such as a hydrogeological study report and verification of conformance with the local Water & Sewerage Master Plan shall also be attached or submitted as supplements to the application.

SECTION E: OTHER ADMINISTRATIVE PERMITS OR ORDERS
List all other State Discharge Permits presently held or applied by the applicant or affiliate:
Identify and list all administrative complaints and/or orders, if any, against the facility of the applicant or affiliate:

SECTION F: SIGNATURE OF APPLICANT OR AGENT

COMAR 26.08.04.01. D.5 requires that applications for a State Discharge Permit be signed by a responsible official as indicated: For corporations, by principal executive officer or authorized representative; For partnerships, by a general partner, For proprietorship, by the proprietor; or, for municipal, State or other public facility, by a principal executive officer, ranking elected official or other authorized employee.

Name and Title (please print)	Phone Number	
Ronald Kauffman, Facilities Planner	410.809.6124	
Signature	Date Signed	and the same of th
Johnsen Harrington, Ag,	ent 1,28.09	

SECTION G: SUBMITTAL OF APPLICATION

Submit one signed original to:

Maryland Department of the Environment

Customer Service Center

1800 Washington Boulevard: Suite 735

Baltimore, Maryland 21230-1720

Forward one signed copy, with any attachments, to the appropriate local government Environmental Health Director. Retain a copy for your records.

SECTION H: NOTICES

- Article §9-323 provides that a person shall hold a discharge permit issued by the Department before Environment the person may construct, install, modify, or operate any wastewater disposal system if it's operation could cause or increase the discharge of pollutants into any waters of the State.
- Environment Article §1-202, provides that the applicant for a permit or license to engage in any activity in which the 2. applicant may employ a "covered employee", as defined in §9-101 of the Labor and Employment Article of the Annotated Code of Maryland shall provide to the Department the policy or binder number of a valid workers' compensation insurance policy that has been issued to the applicant. Such a filing is required before the Department may issue any such license or permit. Alternatively, the applicant shall file a Certificate of Compliance issued by the Maryland Workers' Compensation Commission.
- Article §4-401 defines a "discharge" as the addition, introduction, leaking, spilling, or emitting any Environment pollutant to State waters or the placing of any pollutant in a location where it is likely to pollute.
- COMAR 26.08.04.01.D.4 provides that the Department may require that an applicant for a State Discharge Permit 4. provide additional reports, specifications, plans or other information on the existing or proposed discharge if deemed necessary to allow the Department to adequately evaluate the discharge.
- COMAR 26.08.04.01.D.3 provides that if the discharge is to be from a new facility, preliminary plans and 5. specifications, sufficiently adequate in scope and form to evaluate the proposed facility, shall be submitted with the application.
- COMAR 26.04.02.02. F provides that a person may only dispose of sewage, body or industrial wastes in 6. accordance with an approved on-site sewage disposal permit approved by the local county health officer or other county official authorized to administer environmental laws.
- COMAR 26.08.03.01.A.7 & 04.02.A.3 provide that a discharge must be in compliance with all plans approved by 7. the State prior to the issuance of a discharge permit. This includes the county's comprehensive water and sewer plan.
- Other applicable laws and regulations: 8.

Article: Environmental

Title 4, Subtitle 4: Water Pollution Control and Abatement

Title 9, Subtitle 2: Regulation by State

Title 9, Subtitle 3: Water Pollution Control

Title 9, Subtitle 5: County Water and Sewerage Plans

Code of Maryland Regulations (COMAR):

COMAR 26.03.01 - Planning Water Supply & Sewerage Systems

COMAR 26.04.02 - Sewage Disposal & Certain Water Systems for Homes and other Establishments in the Counties of Maryland Where a Public Sewerage System is not available

COMAR 26.08 - Water Pollution

Privacy Act Notice: This notice is provided pursuant to the Federal Privacy Act of 1974, U.S.C Section 552a. 9. Disclosure of your organization's Federal Tax Identification number or your personal Social Security number with this application is mandatory pursuant to the Maryland Environment Article, Section 1-203 (2003), which requires MDE to verify that applicants for the renewal of permits or licenses have paid all undisputed taxes and unemployment insurance. This information will not be used for any purposes other than those described in this Notice.



Larry Hogan, Governor Boyd K. Rutherford, Lt. Governor

Ben Grumbles, Secretary Horacio Tablada, Deputy Secretary

JUL 18 2018

Certified Mail

Patti Jo Beard, Director of Facilities Harford County Public Schools 102 South Hickory Street Bel Air, MD 21014

RE:

State Discharge Permit No. 17-DP-3666

Campus Hills Elementary School, Harford County

Dear Ms. Beard:

Enclosed is the above referenced discharge permit with the effective date indicated on the cover page. The permittee is responsible for complying with all permit conditions. Therefore, you are advised to read the permit carefully and to become thoroughly familiar with the requirements.

The Maryland Department of the Environment requires NetDMR for filing your required Discharge Monitoring Report (DMR) forms. NetDMR is a freely available Web based tool that allows NPDES permittees to electronically sign and submit their DMRs to EPA via a secure internet connection. NetDMR is designed to improve data quality, reduce reporting liabilities, save paper, and provide cost savings. It allows participants to discontinue mailing in hard copy forms under 40 CFR 122.41 and 403.12. For more information go to the EPA website (www.epa.gov/netdmr) or call the MDE Water Management Administration, Compliance Program, at 410-537-3510 and ask to speak to a NetDMR coordinator.

As indicated in Condition II.C.2 of your permit, before you can submit official DMRs using NetDMR you must attend a training Webinar and successfully set-up and submit test monitoring results electronically. While paper DMR reporting is being phased out, those who are unable to use the NetDMR system may continue to submit paper copies after applying for a waiver (see Condition II.C.2.b). Enclosed are (EPA No. 3320-1) Discharge Monitoring Report (DMR) forms, which, unless you are already using NetDMR, must be completed for each reporting period and submitted to the Department in accordance with the requirements of the permit. Copies of these forms can also be downloaded from the Department's website ((http://cm.gy/MD-DMRForm) Using the latest version of Adobe Acrobat Reader, the DMR form can be completed from a keyboard and printed for mailing to the Department.

You will also find enclosed a copy of the Code of Federal Regulations, 40 CFR Part 136, "Guidelines Establishing Test Procedures for the Analysis of Pollutants." Unless otherwise specified, these guidelines are to be used for the analyses required by this permit. The most current version of 40 CFR Part 136 can be found online at EPA's website. The link is: www.epa.gov/epahome/cfr40.htm.

Please note that the permit authorizes wastewater discharge to groundwaters of the State; discharges to surface waters are prohibited. Please direct all future correspondence regarding permit compliance to the following address:

Compliance Program
Water and Science Administration
Maryland Department of the Environment
1800 Washington Boulevard, Suite 420
Baltimore, MD 21230-1708

If you have any questions, please do not hesitate to call Ching-Tzone Tien, Deputy Program Manager, Wastewater Permits Program at (410) 537-3662.

Sincerely,

D. Lee Currey, Director

Water and Science Administration

Enclosures

cc: Central Inspection Division Chief

Virginia of Keceiney/for

Julie Mackert

William Lee (electronic copy)

Larry Hogan, Governor Boyd K. Rutherford, Lt. Governor

Ben Grumbles, Secretary Horacio Tablada, Deputy Secretary

STATE GROUNDWATER DISCHARGE PERMIT

Permit Number:

17-DP-3666

Effective Date:

August 1, 2018

Expiration Date:

July 31, 2023

Pursuant to the provisions of Title 9 of the Environment Article, <u>Annotated Code of Maryland</u>, and regulations promulgated thereunder, the Department of the Environment, hereinafter referred to as "the Department", hereby authorizes

Harford County Public Schools 102 South Hickory Avenue Bel Air, Maryland 21014

hereinafter referred to as "Permittee", to discharge septic tank - tertiary treated effluent, by absorption trenches as described herein, from:

Campus Hills Elementary School 123 Schucks Road Bel Air, Maryland 21015

to groundwaters of the State in accordance with the following special and general conditions, including the attached maps made a part hereof.

Permit No. 17-DP-3666

Page No.2

I. Special Conditions

A. Waste and Wastewater Limitations

- 1. The Permittee is authorized to discharge treated wastewater via absorption trenches to groundwaters of the State at the site known as Campus Hills Elementary School as shown on Tax Map 42, Parcel 454, and on Map A attached. The Permittee is not authorized to discharge any treated or untreated industrial wastewaters to waters of the State.
- 2. The maximum daily flow to the absorption trenches shall be limited to 11,500 gallons from an educational facility. A construction permit for the pretreatment and disposal systems shall be obtained from the Department prior to installation of same.
- 3. Prior to discharge to the absorption trenches, all wastewaters shall be treated to produce an effluent which does not exceed the following maximum limitations:

	Effluent Limitations					
Parameter Code (STORET)	Parameter Description	Loading		Concentration	Monitoring Frequency	Sample Type
		Yearly Maximum	Monthly Average	Monthly Average		
00310	BOD ₅	N/A	N/A	30 mg/l	Weekly	Grab (2)
00530	Suspended Solids	N/A	N/A	30 mg/l	Weekly	Grab (2)
50050	Flow	N/A	5,750 gpd	N/A	Continuous	Measured
00600	Total Nitrogen ⁽¹⁾	N/A	N/A	8 mg/l	Weekly	Grab (2)
00625	TKN	N/A	N/A	Report Value	Weekly	Grab (2)
00630	Nitrate + Nitrite (N+N)	N/A	N/A	Report Value	Weekly	Grab (²)

(1) Any future expansion of this facility may be limited to no more than 140 lb yearly nitrogen loading requirement which was determined based on 5,750 gpd average daily flow and 8 mg/l effluent nitrogen concentration. Total nitrogen is defined as the sum of Nitrate plus Nitrite and Total Kjeldahl Nitrogen (TKN). The concentration of each constituent shall also be reported.

(2) Grab sample shall be taken between Wednesday and Friday.

4. As specified below, Groundwater samples taken from four monitoring wells per requirements of Section I.C.11.b.and Section I.C.11.c. shall be monitored by the permittee according to the following limitations.

a. The discharge of the wastewater authorized in this permit shall not cause groundwater quality to exceed the limitations listed below, as measured in the designated down gradient monitoring wells MW2 and MW4- shown on Map B. The Table below includes limitations based on the drinking water standards for Nitrite (00615), Total Dissolved Solids (70295), Chloride (00940), and Fecal Coliform (74055).

Parameter Code (STORET)	Parameter Description	Concentration	Monitoring Frequency	Sample Type
		Yearly Average		
00400	рН	(1)	Once every 6 months	Grab
00600	Total Nitrogen (TKN+NO ₂ +NO ₃)	(1)	Once every 6 months	Grab or calculated
00615	NO ₂ Nitrite Nitrogen	1 mg/l ⁽²⁾	Once every 6 months	Grab
00620	NO ₃ Nitrate Nitrogen	(1)	Once every 6 months	Grab
00625	TKN	(1)	Once every 6 months	Grab
00650	PO ₄ -Total Phosphate	(1)	Once every 6 months	Grab
00940	Chloride	250 mg/l ⁽²⁾	Once every 6 months	Grab
70295	Total Dissolved Solids	500 mg/l ⁽²⁾	Once every 6 months	Grab
74055	Fecal Coliform	Non-Detect ⁽²⁾	Once every 6 months	Grab

(1) Monitoring required without limitation

b. For other parameters not included in (a) above, unless the annual average groundwater quality in the background upgradient well ((MW3), MO-95-1713) exceeds the groundwater discharge standards during the reporting period, the discharge of the treated wastewater, which is authorized in this permit, shall not cause an exceedance of the groundwater quality standards adopted by the Department of the Environment in COMAR 26.04.01, and 26.08.02.09.

⁽²⁾ For any reported exceedance, if the average groundwater quality in the background upgradient wells exceeds the groundwater discharge standards, the Department may evaluate whether a violation exists on a case by a case basis.

⁽³⁾ The groundwater quality limitations are not applicable to the upgradient well MW1 and MW3 shown on Map B.

Permit No. 17-DP-3666

Page No.4

B. Effluent and Groundwater Quality Monitoring

- 1. Measurements and Reporting Requirements
 - a. Discharge Monitoring Reports*

Monitoring results obtained each month shall be summarized on a Discharge Monitoring Report form (EPA No. 3320-1). Reports shall be submitted to the Department postmarked no later than the 28th day of the month following the reporting month. One signed copy of these reports shall be submitted to:

Attention: Discharge Monitoring Reports WSA – Compliance Program Maryland Department of the Environment 1800 Washington Boulevard, STE-425 Baltimore, MD.21230-1708

b. Monthly Operating Reports*

The permittee shall submit monthly operating reports on a form supplied or approved by the Inspection and Compliance Program. Reports shall be submitted to the Inspection and Compliance Program postmarked no later than the 28th day of the month following the reporting month.

c. Groundwater Monitoring Report (GMR)*

Groundwater monitoring data required by this permit under Section I.C.11.b.and Section I.C.11.c.shall be summarized on a yearly groundwater monitoring report form. Each report shall be submitted on or before the 28th day of the month following the end of each calendar year to the address shown on I.B.1a. above.

* The permittee is required to submit the Reports via NetDMR in accordance with Section II.C.2.

2. Definitions

- a. The monthly average shall be determined by the summation of all the required measurements divided by the number of days during the month when the measurements were made. The only exception is flow rate which shall be divided by the total number of days each month.
- b. A grab sample is an individual sample collected in less than 15 minutes.
- c. The accumulated nitrogen load per year is the sum of the monthly nitrogen loads within the year. The monthly nitrogen load is the product of the monthly average nitrogen concentration measured in the effluent and the monthly average wastewater flow with appropriate conversion factors.

3. Analysis Methods

The analytical methods used shall conform to test procedures for the analysis of pollutants as identified in "Guideline Establishing Test Procedures for the Analysis of Pollutants" (40 CFR 136), and published in the Federal Register, Volume 41, No. 232-Wednesday, December 1, 1976 or as amended.

4. Monitoring Equipment Maintenance

The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation to insure accuracy of measurements.

5. Data Recording Requirements

For each measurement or sample taken pursuant to the requirements of this permit, the Permittee shall record the following information:

- a. The exact place, date, and time of sampling;
- b. The dates the analyses were performed;
- c. The person(s) who performed the analyses;
- d. The analytical techniques or methods used; and,
- e. The results of all required analyses.

6. Records Retention

All records information resulting from the monitoring activities required by this permit, including all records of analyses performed, calibration and maintenance of instrumentation and original records from flow monitoring instrumentation shall be retained for a minimum of three(3) years. This period may be extended during the course of litigation, or when so requested by the Department.

- 7. The Permittee shall develop a "Manual of Operation and Maintenance". The manual shall clearly state how the entire treatment facility shall be managed to insure satisfactory treatment and operation. The manual shall include:
 - a. Operating and maintenance procedures involving the sewage treatment facility and disposal trenches.
 - b. Testing procedures to determine acceptable maximum application rates and cycles.
 - c. Monitoring and sampling procedures as required in this permit.
 - d. Personnel requirements.
 - e. The wastewater treatment plant and the disposal trench system shall be operated by a Maryland State Certified Operator in accordance with the provisions of COMAR 26.06.01 and consistent with the approved operation and maintenance manual. In order to ensure that the Operator is proficient in the operation of the wastewater system, the operator shall take required training courses, when available, at a frequency approved by the MD Board of Waterworks and Waste Systems Operator. This training shall be specific to the operation of the wastewater system in addition to any other training requirements of the operator's class..

The manual shall be submitted to the Department for approval three (3) months after the issuance date of the Department's Sewerage Construction Permit.

Permit No. 17-DP-3666

Page No.6

C. Absorption Trenches System Monitoring Requirements and Limitations

- 1. Design and installation of the absorption trenches shall be in accordance with COMAR 26.04.02. The pretreatment system and absorption trenches shall be monitored by a certified operator. In addition, the facility engineer or a duly authorized representative shall inspect and check the trenches periodically to determine the efficiency and adequacy of the system.
- 2. Once every three months, the Permittee shall measure and record the water level in the observation pipes installed in the trenches to check the uniformity of effluent distribution and ongoing performance of the trenches.
- 3. The water quality of each existing unconfined individual well within 1/4 mile distance down-gradient from the disposal site shall be sampled prior to the issuance of this groundwater permit to provide baseline water quality. The water samples shall be analyzed for nitrates and fecal coliforms.
- 4. Within three months upon completion of the construction of the disposal system, the Permittee shall submit two complete sets of as-built drawings to the Department. The as-built drawings shall be forwarded to:

Groundwater Discharge Permit Division
Water and Science Administration
1800 Washington Boulevard
Baltimore, Maryland 21230

- 5. The Permittee shall provide an on-site inspector to inspect the system installation during the construction period. The inspector shall ensure that the system is installed according to the approved construction plans. The inspector shall also record any necessary revisions for the purpose of preparing as-built drawings. This requirement is in addition to county health department inspections.
- 6. The Permittee shall provide a minimum of one inspection port per disposal trench. All ports shall be extended to the bottom of the trench.
- 7. The Permittee shall provide a minimum of one piezometer per cell of drainfield for measuring the depth of the groundwater table. The piezometer shall be located at the center of the drainfield. The piezometer shall be extended to at least eight feet below the bottom of the disposal trench.
- 8. A flow recording device shall be installed for measuring the daily sewage flow discharging to the drainfields.
- 9. The initial and reserve areas of the disposal system must be properly maintained and mowed regularly. No trees are permitted to grow on the active drain-field tracts.

- 10. The Permittee shall measure and record the depth of the water table in each piezometer at least once every three months. A minimum of four feet of unsaturated soil must be maintained below the bottom of the disposal trenches at all times. When it is determined that the required 4 foot treatment zone has been violated the certified operator will manage the system by shutting down violating cells or umping and hauling the sewage until the water tables are at a level to return to normal operation of the system.
- 11. The Permittee is responsible for the installation, operation and maintenance of four (4) monitoring wells to be used for obtaining samples of groundwater. These wells are to be used for obtaining grab or pumped samples of the ground water. Locations of the monitoring wells are shown on attached Map B.
 - a. The monitoring wells shall be installed according to the following specifications:
 - 1) Installation of the wells shall be by a licensed Maryland Well Driller in accordance with the following:
 - i. Schedule 40 P.V.C. or better quality well casing, 4-inch diameter shall be used.
 - ii. Commercial well screen or neatly slotted well casing, approved by the Department shall be used in conjunction with a gravel pack.
 - iii. The screen, or slotted casing, shall extend from the seasonally high water table downward approximately 15 feet.
 - iv. The wells shall be grouted from near the top of the screen to ground surface.
 - v. The wells shall be equipped with locking watertight removal caps.
 - 2) The well driller selected to install the observation wells shall obtain all necessary State and local well drilling permits.
 - b. So that the background quality of the ground water may be determined, the monitoring wells in each phase shall be installed in the designated areas immediately after the application for groundwater discharge permit.
 - The Permittee shall take and analyze one sample each month from each of the monitoring wells for a year prior to the discharge of effluent to the absorption trenches.
 - 2) Water samples may be obtained by either pumping or bailing the monitoring wells. Prior to taking the sample, a volume of water equal to 300% of the wetted volume of the casing and screen shall be removed.
 - 3) The water sample shall be analyzed for the parameters shown in Section I.A.4.a.:

c. The Permittee shall take and analyze one water sample every six months from each monitoring well after the start-up of the subsurface absorption system. Samples shall be taken as outlined in I.C.11.b.(2), and analyzed for the same parameters listed in I.C.11 b.(3).

II. GENERAL CONDITIONS

A. Management Requirements

1. Change in Discharge

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant in toxic amounts, as determined by the Department during the effective period of this permit, is prohibited. Any anticipated facility expansion, production increases, or process modifications which will result in new, different, or increased discharge of pollutants shall be reported by the Permittee by submission of a new application at least one year prior to the commencement of the changed discharge or, if such changes will not violate the effluent limitations specified in this permit, by notice to the Department. Following such notice, the permit may be modified by the Department to specify and limit any pollutants not previously limited.

2. <u>Operational Restrictions</u>

The operation of a waste treatment or disposal facility shall at no time create: (1) a direct discharge to surface waters of the State; (2) any standing or ponded water condition on adjacent properties; or (3) a persistent standing or ponded water condition on the Permittee's property, excluding actual storage lagoons.

3. <u>Noncompliance Notification</u>

- a. If, for any reason, the Permittee does not comply with or will be unable to comply with the special and general conditions of this permit, the Permittee shall, within 24 hours, notify the Department by telephone at (410) 537-3510 during work hours and at (866) 633-4686 during evenings, weekends and holidays and provide the Department with the following information in writing within five days of such notification:
 - i. a description of the noncompliance, including its impact upon the receiving ground or surface waters;
 - ii. cause of noncompliance;
 - iii. anticipated time the condition of noncompliance is expected to continue or if such condition has been corrected, the duration of the period of noncompliance;
 - iv. steps taken by the Permittee to reduce and eliminate the noncompliance discharge;
 - v. steps to be taken by the Permittee to prevent recurrence of the condition of noncompliance; and
 - vi. a description of the accelerated or additional monitoring by the Permittee to determine the nature and impact of the noncompliance.

II. GENERAL CONDITIONS

3. <u>Noncompliance Notification continued.....</u>

b. In the case of any discharge subject to any toxic pollutant effluent standard under Section 307 (a) of the Clean Water Act of 1987, the Department shall be notified within 24 hours of the time the Permittee becomes aware of the noncomplying discharge. Notification shall include information as described in paragraph 3.a. above. If such notification is made orally, a written submission must follow within five days of the time the Permittee becomes aware of the noncomplying discharge.

4. Facility Operation and Quality Control

All waste collection, control, treatment, monitoring, and disposal facilities shall be maintained in good working order and operated at all times as efficiently as possible and in a manner which will minimize upsets and discharges of excessive pollutants.

5. Adverse Impact

The Permittee shall take all reasonable steps to minimize any adverse impact to the ground water quality resulting from noncompliance with any limitations specified in this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

6. Removed Substances

The Permittee shall comply with all existing State and federal laws and regulations that apply to sewage sludge monitoring requirements and utilization practices, and with any regulations promulgated pursuant to Environment Article, Section 9-230 et seq. The Permittee is responsible for ensuring that its sewage sludge is utilized in accordance with a valid sewage sludge utilization permit issued by the Department.

II. GENERAL CONDITIONS

A. <u>Management Requirements</u> continued.....

7. Bypassing

Any bypass of treatment facilities necessary to maintain compliance with the terms and conditions of this permit is prohibited unless:

- a. the bypass is unavoidable to prevent loss of life, personal injury or substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources; and
- b. there are no feasible alternatives; and
- c. the Department is notified within 24 hours (if orally notified, then followed by a written submission within five days of the Permittee's becoming aware of the bypass). Where the need for a bypass is known (or should have been known) in advance, this notification shall be submitted to the Department for approval at least ten days before the date of bypass; and
- d. the bypass is allowed under conditions determined by the Department to be necessary to minimize adverse effect; and
- e. there is an existing flow of any such diversion or bypass, then a schedule for the elimination of such shall be included in a schedule of compliance.

B. Responsibility

1. Right of Entry

The Permittee shall allow the Secretary of the Department, or authorized representatives, upon the presentation of credentials:

- a. to enter upon the Permittee's premises where an effluent source is located or in which any records are required to be kept under the terms and conditions of this permit;
- b. to have access to and to copy, at reasonable times, any records required to be kept under the terms and conditions of this permit;
- c. to inspect, at reasonable times, any monitoring equipment or monitoring method required in this permit;
- d. to sample at reasonable times any discharge of pollutants;
- e. to inspect, at reasonable times, any collection, treatment, pollution management or discharge facilities required under this permit; or
- f. to drill and install monitoring wells for the purpose of obtaining samples of the groundwater.

Permit No. 17-DP-3666

Page No. 12

II. GENERAL CONDITIONS

B. Responsibility continued.....

2. <u>Property Rights/Compliance with Other Requirements</u>

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, State or local laws or regulations.

3. Availability of Reports

Except for data determined to be confidential under COMAR 26.08.04.01.F., all reports, plans, maps, or other specifications submitted for review shall be available for public inspection at the Department.

4. <u>Transfer of Ownership or Control</u>

This permit is not transferable to any person except after notice to the Department. The Department may require modification or revocation and re-issuance of the permit to change the name of the Permittee and may incorporate other requirements as may be necessary. The written notice to the Department shall include at least the following information:

- a. the legal name, address and telephone number of the new owner or operator;
- b. a statement, signed by the new owner or operator, indicating that the new owner or operator has read, understands and accepts the terms and conditions of the existing permit; and
- c. the date that the new owner or operator took control or expects to take control of the facility. In the event that new ownership or control is expected in the future, the current Permittee and the anticipated new owner or operator both must sign the written notice to the Department.

5. Reapplication for a Permit

At least one year before the expiration date of this permit, unless permission for a later date has been granted by the Department, the Permittee shall submit an application for renewal of the permit or notify the Department of the intent to cease discharging by the expiration date. In the event that a timely and sufficient reapplication has been submitted and the Department is unable, through no fault of the Permittee, to issue a new permit before the expiration date of this permit, the terms and conditions of this permit are automatically continued and remain fully effective and enforceable.

6. Permit Modification

A permit may be modified by the Department upon the written request of the Permittee and after notice and opportunity for a public hearing in accordance with the reasons set forth in COMAR 26.08.04.10.

II. GENERAL CONDITIONS

B. Responsibility continued.....

7. <u>Permit Modification, Suspension, or Revocation</u>

A permit may be modified, suspended, or revoked by the Department in the event of a violation of the terms or conditions of the permit, or federal or State laws and regulations and in accordance with the procedures set forth in COMAR 26.08.04.10.

8. <u>Civil and Criminal Liability</u>

Environment Article, Sections 9-342 and 9-343 provide that any person who violates a permit condition implementing Environment Article, Section 9-322 et seq. is subject to a civil penalty in an amount not to exceed \$10,000 per day for such violation; and to criminal penalties of a \$25,000 fine or imprisonment not exceeding one year or both for a first offense, and a \$50,000 fine or imprisonment not exceeding two years or both for subsequent offenses.

9. Waterway Construction and Obstruction

This permit does not authorize the construction or placing of physical structures, facilities, debris, or the undertaking of related activities in any waters of the State including the 100-year flood plain.

10. Severability

If any provision of this permit shall be held invalid for any reason, the remaining provisions shall remain in full force and effect, and such invalid provisions shall be considered severed and deleted from this permit.

11. Nuisance and Odor Restrictions

The facility shall be operated at all times to prevent offensive odors from escaping the facility boundaries and to prevent the facility from becoming a public nuisance. In the event that prolonged or excessive odors are noted outside of the property line, the Permittee shall take actions necessary to remedy the problem.

12. Action on Violations

The issuance or reissuance of this permit does not constitute a decision by the State not to proceed in any administrative, civil or criminal action for any violations of State law or regulations occurring prior to the issuance or reissuance of this permit, nor a waiver of the State's right to do so.

II. GENERAL CONDITIONS

C. MONITORING AND REPORTING

1. REPRESENTATIVE SAMPLING

Samples and measurements, if required herein, shall be taken at such times as to be representative of the quantity and quality of the discharges during the specified monitoring periods.

2. SUBMISSION OF REPORTING-MONITORING RESULTS VIA NETDMR

a. NetDMR

Monitoring results obtained during each month shall be reported using NetDMR. Results shall be submitted to the Department no later than the 28th day of the month following the end of the reporting month.

NetDMR is a freely available U.S. EPA tool allowing permittees to submit monitoring reports electronically via a secure Internet application. You must apply for access to NetDMR at www.epa.gov/netdmr and register for a NetDMR Webinar.

Before you can submit official DMRs using NetDMR you must attend a training Webinar and successfully set-up and submit test monitoring results electronically. You must complete all requirements to gain access to NetDMR within six (6) months of authorization under this permit, including applying for access within one (1) month of being registered.

Hard copies of monitoring results obtained before the permittee is granted access to NetDMR shall be submitted postmarked no later than the 28th of the month following the end of the reporting month. Signed copies of the results shall be submitted to the Department at the following address:

Attention: Discharge Monitoring Reports
Compliance Program
Water and Science Administration
Maryland Department of the Environment
1800 Washington Boulevard, STE-425
Baltimore, MD 21230-1708

NetDMR is designed to improve data quality, reduce reporting liabilities, save paper, and provide cost savings. It allows participants to discontinue mailing in hard copy forms. For more information call the MDE Water and Science Administration, Compliance Program, at 410-537-3510 and ask to speak to a NetDMR coordinator.


b. NetDMR Waiver Request

The permittee may be eligible for a temporary waiver by MDE from electronic reporting requirements if the permittee has no current internet access and is physically located in a geographic area (i.e., zip code) that is identified as under-served for broadband internet access in the most recent National Broadband Map from the Federal Communications Commission (FCC); or if the permittee can demonstrate that such electronic reporting of the monitoring data and reports would pose an unreasonable burden or expense to the permitted facility. Waiver requests must be submitted in writing to the Department for written approval at least 120 days prior to the date the permittee would be required under his permit to begin using NetDMR. This demonstration shall be valid for one (1) year from the date of the Department approval and shall thereupon expire. At such time, DMRs and reports shall be submitted electronically to the Department unless the permittee submits a renewed waiver request and such request is approved by the Department. All hardcopy DMRs shall be sent to the following address:


Attention: Discharge Monitoring Reports
Compliance Program
Water and Science Administration
Maryland Department of the Environment
1800 Washington Boulevard, STE-425
Baltimore, MD 21230-1708

<u>Vuguna</u> 4 <u>Keanney/kor</u> D. Lee Currey, Director

Water and Science Administration



Map A. Site Map (Campus Hills Elementary School)



Map B. Locations of Monitoring Wells (MW-1 thru MW-4) and Piezometers (P-1 and P-2)

Department of The Environment Groundwater Discharge Permit Summary Report and Fact Sheet

Executive Summary

Municipal Ground Water Discharge Permit

State Application No.: 17-DP-3666

Facility Name and Location: Campus Hills Elementary School

Schucks Road Bel Air, Maryland

Description of Facility: Public Elementary School

Facility Discharges: Domestic wastewater from the school building is collected by building sewer to septic tanks, treated to reduce nutrients, BOD, and TSS by a treatment plant, and discharged via a pressurized distribution network to deep trench drain-fields.

Pollutants Limited: Subsurface absorption system loading rates require effluent limits of

<30 mg/l BOD5 and TSS and <8 mg/l Total Nitrogen

Changes From Previous Permit: None.

Controversial Provisions: None.

Unusual Conditions: None

Major Facility: No.

Summary of Wastewater Facility

The applicant has applied for a permit to discharge advanced pretreated septic tank effluent to drain-fields and subsequently to groundwater of the State. Information regarding the sewerage facility is summarized as follows:

Sewage effluent from the school building is collected by building sewer and transported to a nutrient reducing treatment plant, thence flowing to a pump station where it is dosed to the subsurface absorption trenches. *Three drain-fields cells are required comprising adequate disposal area for 150% of the sewage flow. Adequate area is also designated for a replacement system adequate to handle 150% of the sewage flow. All proposed systems remain at least 4 feet above the seasonal water table after allowing for groundwater mounding. Total Nitrogen in sewage effluent from the treatment plant is required be less than or equal to 8 mg/l as a measure to mitigate impacts to the Chesapeake Bay and local streams.

As of March 2018, the school has not been built. The school system is renewing the permit so that the school has the necessary permits should that change.

Ground Water Discharge Permit Summary Report and Fact Sheet Page 2

Project Type: Absorption Trench System with Advanced Pretreatment

State Application No.: 17-DP-3666

Facility Name: Campus Hills Elementary School

Address: 123 Schucks Road

County: Harford

Contact (name, title): Patti Jo Beard,

Director of Facilities

Harford County public Schools

Phone: 410-809-4088

Applicant is engaged in: Public Education

Legal Name of Applicant: Harford County Public Schools

Address: 102 South Hickory Avenue

Bel Air, Maryland 21014

Basin Code: <u>02-13-0701</u>

Receiving Water Name(class): Groundwater Type I Aquifer, Port Deposit

Formation.

MD Coordinates: East: 1,001,000 **North:** 627,000

Project Manager: Ching-Tzone Tien

Phone: (410) 537-3662

Ground Water Discharge Permit Summary.Report and Fact Sheet Page 3

Wastewater Characteristics

Design Average Flow: 5,750 **gpd Design Peak Flow:** 11,500 **gpd** from 676 students

Proposed Discharge Period: Year round

Parameter Concentration

Raw Concer	itration *	Treated
BOD5	80 - 190 mg/l	30 mg/l
T.S.S.	48 - 92 mg/l	30 mg/l
Total Nitrogen	63 - 110 mg/l	8 mg/l

^{*}Characteristics of raw wastewater represents the range of values reported by the applicant from 3 similar Harford County schools in November 2007.

Pretreatment Flow Diagram

Septic Tank Effluent ---> Treatment plant ---> Pump Chamber ---> Absorption Trenches

Provide a minimum of 3 treatment cells, each cell with minimum capacity for 50% of design flow for 150% total initial installation. Provide 150% repair area.

Ground Water Discharge Permit Summary Report and Fact Sheet Page 4

Groundwater System

Aquifer Name: Groundwater Type I, Port Deposit Formation

The Port Deposit formation is an important water bearing formation as domestic water supplies are readily obtainable.

Other Properties:

The site is underlain by the soils and rock of the Port Deposit Gneiss rock formation. This formation is described by the Maryland geologic Survey as: "strongly sheared schistose rocks containing secondary muscovite, recrystallized sodic plagioclase, and epidote along with chlorite or biotite and quartz." Soils in this formation are typically described as silty and sandy micaceous soils.

Projected Impact:

The impact on groundwater from the discharge of pretreated septic tank effluent at this site should be negligible. The groundwater discharge permit will limit Nitrogen concentrations in the treatment plant's effluent to less than 8 mg/l total nitrogen because the project occurs in the drainage basin of the Bush River and thence the Chesapeake Bay, impaired due to nutrients. The 8 mg/l total N limit is the effluent quality achievable by the current best available technology (BAT).

The remaining constituents of concern in the wastewater (eg. pathogenic bacteria, phosphorous) will be adequately treated in the four foot unsaturated soil treatment zone that is maintained between the bottom of the absorption trenches and the groundwater. Groundwater mounding studies indicate a greater than 4 foot zone will be maintained as an unsaturated soil treatment zone after groundwater elevation increases due to wastewater loading.

Present Use:

The Port Deposit Formation is used for domestic and agricultural water sources in Harford County. Locally, the groundwater recharges to James Run, tributary to the Bush River and the Chesapeake Bay.

Ground Water Discharge Permit Summary Report and Fact Sheet Page 5

<u>Determining the yearly nitrogen load transported to surface water from the Campus Hills Elementary School large onsite system</u>

(a) Determine the monthly nitrogen load (N_g , lb/month) to groundwater by multiplying the monthly accumulated discharge volume (V, million gallons per month) times the monthly average nitrogen concentration (C, mg/l) measured in the WWTP effluent with a conversion factor of 8.34 for converting mg/l to lb/ million gallons .

$$N_g = V \times C \times 8.34$$

(b) Determine the monthly nitrogen load (N_S) to surface water by multiplying result from (a) to a delivery factor of 50% since the disposal soil absorption bed system is within 1000 ft from Broad Run, a tributary of Bush Creek

$$N_S = N_g \times 50\%$$

(c) The yearly accumulated load to surface water in a calendar year is the sum of the nitrogen load ($N_{\rm S}$) from each of the 12 months determined in item (b) above.



Department of the Environment

Public Hearing for State Groundwater Discharge Permit Application (Permit No. 09-DP-3666) for The Campus Hills Elementary School Wastewater Facility

November 9, 2010

MDE

Discharge Permit Application Summary (Campus Hills Elementary School)

MDE

- Groundwater discharge Permit application received by MDE on 02/23/2009
- Summary of wastewater discharge proposed by the applicant:
 - (1) Proposed wastewater flow: 11, 500 gal/day (daily maximum flow) for 676 students (based on 17 gpd/student)
 - (2) Proposed drainfield area: Approximately 2 acres (perc test area shown on the attached map)
- Site Characteristics: (1) Soil types: Chester silt loam (CcB2) and Glenelg loam (GcC2); (2) Water table depth ranges from 12 ft (northeastern portion) to 16.5ft (western portion) (per Chesapeake Environ. Letter of 1/15/2009) and (3) Direction of groundwater flow: from northwest to southeast)
- A State Groundwater Discharge permit is required for large drainfield system with treated wastewater greater than 10,000 gal/day (max daily flow). The permit will stipulate effluent quality limitations and requirements for groundwater monitoring, system operation, and reporting, etc



Flow: 5,750 gal/day (Monthly average) 11,500 gal/day (maximum)

Starts at about 200 mg/1

- Biochemical Oxygen Demand (BOD-5day) <30 mg/l (monthly average)
- 200 mg/l (monthly average)
- 40-60 mg/l (monthly average), (typicall yearly nitrogen load shall not exceed 140 for home pounds


 Could be about 100 for school)



Proposed Monitoring Requirements (Campus Hills Elementary School)

MDE


- Effluent quality monitoring Take one sample monthly and analyze for BOD, suspended solids, and total nitrogen.
- Four wells are required for groundwater quality monitoring
 - Establish background groundwater quality monthly within 12 months prior to start-up
 - Take one sample per well every six months after startup
 - Analyze groundwater samples for nitrate&TKN, pH, total phosphate, total dissolved solids, chlorides and fecal coliform
- Monitoring water levels in the observation pipes installed in the trenches every 3 months to evaluate trench performance.
- Monitoring water levels in the Piezometers installed in the trench area every 3 months to ensure the four feet unsaturated soil treatment zone is maintained.



Map B. Locations of Monitoring Wells (MW-1 thru MW-4) and Piezometers (P-1 and P-2)

Groundwater Discharge Permit

Application Process





Department of the Environment

Public Information Meeting for State Groundwater Discharge Permit Application (Permit No. 09-DP-3666) for The Campus Hills Elementary School Wastewater Facility

May 28, 2009

MDE

Proposed Drainfield System (Campus Hill Elementary School)


MDE


- Groundwater discharge Permit application received by MDE on 02/23/2009
- Summary of wastewater discharge proposed by the applicant:
 - (1) Proposed wastewater flow: 11, 500 gal/day (daily maximum flow) for 676 students (based on 17 gpd/student)
 - (2) Proposed drainfield area: Approximately 2 acres (perc test area shown on the attached map)

CCB2

- Site Characteristics: (1) Soil type: Glenelg loam (GcC2); (2) Water table depth ranges from 12 ft (northeastern portion) to 16.5ft (western portion) (per Chesapeake Environ. Letter of 1/15/2009) and (3) Direction of GW flow: from northwest to southeast)
- A State Groundwater Discharge permit is required for large drainfield system with treated wastewater greater than 10,000 gal/day (max daily flow). The permit will stipulate effluent quality limitations and requirements for groundwater monitoring, system operation, and reporting, etc








Groundwater Discharge Permit

Application Process





MARYLAND DEPARTMENT OF THE ENVIRONMENT

1800 Washington Boulevard • Baltimore MD 21230 410-537-3000 • 1-800-633-6101

Martin O'Malley Governor

Shari T. Wilson Secretary

Anthony G. Brown Lieutenant Governor

Robert M. Summers, Ph.D. Deputy Secretary

August 26, 2010

Ms. Jennifer Horrington SRI 14315 Jarrettsville Pike Phoenix, MD 21131

Re:

Application for Campus Hills Elementary School WWTP

State Discharge Permit 09-DP-3666, NPDES Permit

Harford County

Dear Ms. Horrington:

The Maryland Department of the Environment (MDE) is aware of your interest in the Campus Hills Elementary School WWTP discharge permit and is advising you that a tentative determination on the application for this permit has been made and a public hearing scheduled on the proposed permit. The hearing has been scheduled for 6:00 PM., November 9, 2010 in the County Council Chambers (first floor), 212 S. Bond St. Bel Air, MD 21014. A copy of the public notice is enclosed for your convenience.

If you have any questions or require additional information on this permit, please contact me at (410) 537-3662 .We look forward to seeing you at the hearing.

Sincerely,

Ching-Tzone Tien, Chief, Ph.D., P. E.

Ground Water Discharge Permits Division

Wastewater Permits Program

Ching Tzone The

Water Management Administration

CT:

Enclosure

MARYLAND DEPARTMENT OF THE ENVIRONMENT WATER MANAGEMENT ADMINISTRATION

NOTICE OF PUBLIC HEARING

Harford County

Application for State Discharge Permit 09-DP-3666:

Harford County Public Schools, 102 South Hickory Avenue, Bel Air, Maryland 21014 submitted an application for a new permit to discharge a maximum of 11,500 gallons per day of treated wastewater from Campus Hills Elementary School located at Schucks Road, Bel Air, Maryland to ground waters via a subsurface soil absorption system.

The Department is proposing to issue the permit with the following limitations and conditions: (1) BOD5: 30 mg/l (monthly average); (2) Suspended solids: 30 mg/l (monthly average); (3) total nitrogen load: 140 lb/year (yearly maximum load based on 8 mg/l nitrogen concentration and daily average flow of 5,750 gpd); and (4) Flow: 11,500 gallons (maximum daily flow). The following conditions are also a part of this permit: 1) The permittee shall monitor the performance of the absorption trench system via inspection ports and piezometers; and 2) The treatment system and disposal fields shall be operated by a Maryland certified operator; and 3) The permittee shall monitor groundwater quality via 4 wells.

The Department has received a request for a public hearing on the tentative determination for the above permit and has scheduled the hearing for **November 9, 2010 at 6:00 PM, in the County Council Chambers (first floor), 212 S. Bond St. Bel Air, MD 21014.** Persons who wish to present information regarding the tentative determination may speak at the public hearing, submit written comments at the public hearing or submit a written statement to the Department no later than **December 9, 2010.** All comments will be considered in making a final determination.

Written comments should be addressed to the Maryland Department of the Environment, Water Management Administration, 1800 Washington Blvd., Baltimore, Maryland 21230-1708, Attn.: Dr. Ching-Tzone Tien Ph.D., P. E., Chief, Ground Water Discharge Permits Division. The supporting information for the tentative determination, including the draft permit and fact sheet, may be reviewed by contacting Dr. Tien at the above address or by telephone at (410) 537-3662 or 800-633-6101 to schedule an appointment. Copies of documents may be procured at a cost of \$0.36 per page.

Any hearing-impaired person may request an interpreter to be present at the public hearing by giving ten working days notice to Dr. Tien at the address or telephone number listed above.

Publication Dates: Please publish on September 10 and 17, 2010

tten: Clarissa Harris ater Permits Program, WMA 2, Balto., MD 21230-1708

MARYLAND DEPARTMENT OF THE ENVIRONMENT 1800 Washington Boulevard • Baltimore, Maryland 21230-1718



Ms. Jennifer Horrington SRI 14315 Jarrettsville Pike Phoenix, MD 21131

TilTitiTes

Indianthealte, the attended the find and and all

Recycled Paper



January 15, 2009

Harford County Public Schools C/o Jennifer Harrington Site Resources, Inc. 14315 Jarrettsville Pike P.O. Box 249 Phoenix, MD 21131-0249

Re: Hydrogeologic Analyses in Support of a Ground-Water Discharge Permit Application for the Proposed Schucks Road School (C0804)

Dear Jennifer:

As required by Maryland Department of the Environment (MDE) regulations, Chesapeake Environmental Management, Inc. (CEM) has performed hydrogeological analyses for the proposed design of the Schucks Road School septic system. The Hydrogeologic Analysis was performed using the Maryland Department of the Environment (MDE) "Guidelines for Land Treatment of Municipal Wastewater, 2003." Attachment 1 contains complete hydrogeologic analyses for the Initial Septic Area. Plate 1 presents a planview diagram of the study area. The proposed septic field is divided into Southwestern (R1) and Northeastern (R2) reserve areas.

1.0 HYDROGEOLOGIC SETTING

The site is located in Harford County, just west of Churchville, and is underlain by the Port Deposit Gneiss, a moderately to strongly deformed intrusive gnessic biotite quartz complex.

Saprolite depths range from 25 to 63 feet in the vicinity of the proposed septic field. The water table generally flows from northwest to southeast across the study area; and the depth to the water table below the septic fields ranges from approximately 12 feet in the northeastern portions of the study area, to nearly 16.5 in the western portions. Hydraulic Conductivity was calculated from falling head slug tests to average 12.8 gpd/sf, and tranmissivity rates were approximately 391-529 gpd/ft.

2.0 GROUND-WATER BALANCE ANALYSIS

The sample MDE calculation for ground-water mounding uses the classic equation of volume rate of flow:

$$Q = KhiA(1)$$

where.

Q = volume rate of flow that can be transmitted by the aquifer;

K = hydraulic conductivity of the aquifer;

I = hydraulic gradient; and

A = cross sectional area of aquifer

The value of K used in CEM's analysis was 12.8 gpd/sf. Table 1 presents the values of K, I and A for each septic reserve area. These parameters were derived from performing slug tests in seven permanently installed piezometers in the area of the septic field, and from data collected during the installation of the piezometers and test pits installed by others.

Table 1. Ground-Water Mounding Parameters

		g = w witters		
Septic Reserve Area	K	Hydraulie Gradient	Cross Sectional Area	
R1	12.8 gpd/sf	9.0 feet/303 feet, or 0.030	41 feet x 408 feet, or 16,728 s.f.	
R2	12.8 gpd/sf	13 feet/438 feet, or 0.030	30.6 feet x 308 feet, or 9,432.50 s.f.	

Using equation (1) above, the volume rate of flow (Q) that can be transmitted by the aquifer was calculated to be 47,505 gallons per day (gpd) beneath R1 and 26,766 gpd beneath R2, flowing southeast to the property boundary.

Using MDE's suggested methodology, the allowable sewage effluent application rate is calculated with the following equation:

$$S = Q - R \quad (2)$$

where,

S = allowable sewage effluent application rate;

Q = volume rate of flow that can be transmitted by the aquifer; and

R = recharge rate to aquifer from precipitation.

The value of R was assumed to be equal to recharge as extrapolated from hydrograph separation of USGS stream discharge measurements from the gaging station at Deer Creek at Rocks State Park, or 1,011 gpd/ac.

Using equation (2) above, S, the allowable daily sewage flow, was calculated to be 45,576 gpd at R1 and 24,944 gpd at R2. The average wastewater flow rate from either proposed septic system is 5,916 gpd. Because the allowable transmissive rate for the proposed fields are far greater than the average proposed application rate, both proposed systems will be able to adequately transmit ground-water recharge and the proposed septic loading.

3.0 NITRATE LOADING ANALYSIS

A nitrate loading analysis was performed for the property to determine whether the proposed septic system would result in elevated ground-water nitrate levels. As per MDE guidelines, approximately 2.12 acres of property is needed to ensure proper dilution of the amount of nitrate contained in every 225 gallons of septic discharge per day.

Because the Schucks Road School septic system is designed for an average daily discharge of 5,916 gpd, a total of 60.07 of property would be necessary for adequate nitrate dilution. The property is approximately 27 acres in size, thus the proposed septic system would required pretreatment to insure that nitrate levels in the ground-water system are below safe drinking water standards.

4.0 GROUND-WATER MOUNDING ANALYSIS

As per MDE requirements, a ground-water mounding analysis was performed for the proposed septic system to determine the ideal trench depth for the system. The Hantush method of calculating ground-water mounding under a rectangular area was used for this analysis. The equation used for this analysis is as follows:

$hx,y,t - H = vt/4f \{ \{ \{ \{ \{ (W/2+x) \} \}, (L/2+y) \} \} \}$ (3)

```
where
hx,y,t = height of the elevated water table;
           original height of the water table;
H
           arrival rate at water table of discharge;
V
       = time since start of discharge;
f
           specific yield;
           length of septic field;
L
W
       = width of septic field;
       = (4tT/f)^{-1/2}; and
n
T
           transmissivity.
```

This mounding value was calculated from the ground-water table, because the highest water table elevation measured in spring from the piezometers and borings emplaced on the property was higher than the bedrock/saprolite interface.

Ms. Jennifer Harrington Schucks Road School Septic Hydrogeologic Analysis January 15, 2009 Page 4 of 4

The value of f was conservatively estimated to be 30%. The value of t was assumed to be twenty years. All other parameter values have been previously presented in this report, and are included in the attached computations.

Using equation (3), an average mounding height of 2.73 feet was calculated below proposed septic field R1 and an average mounding height of 3.26 feet was calculated below proposed septic field R2. The value of (h) plus a 4-foot trench separation buffer was calculated to be an average of 6.73 feet above the water table below R1 and 7.26 feet above the ground-water table beneath R2. Because the water table is located from 9.5 to 16.5 feet below the ground surface, and a minimum of 4 feet is necessary between the septic trench bottom and the high water table, the septic system should be safely designed with a range of trench depths to ensure proper functioning of the system and adequate protection of the local ground-water resources. This range should be from 3.8 to 9.8 feet below ground surface (BGS) in field R1, and from 3.2 to 9.2 feet BGS in field R2.

5.0 CONCLUSIONS

The hydrologic balance analysis of the proposed septic system design for the Schucks Road School septic system indicates that it will be capable of adequately conveying septic discharge and precipitation without detrimental effects on the water table elevation on the property. Nitrate loads to the ground-water system should be pretreated to insure that the discharge will be adequately diluted and will not result in elevated nitrate levels above drinking water standards. Predicted temporary ground-water mounding under the septic fields will require that trenches be designed so that they range in depth between 3.2 to 9.8 feet in depth.

If you are in need of any additional data, or have any questions regarding CEM's analyses, please don't hesitate to call me.


Best Regards.

Joseph A. Hau, P.G.

Vice President

cc: Craig Williams/MDE

<u>ATTACHMENT 1 – HYDROGEOLOGIC ANALYSIS COMPUTATIONS</u>



	Depth	Elevation	Length
Ground Surface	0	365	
Water Table	16	349	
Saprolite/Bedrock Boundary	63	302	
Total Borehole	32	333	
Saturated Screen	30	335	14

Modified Bouwer and Rice $Km=(pi*d^2)/(11*D*(t2-t1)*(InH1/H2))$

d=	10.16 cm
D=	25.40 cm
t1=	30.00 sec
t2=	300.00 sec
h1=	321.87 cm
h2=	193.57 cm

Average Km =

2.19E-03 cm/sec

7.17E-05 ft/sec 6.20E+00 ft/day 5.16E-02 in/min 3.10 in/hr 46.35 gpd/sf


Hvorslev

 $K = (r^2 \ln(L/R))/2Lt$


		r= L= R=	5.08 426.72 25.40	cm
47.47	241.04	37%t=	195.00	sec
Average Km =			4.38E-04	cm/sec
			1.44E-05 1.24E+00 1.03E-02 0.62 9.28	ft/day in/min

Method Average


27.81 gpd/sf



Ground Surface Water Table Saprolite/Bedrock Boundary Total Borehole Saturated Screen Modified Bouwer and Rice	0 13 63 32 30	Elevation 360 347 297 315 330		
$Km=(pi*d^2)/(11*D*(t2-t1)*(lnF)$	11/HZ))			
		d= D= t1= t2= h1= h2=	10.16 25.40 30.00 300.00 414.19 385.24	cm sec sec cm
Average Km =			3 11F-04	cm/sec
/Werage Kiii =			5.1120-	r citiy sec
			1.02E-05	
			8.83E-01	
			7.36E-03	
				in/hr
			6.61	gpd/sf
Hvorslev $K = (r^2\ln(L/R))/2Lt$				
		r=	5.08	cm
		L=	518.16	
		R=	25.40	cm
10.71	395.95	37%t=	120.00	sec
Average Km =			6.26E-04	cm/sec
			2.05E-05	ft/sec
			1.77E+00	
			1.48E-02	
				in/hr
				gpd/sf
Method Average				gpd/sf



Ground Surface Water Table Saprolite/Bedrock Boundary Total Borehole Saturated Screen Modified Bouwer and Rice	Depth 0 15 44 32 30	Elevation 361 346 317 314 331	Length	
Km=(pi*d^2)/(11*D*(t2-t1)*(lnH1/H2))			
		d= D= t1= t2= h1= h2=	600.00	cm sec sec cm
Average Km =			2.72E-04	cm/sec
,				ft/day
Hvorslev $K = (r^2 \ln(L/R))/2Lt$				
13.39	259.24	r= L= R= 37%t=	5.08 457.20 25.40 180.00	cm cm
Average Km =			4.53E-04	cm/sec
				ft/day
Method Average			7.69	gpd/sf



Ground Surface	Depth 0	Elevation 361	Length
Water Table	16.16	344.84	
Saprolite/Bedrock Boundary	44	317	
Total Borehole	32	312.84	
Saturated Screen	30	331	13.84
Modified Bouwer and Rice Km=(pi*d^2)/(11*D*(t2-t1)*(InI	H1/H2))		

d=	10.16 cm	
D=	25.40 cm	
t1=	60.00 sec	
t2=	600.00 sec	
h1=	235.95 cm	
h2=	203.18 cm	

Average Km = 3.21E-04 cm/sec

1.05E-05 ft/sec 9.11E-01 ft/day 7.59E-03 in/min 0.46 in/hr 6.81 gpd/sf


Hvorslev $K = (r^2\ln(L/R))/2Lt$

			r=	5.08 cm
			_=	421.84 cm
			R=	25.40 cm
199	12.12	215.30	37%t=	240.00 sec

Average Km = 3.58E-04 cm/sec

1.17E-05 ft/sec 1.02E+00 ft/day 8.46E-03 in/min 0.51 in/hr 7.59 gpd/sf

Method Average 7.20 gpd/sf



	Depth	Elevation	Length
Ground Surface	0	348	
Water Table	4.66	343.34	
Saprolite/Bedrock Boundary	32	316	
Total Borehole	32	311.34	
Saturated Screen	23	325	18.34

Modified Bouwer and Rice Km=(pi*d^2)/(11*D*(t2-t1)*(lnH1/H2))

d=	10.16	cm
D=	25.40	cm
t1=	60.00	sec
t2=	600.00	sec
h1=	206.50	cm
h2=	145.85	cm

Average Km =

7.47E-04 cm/sec

2.45E-05 ft/sec 2.12E+00 ft/day 1.77E-02 in/min 1.06 in/hr 15.85 gpd/sf

Hvorslev $K = (r^2*ln(L/R))/2Lt$

r= 5.08 cm L= 559.00 cm R= 25.40 cm 22.44 168.29 37%t= 180.00 sec


Average Km =

3.96E-04 cm/sec

1.30E-05 ft/sec 1.12E+00 ft/day 9.36E-03 in/min 0.56 in/hr 8.41 gpd/sf

Method Average

12.13 gpd/sf



	Depth	Elevation	Length
Ground Surface	0	347.5	
Water Table	4.16	343.34	
Saprolite/Bedrock Boundary	25	322.5	
Total Borehole	25	322.5	
Saturated Screen	24	323.5	19.84

Modified Bouwer and Rice Km=(pi*d^2)/(11*D*(t2-t1)*(InH1/H2))

d=	10.16 cm
D=	25.40 cm
t1=	60.00 sec
t2=	600.00 sec
h1=	305.01 cm
h2=	206.26 cm

Average Km =

8.41E-04 cm/sec

2.76E-05 ft/sec 2.38E+00 ft/day 1.99E-02 in/min 1.19 in/hr 17.83 gpd/sf

Hvorslev

 $\mathsf{K} = (\mathsf{r} \land \mathsf{2} \mathsf{In}(\mathsf{L}/\mathsf{R}))/2\mathsf{L}\mathsf{t}$

		r=	5.08	cm
		L=	604.72	cm
		R=	25.40	cm
36.54	242.80	37%t=	240.00	sec

Average Km =


2.82E-04 cm/sec

9.25E-06 ft/sec 7.99E-01 ft/day 6.66E-03 in/min 0.40 in/hr

5.98 gpd/sf

Method Average

11.90 gpd/sf



	Depth	Elevation	Length
Ground Surface	0	372	
Water Table	18	354	
Saprolite/Bedrock Boundary	63	309	
Total Borehole	32	340	
Saturated Screen	30	342	12

Modified Bouwer and Rice Km=(pi*d^2)/(11*D*(t2-t1)*(lnH1/H2))

d=	10.16 cm
D=	25.40 cm
t1=	10.00 sec
t2=	100.00 sec
h1=	185.26 cm
h2=	174.07 cm

Average Km =

8.03E-04 cm/sec

2.63E-05 ft/sec 2.28E+00 ft/day 1.90E-02 in/min 1.14 in/hr 17.03 gpd/sf

Hvorslev $K = (r^2\ln(L/R))/2Lt$

r= 5.08 cm L= 365.76 cm R= 25.40 cm 4.14 178.21 37%t= 30.00 sec

Average Km = 3.14E-03 cm/sec

1.03E-04 ft/sec 8.89E+00 ft/day 7.41E-02 in/min 4.45 in/hr 66.52 gpd/sf

Method Average 41.77 gpd/sf



08035

JAN 3 0 2009

260 Gateway Dr. Suite 21-C Bel Air, MD 21014 SITE RESOURCES

ALTN JENNIFER HARRINGTON
14315 JARRETTSVILLE PIKE
P.O. BOX 249

PHOENIX, MD 21131

156 PB2257592 0080 \$ 01.850 JAN 29 89 3163 MALED FROM ZIP CODE 21014

lydraulic Conductivity Summary										Depth to Bedrock/Water Ta				uifer)				
	MW1	MW2	MW3	MW4	MW5	MW6	MW7	<u>Average</u>		Vicinity	MW1	MW2	MW3	MW4	MW5	MW6		<u>Average</u>
										Depth	63.0	63.0	44.0	44.0	32.0	25.0	63.0	
Area 1	27.8	9.9	7.7	7.2	12.1	11.9	na	12.8	gpd/sf	Area 1	Α	В	С	D	E	F	G	
										Depth	na	na	na	34.5	38.0	53.5	53.5	44.9
													5.0	1	ft.			
Spring 2008 Depth to Water Table S	Summary	1								Length of Discharge Plane)							
	A	В	С	D	E	F	G	<u>Average</u>			Length							
Area 1	na	na	na	10.5	14.0	16.0	16.5	14.3	ft.	Area 1	308.0	ft.						
Elevation																		
												i						
Discharge Vector Gradient (From W	ater Table Obs	servations)								Discharge Vector Lengths								
	High (ft.)	Midpoint	Low (ft.)	Gradient	Southea	ast					<u>Length</u>							
Area 1	17.0	-	4.0	13.0						Area 1	438.0	ft						
	1									Results Summary								
Area of Septic Field	J									Septic Flow:	11,832.0	gpd max		5,916.0	gpd ave	rage		
										Hydrologic Balance:	PASS							
1	308.0	ft.								Nitrate Loading:	FAIL	Pretreatmer	nt Required					
<u>Length</u> Average Width	254.8	ft.								Vicinity	A	В	c	D	E	F	G	
	78,490.0	sf								Water Table	na	na	na	10.5	14.0	16.0	16.5	ft.
<u>Area</u>	70,430.0	31								Mound Height	na	na	na	3.3	3.3	3.3	3.3	
										Buffer	na	na	na	4.0	4.0	4.0	4.0	
										Max. Trench Depth Vicinty	na C-H		na C-J	3.2	6.7	8.7	9.2	
										Water Table	14.5	16.0	16.5	ft.				
										Mound Height	3.3		3.3					
										Buffer	4.0		4.0					
										Max. Trench Depth	7.2		9.2	ft.				

Table 1: Schuck's Road Elementary School School Septic Flow Analysis

(696 Student Basis) Aug-08


Average Weekly Use Program Calculation	Number	Gallons / User / Day	Days in Use	Total Weekly Usage	7-Day Average	5-Day Average
	696	15	5	52,200	7,457	10,440
School (Based on 696 Students)	696	2.	5	6,960	994	1,392
Warming Kitchen	850	5	3	12,750	1,821	2,550
Special Event (625 Gym Cap, 225 Cafeteria Cap) TOTA	_			71,910	10,273	14,382

Maximum Day Program Calculation	Monday	Tuesday	Wednes day	Thursday	Friday	Saturday	Sunda
	10,440	10,440	10,440	10,440	10,440		
School (Based on 696 Students)	1,392	1,392	1,392	1,392	1,392		
Warming Kitchen	1,572	1,00	-,-		4,250	4,250	4,250
Special Event (625 Gym Cap, 225 Cafeteria Cap) TOTAL	: 11,832	11,832	11,832	11,832	16,082	4,250	4,250

MDE Permit Values	Maximum	Averag
School (Based on 696 Students)	10,440	5,220
Warming Kitchen	1,392	696
Special Event (625 Gym Cap, 225 Cafeteria Cap)		
TOTAL:	11,832	5,916

Septic System Analysis Worksheet: Ground Water Balance Analysis (R1) Q = Kh I A where Q = Volume rate of flow that can be transmitted by the surficial aquifer (gpd) Kh = Honzontal permeability of the aquifer (gpd/sf) i = Hydraulic gradient dh/dl dh = Change in head (tt.) dl = Change in head (tt.) A = Cross sectional area of the aquifer (ft*2) = (b x c.) b = Thickness of the aquifer (tt.) c = Width of the aquifer through the discharge plane	R = PA where R = Recharge from precipitation (gpd) P = Recharge from USGS Stream Discharge Measurement Extrapolated from Hydrograph Separation USGS Stream Flow Gaging Station Deer Creek at Rocks State Park A = Area of the Septic field (sq.ft.)	S = Q-R where S = Allowable septic effluent application rate (gpd) Q = Volume rate of flow that can be transmitted by the surficial aquifer (gpd) R = Recharge from precipitation (gpd)					
Area 1 Solutions	P = 1011.00 gpd/ac P = 0.02 gpd/sf A = 78490.00 sf R = 1821.70 gpd	S = Q = 26766.35 gpd R = 1821.70 gpd S = 24944.65 gpd Allowable Transmissive Rate Proposed Septic Discharge = 5916.00 gpd Pass/Fall = PASS S>(Septic Discharge)					

1 Septic System Analysis Worksheet: Ground-Water Mounding Analysis (R1)	
$h_{xy,t}$ - H = (Vt/4f) [4F (α,β)]	Solution
h _{xyt} = Height (m) of water table including mound above confining layer at time t. H = Original water table height (m) above confining layer = b-d b = depth to bedrock d = depth to water table V = Arrival rate at water table of septic effluent (m/day) t = Time since start of recharge (day) f = Filable Porosity F = Septic functions	$\begin{array}{cccccccccccccccccccccccccccccccccccc$
$\alpha = (w/2+x)n^*$ $\beta = (l/2+x)n^*$	F (α,β) = $[(w/2+x)n, (l/2+y)n)]$ From Bouwer (1978) pp. 284-29
w = Width of the system (m) I = Length of the septic system (m) n = (4tT/f)^-1/2 T = Transmissivity (m^2/day) (x,y,t) = Cartesian coordinates of position in septic field at time t	w = 77.73 m w = 77.73 m w = 77.73 m l = 93.94 m l =
	$\alpha = 4.83$ $\alpha = 0.51$ $\alpha = 0.25$ $\alpha = 0.06$ $\beta = 5.83$ $\beta = 0.61$ $\beta = 0.30$ $\beta = 0.07$
Given: b = 44.875 ft = 13.69 m d = 14.250 ft = 4.35 m H = = 93.44 m 1 = 308.000 ft = 93.94 m	$F\left(\alpha,\beta\right) = \boxed{1.00} \qquad F\left(\alpha,\beta\right) = \boxed{0.60} \qquad F\left(\alpha,\beta\right) = \boxed{0.27} \qquad F\left(\alpha,\beta\right) = \boxed{0.03}$ Calculate Mound Height $h_{x_3,t} - H = (Vt/4f) [4F\left(\alpha,\beta\right)] \qquad \text{in meters}$
W = 254.838 ft = 77.73 m V = 5916.00 gpd = 0.0031 m/day	h co.1 · H = 0.010 h co.00 · H = 0.55 h co.365 · H = 1.02 h co.700 · H = 1.99 m
$T_0 = 391.4 \text{ gpd/ft} = 4.86$ $T_{80} = 393.2 \text{ gpd/ft} = 4.88$ m^2/day m^2/day	h aa 1 = <u>9.35</u> h aa 35 h aa 36 h aa 7300 <u>9.89</u> h aa 36 h aa 7300 <u>11.33</u> m
$T_{365} = 394.7 \text{ gpd/ft} = 4.90 \text{ m}^2/\text{day}$ $T_{7200} = 397.9 \text{ gpd/ft} = 4.94 \text{ m}^2/\text{day}$ $f = 0.30 \text{ m}$ $x = 0.00 \text{ m}$	h o o i - H Converted back to feet h o o i - H = 0.03 h o o so - H = 1.80 h o o ses - H = 3.35 h o o seo - H = 6.51 f
y = = <u>0.00</u> m	Maximum Mound Height (Field Center) = 6.51 f Average Mound Height (Entire Field = 1/2 Maximum) = 3.26 f Add 4 foot buffer = 7.26 f



										Depth to Bedrock/Water Tal	ole Summar	v (Thickness	of the Aqu	uifer)				
ydraulic Conductivity Summary										Vicinity	MW1	MW2	MW3	MW4	MW5	MW6	MW7	<u>Average</u>
	MW1	MW2	MW3	MW4	MW5	MW6	MW7	Average			63.0	63.0	44.0	44.0	32.0	25.0	63.0	
										Depth Area 1	Α	В	С	D	Е	F	G	
Area 1	27.8	9.9	7.7	7.2	12.1	11.9	na	12.8	gpd/sf		63.0	63.0	53.5	34.5	na	na	53.5	53.5
										Depth	00.0	00.0	5.0		t.			
													0.0	-				
										Length of Discharge Plane								
Spring 2008 Depth to Water Table S				D	E	F	G	Average			Length							
	Α	В	C			na	16.5	12.5	ft.	Area 1	408.0	ft.						
Area 1	14.5	11.5	9.5	10.5	na	IIa	10.0			10000 II								
Elevation																		
										Discharge Vector Lengths								
Discharge Vector Gradient (From V	Vater Table Obs	ervations)																
					0 4 h -						Length							
	High (ft.)	Midpoint	Low (ft.)		Southe	ast				Area 1	303.0	ft						
Area 1	17.0	-	8.0	9.0											10.70			
	7									Results Summary								
Area of Septic Field										Septic Flow:	11,832.0	gpd max		5,916.0	gpd ave	erage		
										Hydrologic Balance:	PASS							
										Nitrate Loading:	FAIL	Pretreatme	nt Required					
<u>Length</u>	408.0	ft.								Vicinity	A	В		D	E	F	G	
Average Width	203.8	ft.								Water Table	14.5	11.5	9.5	10.5	na	na	16.5	ft.
Area	83,137.0	sf								Mound Height	2.7	2.7	2.7	2.7	na	na	2.7	
										Buffer	4.0	4.0	4.0	4.0	na	na	4.0	
										Max. Trench Depth	7.8		2.8	3.8	na	na	9.8	ft.
										Vicinty	C-H		C-J					
										Water Table	14.5	16.0	16.5	ft.				
										Mound Height	2.7	2.7	2.7					
										Buffer	4.0	4.0	4.0					
										Max. Trench Depth	7.8	9.3	9.8	ft.				
copyright © 2007- may not be copied or	r used without exp	oress written a	uthorization of	СЕМ														

Table 1: Schuck's Road Elementary School School Septic Flow Analysis

(696 Student Basis) Aug-08

Average Weekly Use Program Calculation	Number	Gallons / User / Day	Days in Use	Total Weekly Usage	7-Day Average	5-Day Average
School (Based on 696 Students)	696	15	5	52,200	7,457	10,440
Warming Kitchen	696	2	5	6,960	994	1,392
Special Event (625 Gym Cap, 225 Cafeteria Cap)	850	5	3	12,750	1,821	2,550
TOTAL:				71,910	10,273	14,382

Monday	Tuesday	Wednes day	Thursday	Friday	Saturday	Sunday
10,440	10,440	10,440	10,440	10,440		
1,392	1,392	1,392	1,392	1,392		
				4,250	4,250	4,250
11,832	11,832	11,832	11,832	16,082	4,250	4,250
	1,392	10,440 10,440 1,392 1,392	Monday Tuesday day 10,440 10,440 10,440 1,392 1,392 1,392	Monday Tuesday day Thursday 10,440 10,440 10,440 10,440 1,392 1,392 1,392 1,392	Monday Tuesday Thursday Friday 10,440 10,440 10,440 10,440 1,392 1,392 1,392 1,392 4,250 1,392 1,392 1,392	Monday Tuesday Thursday Friday Saturday 10,440 10,440 10,440 10,440 1,392 1,392 1,392 1,392 4,250 4,250

MDE Permit Values	Maximum	Average	
School (Based on 696 Students)	10,440	5,220	
Warming Kitchen	1,392	696	
Special Event (625 Gym Cap, 225 Cafeteria Cap)			
TOTAL:	11,832	5,916	

Soptic System Analysis Worksheet: Ground Water Balance Analysis (R1) Q = Kh A where Q = Volume rate of flow that can be transmitted by the surficial aquifer (gpd) Kh = Horizontal permeability of the aquifer (gpd/sf) i = Hydraulic gradient dh/dl dh = Change in head (t.) dl = Change in length (ft.) A = Cross sectional area of the aquifer (ft*2) = (b x c) b = Thickness of the aquifer (ft.) c = Width of the aquifer through the discharge plane	R = PA where R = Recharge from precipitation (gpd) P = Recharge from USGS Stream Discharge Measurement Extrapolated from Hydrograph Separation USGS Stream Flow Gaging Station Deer Creek at Rocks State Park A = Area of the Septic field (sq.ft.)	S = Q - R where S = Allowable septic effluent application rate (gpd) Q = Volume rate of flow that can be transmitted by the surficial aquifer (gpd) R = Recharge from precipitation (gpd)
Area 1. Solutions Q	R = PA P= 1011.00 gpd/ac P= 0.02 gpd/sf A= 83137.00 sf R= 1929.56 gpd	S = Q - R Q = 47504.74 gpd R = 1929.56 gpd S = 45575.19 gpd Allowable Transmissive Rate Proposed Septic Discharge = 5916.00 gpd Pass/Fail = PASS S>(Septic Discharge)

1 Septic System Analysis Worksheet: Ground-Water Mounding Analysis (R1)	
$h_{x,y,t} - H = (Vt/4f) [4F (\alpha,\beta)]$	Solution
re	$\begin{array}{cccccccccccccccccccccccccccccccccccc$
$\alpha = (w/2+x)n^*$	
$\beta = (1/2 + x)n^{+}$	F (α, β) = $[(w/2+x)n, (l/2+y)n]$ From Bouwer (1978) pp. 284-29
w = Width of the system (m) Length of the septic system (m) n = (417/0^1-1/2) T = Transmissivity (m^2/day) (x,y,t) = Cartesian coordinates of position in septic field at time t	w = 62.15 m n = 62.15
	α = 3.34 α = 0.35 α = 0.17 α = 0.04
	$\beta = 6.68$ $\beta = 0.70$ $\beta = 0.35$ $\beta = 0.08$
Given:	
b = 53.500 ft = 16.32 m d = 12.500 ft = 3.81 m H = 12.51 m I = 408.000 ft = 124.44 m w = 203.767 ft = 62.15 m	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$
V = 5916.00 gpd = 0.0029 m/day	h _{0.0.1} · H = <u>0.010</u> h _{0.0.59} · H = <u>0.43</u> h _{0.0.385} · H = <u>0.79</u> h _{0.0.790} · H = <u>1.66</u> m
$T_0 = 524.0 \text{ gpd/ft} = 6.51 \text{ m}^2/\text{day}$ $T_{00} = 525.4 \text{ gpd/ft} = 6.52 \text{ m}^2/\text{day}$ $T_{365} = 526.6 \text{ gpd/ft} = 6.54 \text{ m}^2/\text{day}$	h aa: = 12.51 h aa:
T ₇₅₀₀ = 529.4 gpd/ft = 6.57 f = 0.30 x = 0.00 y = 0.00 m	h авл - H Converted back to feet h авл - H = <u>0.03</u> h авло - H = <u>1.41</u> h авло - H = <u>2.60</u> h авлоо - H = <u>5.46</u> ft
	Maximum Mound Height (Field Center) = <u>5.46</u> ft Average Mound Height (Entire Field = 1/2 Maximum) = <u>2.73</u> ft Add 4 foot buffer = <u>6.73</u> ft

Area 1	Septic System	Ana	lysis Workshee	t: Nitrate Loadin	g Analysis
where	А	=	BxC		
	Α	=	minimum acreaç	ge required for av	verage daily nitrate discharge
	В	=	Planned average	e daily septic disc	charge (gpd)
	С	=	acreage require	ment per unit sep	otic discharge (MD regulations require 1.06 acres per 225 gpd of septic discharge)
Given:	in the second				
	В	=	5040.00		
	С	_	5916.00 2.12	gpd ac/225gpd	Assume ∼120 mgl
9	C	_	2.12	ac/225gpu =	Assume ~120 mg
Solution:		0 4 4			
	Α	=	55.74	ac	Required for untreated application
	Site Acreage	=	26.93	ac	Available for application
	Pass/Fail	=	FAIL	Pass if Total Sit	te Acreage > Acreage Necessary for Nitrate Discharge
				Fail if Total Site	Acreage < Acreage Necessary for Nitrate Discharge
			2857.733	gpd	Maximum application rate for proposed acreage without pretreatment
				_	
	07				displaying of CEM
copyright © 200	u/- may not be c	:оріе	a or usea without o	express written aut	thorization of CEM



JOBNO. SCHUCKS RO	2. Sanitary Design
SHEET NO. 08035	OF OF
CALCULATED BY	PA DATE 9 9.08
CHECKED BY	DATE
SCALE	

Daily Usage

474 Studentes x 176pb = 11,500 apd *

*aggume thig incorporates extra activities and can be used as a 7-day average.

Standard Trench design

soil loading rate = 1,2 gpd/sf (using pretreatment) where the trench is 3-ft wide rate = 3. lightly

Std deargn length = usage volume loading

> = 11500 gpd = 3200 LF 3. leg Pd/LF

Site is limited in available space - try

find 3-arras each.

- comer 210.04.02

providing 3200 LF = (W+2) x 100 x Std. length.

31t

gravel below pipe -(depends upor) available verticel distance computed of mounding analysis)



JOB NO. 08000	~ 1	
SHEET NO. SCHUCKS	ROad OF	
CALCULATED BY	M DATE	9.9.08
CHECKED BY	() DATE	

mounding analysis indicates that 4.46 to 8.46 ft is the depth of remaining unesturated depth (see CEM Spreadsheet).

if
$$W=3$$
. $(3+2)$
and $d=2.5$ $(3+1+5)$ × 100 = 55%.

1. deeptrench length = 55% x 3200 = 1775.LF

min spacing Statrenen = 10.5ft. - g'undistorbet min spacing deep trench = 18 Ft. with 3'trenche


$$d = 2.5' \frac{3+2}{3+1+5} \times 100 = 55\%$$

$$d=3.5'$$
 $\frac{21}{3+1+7} \times 100 = 45\%$



JOB NO. 08035	shucks Rd
SHEET NO.	OF
CALCULATED BY	jh DATE 09,10.08
CHECKED BY	DATE
SCALE	

schematically the trench will be as follows.



design will incorporate a 150% design factor where flow will be distributed between at least 3 cells.

for standard trench design the required length of trench is 150% x 3200 UF

1 :



	9c	1			1	20	70	Larens .
JOB NO.	10	110	CK	-5	1	0	-	Lord

SHEET NO. OF

CALCULATED BY

CHECKED BY

DATE

SCALE

Trench layout

Cell A 700 F

Cell B 550 LF

Cell C FOOLF

Call D 600 CF

Gell E 600 CF

(divide by percent as determined for deep trench).

550 + 1,00 = 550 LF

700 + 10,45 = 1540 LF

600 + 0.55 = 1080 LF

600- 055 - 1080 LF

74800CF REDID

Construct Cell A + B as std trenches

construct Cell C as deep trench d = 3.5'

construct cells D+E as deep trench d = 2.5'

cell no.	lengtri	GW.	Scdeptn1 boring	1. STIO Trench	Trench	eguiralent STD trench length	SITE Comprehensive
[]	800 LF	14'	5.5' / 200,201	1.00%	0'	800 LF	E PEC
B.	575LF	14'	55/200,201	100%	0'	575LF	OURCI ning & Site Design S
C	700UF	14'	0 / 203	45%	3.5	1540LF	enices 1
D	600LF	14'	4'/206.	55%	2.5	1080LF	
E	650LF	16'	6//211	55%	2.5	1180LF.	
F	5 55 LF	16	81/204	(00)	0.	555.LF	JOB NO. OR SHEET NO. CALCULATED BY CHECKED BY SCALE
to de	termine	depthia	vailable for se	eptic trenche	es .		28035 1084
7/	av = de grai	ailable buffer	pen of fill or chay depth for deep mounding-				Schucks Rd. OF OF DATE 9.11.08

JOB NO. 08035

16 6.5/207 595 16' 4/209 375

62%. 2.0.

950LF.

62%

2.0.

600 LF.

7280 LF

9600 REDD FOR MAIN+ REGOVERY

2320LF needed.

CHECKED BY	CALCULATED BY	SHEET NO.	JOB NO.
DATE	DATE	OF	

Campus Hills ES - 08035 Date: June 11, 2009

Step 1 - Select Lateral Length

Lateral length is dictated by trench length. Trenches should be a long as possible perpendicular to the gradient of groundwater flow or the gradient of the restrictive horizon. In the absence of specific information of ground water or limiting horizon gradients, it is assumed these gradients are parallel to the surface gradient. Therefore, trenches should be as long as feasible along the contour. Trenches longer than 75 feet typically have a center manifold; trenches shorter than 50 feet typically have an end manifold.

width of trenches -	3 ft	manifold type -	center manifold
depth of trenches -	varies ft	lateral length -	110 ft
depth of stone -	varies ft	number of laterals -	6

Step 2 - Select Perforation Hole Diameter

A 5/16 inch perforation is recommended. A 1/4 inch perforation is acceptable but is more subject to clogging and is bestreserved for use on sloping sites. Using a smaller diameter hole with slightly higher head at the distal end of the lateral may allow for use of a smaller pump.

perforation diameter -

5/16 in

Step 3 - Select Perforation Spacing

Holes in the distribution lateral should be spaced 3 to 10 feet apart. As holes are spaced closer together application of effluent to the absorption area is more uniform, but the system flow rate increases which may require a larger pump.

Special Note for Sloping Sites: Sloping sites present a special set of problems for designing pressure distribution systems. The system must be carefully planned to obtain even distribution to all laterals. The pressure head on each lateral is different due to a different elevation. As the elevation changes by one foot, the pressure head changes by one foot. Hole spacing and diameter must be selected such that there is less than a 10% differential in flow rate between any two laterals.

number of perforations (N) -	20
perforation spacing -	5.5 ft

Step 4 - Determine Lateral Diameter

use figure 4.4 (Sand Mound Systems) to determine lateral diameter for appropriate perforation diameter lateral diameter (d) - 2 in

Step 5 - Calculate Lateral Discharge Rate

Lateral Discharge Rate = number of holes per lateral X discharge rate per hole

H = 2 ft for the first lat	eral		TT	2.0
H = 2 + change in EL		10-00	Н -	2 ft
	for next lateral	$Q_0 =$	discharge rate per hole -	1.63 gpm / hole
$Qo = 11.797d^2H^{1/2}$	$Q_L = 11.797 \text{Nd}^2 \text{H}^{1/2}$	10020	2018 N. 1989	1.05 gpm/ noic
(QL - 11.79/Nu H	$Q_L =$	lateral discharge rate -	32.60 gpm

Step 6 - Select Manifold Diameter and Forcemain Diameter

use Table 4.4 for guideline of appropriate pipe diameter.	manifold diameter -	6 in
	manifold length -	60 ft
	forcemain diameter -	6 in
	forcemain length -	660 ft

Campus Hills ES - 08035 Date: June 11, 2009

Step 7 - Determine Minimum Dose

The minimum dose must be no less than 1/6 X design flow or the volume of (5 x lateral volume) + one manifold volume + one forcemain volume. Use Table 4.2b to determine volumes for 100 feet length of different diameter pipes.

volume/ft for lateral = 17.4 5 x lateral volume = 5 x Length x volume/ft = 574 gal volume/ft for manifold = 150 one manifold = manifold length x volume/ft = 90 gal volume/ft for forcemain= 150 one forcemain volume = FM length x volume/ft = 990 gal 1654 gal design flow = 11850 gpd 1/6 x design flow = 1975 gal **USE MINIMUM** 2000 gal

Step 8 - Determine Minimum System Discharge

The minimum discharge rate = the sum of the lateral discharge rates.

minimum discharge rate -

0.00 gpm

Step 9 - Sizing the Pump

The pump must be capable of delivering the minimum flow rate at the designed total dynamic head (TDH). The minimum flow rate is the minimum system discharge rate. The total dynamic head is the sum of friction losses, the static head (the elevation differential) and the operating head.

1. Friction Loss: (from Table 4.4 in the EPA Design Manual)
friction loss at 200 gpm 0.28 ft per 100 foot length of 6 in. pipe friction loss at 250 gpm 0.41 ft per 100 foot length of 6 in. pipe therefore, friction loss at 219.78 gpm 0.33 ft per 100 foot length of 6 in. pipe

friction loss in 660 LF 2.2 ft

2. Static Head: The distance that the laterals are above the pump inlet is the static head. pump EI = 340 17.0 ft

highest lateral El = 357

3. Discharge Head: 2.0 ft

4. TDH = Friction Loss + Static Head + Discharge Head = 21.2 ft Therefore the pump must be capable of delivering 219.78 gpm against a TDH of 21.2 ft.

Campus Hills ES - 08035

Date: June 11, 2009

Summary of Data Tabulation

	Ground	7			Ta				
	Surface	1.21	Lateral		Perforation		Perforation	1	
FIELD 10	Discovery and the contract of	Lateral	Length		Diameter	Perforation	1 Spacing	Number of	Lateral
C1	Elevation 359.9			Head (feet		(gpm)	(feet)	Perforation	s Flow (gpm)
C2	359.6	355.9	110	2	5/16	1.63	4.23	26	42.38
C3		355.6	110	2.3	5/16	1.75	4.58	24	42.00
C4	359.3 358.9	355.3	110	2.6	5/16	1.86	4.58	24	44.64
C5	358.5	354.9	110	3	5/16	2.00	5.00	22	44.00
C3	338.3	354.5	110	3.4	5/16	2.12	5.50	20	42.40
								Total gpm =	
	Ground		Lateral		Perforation	Flow per	Perforation		
	Surface	Lateral	Length		Diameter	Perforation		Number of	T1
FIELD 2C	Elevation	Elevation	(feet)	Head (feet)		(gpm)	(feet)	Perforations	7.7557110075
C6	358.1	354.1	110	2	5/16	1.63	5.50	20	Flow (gpm) 32.60
C7	357.9	353.9	110	2.2	5/16	1.71	6.11	18	30.78
C8	357.3	353.3	110	2.8	5/16	1.93	6.87	16	30.78
C9	356.7	352.7	110	3.4	5/16	2.12	7.85	14	29.68
C10	356.1	352.1	110	4	5/16	2.30	7.85	14	32.20
C11	355.5	351.5	110	4.6	1/4	1.58	5.50	20	31.60
C12	354.8	350.8	110	5.3	1/4	1.70	6.11	18	30.60
- 111						2	0.11	Total gpm =	218.34
	Ground		Lateral		D- C .:			Total gpin	210.34
	Surface	Lateral			Perforation	Flow per	Perforation		
FIELD 3C	Elevation	Elevation	Length	11 1 (0)	Diameter	Perforation	Spacing	Number of	Lateral
C13	354	350.5	(feet)	Head (feet)	(inches)	(gpm)	(feet)	Perforations	Flow (gpm)
C14	353.5	350.5	110	2	5/16	1.63	5.00	22	35.86
C15	352.5	349.5	110 110	2	5/16	1.63	5.00	22	35.86
C16	351.5	348.5	110	3	5/16	2.00	6.11	18	36.00
C17	351	348	110	4	5/16	2.30	6.87	16	36.80
C18	350	347	110	4.5	5/16	2.44	7.85	14	34.16
CIO	330	347	110	5.5	1/4	1.73	5.50	20	34.60
								Total gpm =	213.28
	Ground		Lateral		Perforation	Elemen	D. C.		
	Surface	Lateral	Length		Diameter	Flow per Perforation	Perforation	No.	
FIELD 1D	Elevation	Elevation	(feet)	Head (feet)	(inches)	E 100 MI 100 MI	Spacing	Number of	Lateral
D1 D2	361	357	110	2	5/16	(gpm)	(feet)	Perforations	
D2	360.5	356.5	110	2.6	5/16	1.63 1.86	5.00	22	35.86
D3	359.9	355.9	110	3	5/16		5.50	20	37.20
D4	359.5	355.5	110	3.5	1/4	2.00 1.38	6.11	18	36.00
D5	359	355	110	3.8	1/4	1.44	4.23	26	35.88
D6	358.7	354.7	110	4.1	1/4		4.58	24	34.56
	33000		- 10	1.1	1/4	1.49	4.58	24	35.76
							···	Total gpm =	215.26
	Ground		Lateral		Perforation	Flow per	Perforation		
0	Surface	Lateral	Length			Perforation	Spacing	Name le C	W. S
FIELD 2D	Elevation	Elevation		Head (feet)	(inches)	(gpm)		Number of	Lateral
D7	358.3	354.3	110	2	5/16	1.63	(feet) 5.00		Flow (gpm)
11.00					2/10	1.00	5.00	22	35.86

Suggest clear procifor viewing the dosing cell

5 Solw 08035_Trench_Design_Comps.xls

^{1.} Separate lines fronchomber


^{2.} LVal2168108035-Schucks Rd Elementary School\Eng & Design\Septic\

Campus Hills ES - 08035

Date:

June 11, 2009

D8	358.2	254.2	110						
D9		354.2	110	2.1	5/16	1.67	5.00	22	36.74
	357.9	353.9	110	2.4	5/16	1.78	5.50	20	35.60
D10	357.5	353.5	110	2.8	5/16	1.93	6.11	18	BOUND STATE OF THE
D11	357	353	110	3.3	5/16	2.09	6.11	18	34.74
D12	356.5	352.5	110	3.8	5/16	2.25			37.62
					3/10	2.23	6.87	16	36.00
								Total gpm =	216.56
120	Ground		Lateral		Perforation	Flow per	Perforation		
	Surface	Lateral	Length		Diameter	Perforation			200
FIELD 3D	Elevation	Elevation	(feet)	Head (feet)		010/ 10 10 10 10 10 10 10 10 10 10 10 10 10	Spacing	Number of	Lateral
D13	355.6	350.6	110	2		(gpm)	(feet)	Perforations	Flow (gpm)
D14	355	350.5	110	2.1	5/16	1.63	5.50	20	32.60
D15	354.2	350.2	Canada a sala		5/16	1.67	6.11	18	30.06
D16	353.5	349.5	110	2.4	5/16	1.78	6.11	18	32.04
D17	352.8		110	3.1	1/4	1.30	4.58	24	31.20
D18		348.8	110	3.8	1/4	1.44	5.00	22	31.68
	352	348	110	4.6	1/4	1.58	5.50	20	31.60
D19	351.3	347.3	110	5.3	1/4	1.70	6.11	18	30.60
								Total gpm =	219.78









IB035-Schucks Rd Etementary School/Dwg/Groundwater_Discharge_Permit_Plan.dwg, 6/16/2009 3:55.53 PM


Date From the property of the	SEQUENCE NO.	CTATE OF	MARYLAND	P 200, 111	STATE PERMIT NUM	BER
Date Recorded (APA) 3	B 7 Z 4 4 0 (MDE USE ONLY)			7 110	1 0- 15	1:0
Date precision (APA) OWNER INFORMATION STATE OF THE Name STATE O	1 2 3 6			9 3 8	4-40-10	104
SI SULDING COUNTY NO. STEEL NO. STEEL STEE		pleas	se type	70 f	ill in this form comp	oletely 79
SUBJOURNESS COUNTY NAME OF PRICE STORY OF STORY WELL WILL DEPARTMENT ADDRESS OF PRICE STORY OF STORY WELL WILL DEPART CON WELL THAT WILL BE SEED AND A SECTION WELL TO A SECTION OF STORY WELL WILL DEPART TO DEPENED WELL STORY OF STORY WELL WILL DEPART TO DEPENED WELL STORY OF STORY WELL WILL DEPART TO DESIGN OF STORY WELL WILL DEPART DO DESIGN OF STORY WELL WILL DESIGN OF STORY WELL WILL DEPART DO DESIGN OF STORY WELL WILL	Date Received (APA)	and the second process of the Parish and the Second	B 3	LOCATION	OF WELL	
THE WELL INFORMATION DOMESTIC PROTRIES DEPTH OF WELL APPROPRIATE BOXY DEPOSITION OF THE TOP TO SET OF THE WELL WILL REPRESE A PERSONAL PROVINCE APPROPRIATE BOXY DEPOSITION OF WELL INFORMATION APPROXIMATE DIAMETER OF WELL SET OF THE TOP THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE TOP THE WELL WILL REPRESE APPROPRIATE BOXY APPROXIMATE DIAMETER OF WELL SET OF THE TOP THE WELL WILL REPRESE APPROPRIATE BOXY DESCRIPTION OF THE WELL SET OF THE TOP THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE TOP THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE TOP THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF THE WELL SET OF THE WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF WELL WILL REPRESE APPROPRIATE BOXY DEPOSITION OF WELL WILL REPRESE	2 2110 Y OWNER INFORM	MATION	HARPON	4)		
STEED AND STREET OF READ STATE STREET OF WELL PROPERTIES DAYS AS PECIAL CONDITIONS STEED AND STREET OF STREET OF STREET STORM STREET S	8 MM DD YY 13		8 COUNTY	1	21	
SCHOOL 44 46 LOT 49 50 MP - UN W STATE STA	Harfard Co. Public -	Schools	1 L/0 Shuc	ks (OMPT	1
Section No. Service Proposed Section No. Service Proposed No. Service Name Defens	15 Last Name Owner	First Name 34	23 SUBDIVISION		_	42
Service of RPD APPLICATION DRILLER INFORMATION DRILLER INFORMATION Delie 3 TO Subs 172 Zp 76 TO Subs 174 Zp 77 TO Subs 1	102 S. Hickory St.	and the second	SECTION	LOTI	3	1
SPECIAL CONDITIONS TO SINIE 72 ZIP 76 DRILLER INFORMATION TO SENIE 72 ZIP 76 DRILLER INFORMATION TO SENIE 2 ZIP 76 TO MILES FROM TOWN (enter 0 if in lown) 2 M 1 ZIP 76 77 78 MILES FROM TOWN (enter 0 if in lown) 2 M 1	36 Street or RFD	55			50 MF- U	MWI
57 TOWN 70 SIMILE 72 ZIP 76 DRILLER INFORMATION 70 SIMILE 72 ZIP 76 DRILLER INFORMATION 70 LICENSE No. B1 JOHN WELL INFORMATION DITE 12 ZIP 76 77 77 78 SE PRAINT OWN (order 0 if in low) 2 M. 1 J 79 77 77 78 MILES FROM TOWN (order 0 if in low)	Bel Ais al	71014	Cl. rebuil	10		
MILES FROM TOWN (enter 0 if in lower) MILES FROM TOWN (e	57 Town 70 State 7:		52 NEAREST TOWN			71
MILES FROM TOWN (enter 0 il in low) TO LIGHT Name THE			oz wzwiest town		3	, ,
DOMESTIC POTABLE SUPPLY A RESIDENTIAL RAPPROXIMATE DEPTH OF WELL APPROXIMATE DEPTH OF WELL AS A STANDAY CONTROL OF WELL APPROXIMATE DEPTH OF WELL AS A STANDAY CONTROL OF WELL APPROXIMATE DEPTH OF WELL AP	D -0 11-16	11 - 7-4	MILES FROM TOWN (ent	ter 0 if in town)		
DISCRITION OF WELL FROM TONIN (CIRCLE SOR) THIS Manne WELL INFORMATION ADMESS SUPPLIFIES SEPTION OF WELL FROM TONIN (CIRCLE SOR) SUPPLIFIES SEPTION OF WELL FROM TONIN (CIRCLE SOR) SUPPLIFIES SEPTION OF WELL FROM TONIN (CIRCLE SOR) ON WHICH SIDE OF ROAD ON	Drillar's Name	License No. 91	B A	14	73 70 11 1	0
DIRECTION OF WELL FROM TOWN MAJOR FATURES OF SUPPRISON WALLS S		License No. 81		102		00
Address B 2 WELL INFORMATION Date W CIRCLE APPROPRIATE BOX W W CONN E SIGNATURE B 2 WELL INFORMATION ON WHICH SIDE OF ROAD ON WHICH SIDE OF SAME ON WHI	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		DIRECTION OF WELL FROM	100	Schucks	red.
Supposition Supposition S	· · · · · · · · · · · · · · · · · · ·	11 0 - '211	TOWN (CIRCLE BOX)	11	NEAR WHAT ROAD	30
Signature Signature B 2 WELL INFORMATION APPROX PUMPING RATE (GAL PER MIN) AVERAGE DAILY QUANTITY NEEDED (GAL PER DAY) DOMESTIC POTABLE SUPPLY & RESIDENTIAL INFIGATION DOMESTIC POTA		11c max 21084		ON WHI	CH SIDE OF ROAD	
SIGNATURE Supplier Date			W B E			X)
B 2 WELL INFORMATION APPROX PUMPING FATE (GAL PER MIN) APPROX PUMPING FATE (GAL PER MIN) APPROX PUMPING FATE (GAL PER MIN) DISTANCE FROM ROAD (GAL PER MIN) APPROX WATER (GIRCLE APPROPRIATE BOX) DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION F PARHMING LUVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMING LUVESTOCK WATERING & AGRICULTURAL IRRIGATION THE MAINING LIVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMING LIVESTOCK WATERING & AGRICULTURAL IRRIGATION THE MAINING LIVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMING LIVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMIN LIVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMIN LIVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMIN MAIN LIVESTOCK WATERING & AGRICULTURAL IRRIGATION F PARHMIN LIVESTOCK WATERING F PARHMIN LIVESTOCK WATERING F PARHMI	Vavel 1884	2-25-08	8-9			WEST CLEAST
APPROXIMATE DEPTH OF WELL APPROXIMATE DEPTH OF	Signature	Date	W (TOWN) E		34 545 3	7 SOUTH
AVERAGE DAILY QUANTITY NEEDED AVERAGE DAILY QUANTITY NEEDED LOSE FOR WATER (CIRCLE APPROPRIATE BOX) DOMESTIC POTABLE SUPPLY A RESIDENTIAL IBRIGATION FARMING [LIVESTOCK WATERING & AGRICULTURAL IBRIGATION IRRIGATION PUBLIC WATER SUPPLY WELL TO TEST, OBSERVATION, MONITORING G GEOTHERMAL APPROXIMATE DIAMETER OF WELL APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIVEN METHOD OF DRILLING (circle one) JETTED Jetted & DRIVEN MITH AN X SOURCES OF DRILLING WATER 1. 2. 3. WRITE THE BOX NUMBER FROM THE MAP HERE E DRIVEN STATE WITH AN X WRITE THE BOX NUMBER FROM THE MAP HERE E DRIVEN SHOWN AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE SHAPP OF THE MAP (B RELATION TO NEARBY TOWNS AND ROADS AND GIVE SHAPP OF THE MAP (B RELATION TOWNS A		0	1		DISTANCE FROM RO	DAD
USE FOR WATER (CIRCLE APPROPRIATE BOX) USE FOR WATER (CIRCLE APPROPRIATE BOX) DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION E FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) PUBLIC WATER SUPPLY WELL T) TEST, OBSERVATION WONITORING G GEO-THERMAL APPROXIMATE DEPTH OF WELL APPROXIMATE DEPTH OF WELL APPROXIMATE DIAMETER OF WELL WITH AN X SOURCES OF DRILLING WATER WETHOD OF DRILLING (circle one) BORED (or Augered) WETHOD OF DRILLING		12	IS IS	0338	66 SENTER FT C	OR MI 38 39
USE FOR WATER (CIRCLE APPROPRIATE BOX) USE FOR WATER (CIRCLE APPROPRIATE BOX) DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION E FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) 1 INDUSTRIAL COMMERICIAL, DEWATERING P PUBLIC WATER SUPPLY WELL T) TEST, OBSERVATION WONITORING G GEO-THERMAL APPROXIMATE DEPTH OF WELL 43 M 00 V 46 CO SIGNATURE EXP. DATE SIGNATURE DATE ISSUED AND ISSUED INDUSTRICE POPOLOGE THIS WELL WILL DATE ISSUED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS ADDRAW AS ASKETCH BELOW SHOWING LOCATION OF WELL IN MAP IS DATE ISSUED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A SANDBY-CONTACT LOCAL APPROVING AUTHORITY POR POLICY ON STANDBY WELL TO THE THE BOX NUMBER FROM THE MAP HERE E DOO DOO NO DATE ISSUED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A SANDBY-CONTACT LOCAL APPROVING AUTHORITY POR POLICY ON STANDBY WELL TO THE THE BOX NUMBER IS TO NUMBER FROM THE MAP HERE E DOO DOO NO DOO NO DATE ISSUED THE WELL HEPLACE A WELL THAT WILL BE USED AS A SANDBY-CONTACT LOCAL APPROVING AUTHORITY POR POLICY ON STANDBY WELL TO BE REPLACED OR DEEPENED THIS WELL WILL HEPLACE A WELL THAT WILL BE USED AS A SANDBY-CONTAC			W S E	TAY MAD	42 - 4R.	454
DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION F FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) 1 INDUSTRIAL COMMERICIAL, DEWATERING P PUBLIC WATER SUPPLY WELL T) TEST, OBSERVATION MONITORING G GEO-THERMAL APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) BORED (or Augerd) METHOD OF DRILLING (circle one) BORED (or Augerd) METHOD OF DRILLING (circle one) METHOD OF DR			8	TAX MAP: _	BLK:	PARCEL
DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION F FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) 1 INDUSTRIAL COMMERICIAL, DEWATERING P PUBLIC WATER SUPPLY WELL T TEST, OBSERVATION MONITORING G GEO-THERMAL APPROXIMATE DEPTH OF WELL 43 W 10 W 48 CO SIGNATURE DATE ISSUED DATE ISSUE	USE FOR WATER (CIRCLE APP	ROPRIATE BOX)	NOT T	O BE FILLE	D IN BY DRILLER	7
DIRECTION FIRMANIS (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) FOR FOLIO (LIVEST						
COUNTY NAME STATE SIGNATURE DATE ISSUED LISSUED		IAL	Llevisod			17
STATE P PUBLIC WATER SUPPLY WELL T) TEST, OBSERVATION MONITORING G) GEO-THERMAL APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) Jefted & DRIVEN BORRE REVISED Jetted & DRIVEN BORRE REVISED WHAT AN X SOURCES OF DRILLING WATER 1. 2. 3. 3. WAITE THE BOX NUMBER FROM THE MAP HERE DISTANCE FROM WELL IN DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN METHOD THIS WELL WILL REPLACE A WELL THAT WILL BE AS A SHADOP CONTROL TO LOCAL APPROPRIATE BOX) THIS WELL WILL DEEPEN A RISTING WELL THIS WELL WILL DEEPEN A RISTING WELL TO THIS WELL WILL DEEPEN A RISTING WELL THIS WELL WILL DEEPEN A RISTING WELL THIS WELL WILL DEEPEN A RISTING WELL TO THIS WELL WILL DEEPEN A RISTING WELL THIS WELL WILL DEEPEN AN EXISTING WELL THIS WELL WILL DEEPEN AND THE THI	- FARMANO // INFOTOCK MATERIALO & ACRIC	CHITHBAL	COUNTY NAME		COUN	JTY NO
DATE ISSUED P PUBLIC WATER SUPPLY WELL T) TEST, OBSERVATION MONITORING) G GEO-THERMAL APPROXIMATE DEPTH OF WELL 24 28 FEET APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIVEN BORNE REVerse-ROTary AIR-PERGussion ROTARY (Hydraulic Rolary) THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE AS A SANADOVE CONTACT LOCAL APPROPRIATE BOX) THIS WELL WILL DEPEN A RISTING WELL THIS WELL WILL DEPEN AR RESTRICATION TO REARST TOAD JUNCTION THIS WELL WILL DEPEN AR RISTING WELL THIS WELL WILL DEPEN AR RISTING WELL THIS WELL WILL DEPEN AR RISTING WELL THIS WELL WILL DEPE		OCCIONAL				
DATE ISSUED AT EIST, OBSERVATION, MONITORING G GEO-THERMAL APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) JETTED JETTED JETTED JETTED JETTED JOHON POLICY OF AUGUST OF THE BOX) WHAT THIS WELL WILL NOT REPLACE AN EXISTING WELL Y ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED JETTING WELL WILL REPLACE A WELL THAT WILL BE USED THIS WELL WILL REPLACE A WELL THAT WILL BE USED THIS WELL WILL REPLACE A WELL THAT WILL BE USED THIS WELL WILL REPLACE A WELL THAT WILL BE USED THIS WELL WILL DEPPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) AND OF VAS CONTROL COCAL APPROPRISE BOX) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO THE REPLACE OF DATE NOT TO REAREST ROAD JUNCTION APPROPP. PERMIT NUMBER PERMIT NO THE REATE END SITURE BOURCES OF BRILLING WRITE THE BOX NUMBER PERMIT NUMBER	22 I INDUSTRIAL COMMERICIAL DEWATERING	3	SIGNATURE /		INSERT S	41
TT TEST, OBSERVATION MONITORING G GEO-THERMAL APPROXIMATE DEPTH OF WELL APPROXIMATE DEPTH OF WELL APPROXIMATE DIAMETER OF BOX & LOCATE WELL APPROXIMATE DEPTH OF WELL APPROXIMATE DIAMETER OF BOX & LOCATE WELL APPROXIMATE DIAMETER APPROX			DATE ISSUED	(aux	Dans	0/01/1000
G GEO-THERMAL APPROXIMATE DEPTH OF WELL 24 28 NEAREST INCH APPROXIMATE DIAMETER OF WELL APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIVEN MAIR-ROTary AIR-PERGussion ROTARY (Hydraulic Rolary) THIS WELL WILL REPLACE AN EXISTING WELL THIS WELL WILL REPLACE AN WELL-THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE AN WELL-THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 17-17-17-17-17-17-17-17-17-17-17-17-17-1	P PUBLIC WATER SUPPLY WELL		12/24/2008	(au)	BURCHER	3/01 KW
GRID 50 50 50 50 50 50 50 50 50 50 50 50 50	T TEST, OBSERVATION, MONITORING				and the second second	EXP. DAVE
APPROXIMATE DEPTH OF WELL 24 28 SHOW MAJOR FEATURES OF BOX & LOCATE WELL WITH AN X SOURCES OF DRILLING WATER SOURCES OF DRILLING WATER METHOD OF DRILLING (circle one) JETTED Jetted & DRIVEN METHOD OF DRILLING (circle one) ARR-PERcussion ROTARY (Hydraulic Rolary) TOTARY REVerse-ROTary DRIVE-POINT Other REPLACEMENT OR DEEPENED WELLS (CICICLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 49 PERMIT NO. 47 70 71 72 73 74 75 76 77 77 77 78 79 SPECIAL CONDITIONS	G GEO-THERMAL		GRID 06400	0 0 GR	ID / UU /	
APPROXIMATE DEPTH OF WELL 24 28 FEET NEAREST APPROXIMATE DIAMETER OF WELL 4 NEAREST INCH 5 METHOD OF DRILLING (circle one) JETTED Jetted & DRIVEN JETTED Jetted & DRIVEN 30 AIR-ROTary AIR-PERGussion ROTARY (Hydraulic Rotary) 37 CABLE REVerse-ROTary DRIVE-POINT other REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER PERMIT NO. FOR POLICY ON STANDBY WELLS NOOD N APPROP. PERMIT NUMBER PERMIT NO. FOR THE MORE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. FOR THE MORE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. FOR THE MORE OR COUNTY USE ONLY) SPECIAL CONDITIONS			50	55	5/	63
APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DIAMETER OF WELL APPROXIMATE DIAMETER APPROXIMATE DI						
APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) JETTED Jetted & DRIVEN AIR-PErcussion ROTARY (Hydraulic Rolary) TABLE REVerse-ROTary DRIVE-POINT Other REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. PERMIT NO. THE METHOD OF DRILLING WATER 1. 2. 3. WRITE THE BOX NUMBER FROM THE MAP HERE DOWN DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP 1 B RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBST ROAD JUNCTION APPROP. PERMIT NUMBER PERMIT NO. THE METHOD OF DRILLING WATER 1. 2. 3. WRITE THE BOX NUMBER FROM THE MAP HERE DOWN DOWN N DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN MAP 1 B RELATION TO NEARBST ROAD JUNCTION APPROPAGE FROM WELL TO NEARBST ROAD	APPROXIMATE DEPTH OF WELL 39	FEET			6	
APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) JETTED Jetted & DRIVEN AIR-PERclussion ROTARY (Hydraulic Rodary) TABLE ORDER REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED THIS WELL WILL REPLACE A WELL THAT WILL BE USED THIS WELL WILL BEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	. 24	28		WATER		
METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIVEN AIR-ROTary AIR-PERGUSSION ROTARY (Hydraulic Rolary) Other REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS PERMIT NO. STANDS SPECIAL CONDITIONS	APPROXIMATE DIAMETER OF WELL 4			WAIEN	and the second	
METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIVEN JETTED Jetted & DRIVEN ROTARY (Hydraulic Rolary) REVerse-ROTary DRIVE-POINT oither REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL-THAT WILL BE ABANDONED AND SEALED JETTED DRIVE-POINT ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS		INOTI	2		X	3
BORED (or Augered) JETTED Jetted & DRIVEN AIR-PERCussion ROTARY (Hydraulic Rotary) AIR-PERCussion ROTARY (Hydraulic Rotary) AIR-PERCussion ROTARY (Hydraulic Rotary) AIR-PERCussion ROTARY (Hydraulic Rotary) DRIVe-POINT other REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL-THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	METHOD OF DRILLING (circle one)	100		$\omega = \omega$	Millionania, sup marin control
ARPHOLARY AREHOLARY OTHER REVERSE ROTARY DRIVE POINT OTHIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED APPROP. PERMIT NUMBER PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS WRITE THE BOX NUMBER FROM THE MAP HERE U000 N DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY ROAD JUNCTION N (R4, 22) N REPLACEMENT OR DEEPENED O00 N DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY ROAD JUNCTION N (R4, 22) N REPLACEMENT OR DEEPENED O000 N DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY ROAD JUNCTION N (R4, 22) N SPECIAL CONDITIONS	BORED (or Augered) JETTED	Jetted & DRIVEN	0.		43	
DRIVE-POINT OTHER REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 S2 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER G PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	30 AIR-ROTary AIR-PERcussion R	OTARY (Hydraulic Botary)	WRITE THE BOY NUMBE	В		
REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER G PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	37			n e		
REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL-THAT WILL BE ABANDONED AND SEALED S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 PERMIT NUMBER GOT WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 PERMIT NUMBER GOT WELL TO BE REPLACED OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NUMBER SPECIAL CONDITIONS		Dilive-i Olivi	FROM THE MAP HERE			
(CIRCLE APPROPRIATE BOX) THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER G PERMIT NO. HA - 96 - 1004 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	otner	4	- 1000			
THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL-THAT WILL BE ABANDONED AND SEALED 39 S THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 S2 NOT to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NUMBER PERMIT NO. 170 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS			E		000	
THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 NOT to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS		,	102	o	000	
ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT NO. HAPPONDE PERMIT NUMBER PERMIT NO. HAPPONDE PERMIT NUMBER SPECIAL CONDITIONS RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEARBY TOWNS AND GIVE DISTANCE F	THIS WELL WILL NOT REPLACE AN EXISTIN	G WELL	N			map 18
THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT No. 4 - 95 - 104 - 107 78 79 SPECIAL CONDITIONS DISTANCE FROM WELL TO NEAREST ROAD JUNCTION Churchy Itc Rd. N PERMIT No. 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS		ILL BE				10101
AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER G PERMIT No. HA - 95 - 104 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS						66
FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41 Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP PERMIT NUMBER PERMIT No. HA - 96 - 100 + 4 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	S THIS WELL WILL REPLACE A WELL THAT W		DISTANCE FROM WELL	TO NEAREST I	HOAD JUNCTION	
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	FOR POLICY ON STANDBY WELLS	ia no monini		01		1
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	THIS WELL WILL DEEPEN AN EXISTING WEL	L		The	Churchvill	c Rel.
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS		DEEPENED	N (Rt. 22)	4	and the same of th	and the second s
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS			IV (11		
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	Not to be filled in by driller (MDE OD CO	HINTY HEE ONLY	A		blobers	-
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	Not to be lined in by driner (NIDE OR CO	ONTITUDE UNLT)		3 - 50	Chales !	Counter
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	APPROP. PERMIT NUMBER	G		31 1	Jhon J	1 1
PERMIT No. 777 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	*	0-		St. A	X elentar	y school
70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS	PERMIT NO HA-	45 -1m4		N	Site	
		73 74 75 76 77 78 79		1	1112	44
	SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED -					0




SEQUENCE NO.	CTATE OF	MADY AND		STATE PERMIT NUMB	ER
B 7 C441 (MDE USE ONLY)		MARYLAND	. 11	1 0- 12	25
1 2 3 6		ERMIT TO DRILL WELL se type	70	H-10-100	70
2.4.	piouo		_ fi	ill in this form compl	letely ⁷⁹
Date Received (APA)		B 3 H225005	LOCATION	OF WELL	
8 MM DD YY 13	MATION	8 COUNTY		21	
Harford Co. Public Sch	2-16	110 Shu	456	orner	
15 Last Name Owner	First Name 34	23 SUBDIVISION		311111	42
102 Si Hickory St	4.	OFOTION I	1071	3	503
36 Street or RFD	55	SECTION 44 46	LOT	50 MI 1	154
Bel Air MR	2/014	Churchal	le		- 7
	72 Zip 76	52 NEAREST TOWN			71
DRILLER INFORMATION		MILES FROM TOWN (ent	er 0 if in town)	2 MI	
DAVID Kelly M	WD 304			73 76 77 78	
Driller's Name 76	6 License No. 81	B 4 1 1 2	103	- 1 1 0	0
Jones Weel Willing Inc.	5	DIRECTION OF WELL FROM	10-	Schools 19	<u>P.</u>
13700 Rush R.J. Jarralts	46012	TOWN (CIRCLE BOX)	11	NEAR WHAT ROAD	30
Address	lile, ma	NW 8 NE		CH SIDE OF ROAD	NORTH
D 1/600.	2-20-08	8-9 8-9	(CIHCLE	APPROPRIATE BOX	
Signature	Date	TOWN E		34 90 4 37	WEST S EAST
B 2 WELL INFORMATION	^			DISTANCE FROM ROA	000111
1 2 APPROX. PUMPING RATE (GAL. PER MIN.) 8	12		02396	SZ ENTER FT OF	R MI 38 39
(GAL. PER MIN.) 8 AVERAGE DAILY QUANTITY NEEDED	0	S W 8-9 S 8-9	TAV MAD.	42 BLK: 4B PA	ARCEL 454
(GAL. PER DAY) 14	20	8	TAX WAF		AHUEL
USE FOR WATER (CIRCLE APP	PROPRIATE BOX)			D IN BY DRILLER	
D DOMESTIC POTABLE SUPPLY & RESIDENT	TIAL	// / PEALI	H DEPARTI	MENT APPROVAL	
IRRIGATION		Hartora		/.	2
F FARMING (LIVESTOCK WATERING & AGRIC	CULTURAL	COUNTY NAME STATE		COUNT	TY NO.
22 INDUSTRIAL, COMMERICIAL, DEWATERING	G	SIGNATURE		JNSERT S -	7 /41
INDOGITAL, COMMENTOIAL, DEWATERING		DATE ISSUED	/h. 1	Pinne AZ/	21/2009
P PUBLIC WATER SUPPLY WELL		43 MM DD YY 48	CO SIGN	DIDUIT OF	XP. DATE
T TEST, OBSERVATION, MONITORING		NORTH 1626	· FAS		,
G GEO-THERMAL		GRID 50	0 0 GRI	ID 57 0	63
		SHOW MAJOR FEATURE	S OF	12 13 B	ner papanes para papanes
APPROXIMATE DEPTH OF WELL 30	FEET	BOX & LOCATE WELL '-		250	
24	28	WITH AN X	WATER		
APPROXIMATE DIAMETER OF WELL	NEAREST INCH	SOURCES OF DRILLING 1.	WAIER	N	
		2.		X 9-	
METHOD OF DRILLING (3.		- 1	
BORED (or Augered) JETTED ALD DOT	Jetted & DRIVEN				
AIH-HUTary AIH-PEHcussion H	ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBE	.R	W	
CABLE HEVerse-HOTary	DRive-POINT	FROM THE MAP HERE		8	
other		- 1000			
REPLACEMENT OR DEEPEN		E //000		000	
(CIRCLE APPROPRIATE E		N 620	-	000	
		N		CATION OF WELL IN	~ 1019
THIS WELL WILL REPLACE A WELL THAT W ABANDONED AND SEALED	ILL BE	DRAW A SKETCH BELOW RELATION TO NEARBY T	TOWNS AND RO	OADS AND GIVE	MATTIO
THIS WELL WILL REPLACE A WELL THAT W		DISTANCE FROM WELL			E6
39 S AS A STANDBY-CONTACT LOCAL APPROVIN FOR POLICY ON STANDBY WELLS	NG AUTHORITY		81	P.	
THIS WELL WILL DEEPEN AN EXISTING WEL	LL		Pel	~ 0 - 0 - No	00
PERMIT NUMBER OF WELL TO BE REPLACED OR		N PG+. 22		Churchite	FOC.
(IF AVAILABLE) 41	52	IV	3	110005	· D
Not to be filled in by driller (MDE OR CO	DUNTY USE ONLY)	A	3	il There	- Carpen
			4:	(a) Show	Lo - A
APPROP. PERMIT NUMBER	G	9. A	(0)	elem	Tary School
HA -	95 - 1005		2	Y X SIT	2
PERMIT No. / / / - 70 71 72	73 74 75 76 77 78 79			4 3	
SPECIAL CONDITIONS					A
NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED =					●




EMERGENCY/TE	EMP NO. IF ANY
(MDE USE ONLY) APPLICATION FOR PL pleas	MARYLAND ERMIT TO DRILL WELL e type STATE PERMIT NUMBER HA - 95 - 1006 70 fill in this form completely 79
Date Received (APA) 8 MM DD YY 13 Harfiel C. Public Schools 15 Last Name Owner First Name 34 16 Street or RFD 55 Bel Hin Mel 2/014 57 Town 70 State 72 Zip 76 DRILLER INFORMATION	B 3 LOCATION OF WELL 8 COUNTY LO SHUCKS COMON 23 SUBDIVISION 42 SECTION LA 46 LOT B 50 MF-TB3 Churchy le 52 NEAREST TOWN 71
David KELLY MW D 304 Driller's Name 76 License No. 81 Jones Well Dr. II ing Inc. Firm Name 3700 Rush Af Tanathsville, and 210544 Address Signature Date B 2 WELL INFORMATION 1 2 APPROX. PUMPING RATE (GAL. PER MIN.) 8 12 AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14 20	MILES FROM TOWN (enter 0 if in town) B 4 DIRECTION OF WELL FROM TOWN (CIRCLE BOX) N NEW HOLES APPROPRIATE BOX) NORTH
USE FOR WATER (CIRCLE APPROPRIATE BOX) D DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION F FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) 22 I INDUSTRIAL, COMMERICIAL, DEWATERING P PUBLIC WATER SUPPLY WELL T TEST, OBSERVATION, MONITORING G GEO-THERMAL	NOT TO BE FILLED IN BY DRILLER HEALTH DEPARTMENT APPROVAL COUNTY NAME COUNTY NO. STATE SIGNATURE DATE ISSUED 41 A1 A1 A1 A1 A1 A1 A1 A1 A1
APPROXIMATE DEPTH OF WELL 24 28 APPROXIMATE DIAMETER OF WELL NC (1) NEAREST INCH	SHOW MAJOR FEATURES OF BOX & LOCATE WELL
METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIVEN AIR-ROTary AIR-PERcussion ROTARY (Hydraulic Rotary) TOTAL OTHER REVERSE-ROTARY DRIVE-POINT Other REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX)	WRITE THE BOX NUMBER FROM THE MAP HERE E
THIS WELL WILL NOT REPLACE AN EXISTING WELL Y THIS WELL WILL REPLACE A WELL THAT WILL BE ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS D THIS WELL WILL DEEPEN AN EXISTING WELL PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED (IF AVAILABLE) 41	DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEAREST ROAD JUNCTION ELLOW AND Christian Relation Research Road Junction Research Road Junction Research Road Research Road Research Road Research Road Research Research Road Resear
Not to be filled in by driller (MDE OR COUNTY USE ONLY) APPROP. PERMIT NUMBER PERMIT No. HA-96-1000 70 71 72 73 74 75 76 77 78 79 SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED =	Proposed Schucks Corener elemtary school Site




DAAO SEQUENCE NO.	07175.05		STATE	PERMIT NUMBER
B 7 Z 4 4 6 (MDE LISE ONLY)		MARYLAND	111	BE IMY
1 2 3 6		ERMIT TO DRILL WELL	HA -	10 -100
	pleas	se type	70 fill in this	s form completely 79
Date Received (APA)		B 3	LOCATION OF WE	ELL
OWNER INFORMA	ATION	HARFOIL		1
8 MM DD YY 13	1	8 COUNTY	1	21
Harford Co. Public Sc	hooks	160 Shuc	KS Corn	er
15 Last Name Owner Fi	irst Name 34	23 SUBDIVISION		42
102 S. Hickory St.	1	SECTION	LOT 1 13 1	MAC TRY
36 Street or RFD	55	44 46	48 50	MIF-101
bet HIR ma	21014	Chischville		1
57 Town 70 State 72	Zip 76	52 NEAREST TOWN		71
DRILLER INFORMATION		MILES FROM TOWN (enter	O if in town)	2 м 11
Javid Kelly MU	D304	III.220 Y I I O III Y O I I I O I I I O I I I O I I I O I I I I O I I O I I	73	76 77 78
Driller's Name 76	License No. 81	B 4	1.00	
Tones Well Dalling Inc.	_1	1 2 DIRECTION OF WELL FROM	105 Schoo	eks Rd.
Firm Name	21084	TOWN (CIRCLE BOX)	11 NEAR	R WHAT ROAD 30
3700 Rush Pd. JAIRETSVI	lle Ma	N	ON WHICH SIDI	E OF BOAD NORTH
Address		NW 8 NE	(CIRCLE APPRO	OPRIATE BOX)
Havid Relly	2-20-08	8-9		WEST S EAST
Signature	Date	W (TOWN) E	34	/023 37 SOUTH
B 2 WELL INFORMATION	0	8	DISTAL	NCE FROM ROAD
1 2 APPROX. PUMPING RATE (GAL. PER MIN.) 8	12	SW SE C	3386635	ENTER FT OR MI 38 39
AVERAGE DAILY QUANTITY NEEDED	0	8-9 S 8-9	TAX MAP: 42 B	BLK: 4B PARCEL 454
(GAL. PER DAY) 14	20	8		
USE FOR WATER (CIRCLE APPRO	OPRIATE BOX)		BE FILLED IN B	
DOMESTIC POTABLE SUPPLY & RESIDENTIA	ıL	HEALTH	I DEPARTMENT	APPHOVAL
IRRIGATION		Hartora		12
F FARMING (LIVESTOCK WATERING & AGRICU	LTURAL	COUNTY NAME		COUNTY NO.
- IRRIGATION		STATE SIGNATURE/		INSERT S -
22 I INDUSTRIAL, COMMERICIAL, DEWATERING		DATE ISSUED	0 . 1	2 41/2
P PUBLIC WATER SUPPLY WELL		2/29/2008	Can A	Sucre 3/01/07
T TEST, OBSERVATION, MONITORING		43 MM pb yy 48	CO SIGNATURE	EXP. DATE
G GEO-THERMAL		GRID OCOLO 0	0 0 EAST /	00/ 000
GEO-THERIMAL		50	55 57	63
		SHOW MAJOR FEATURES	OF	
APPROXIMATE DEPTH OF WELL 30	FEET	BOX & LOCATE WELL '_		
24	28	SOURCES OF DRILLING W	/ATER	8 8 3
APPROXIMATE DIAMETER OF WELL	NEAREST INCH	1.	in line	
		2.	1 13	X 2 8 8 8
METHOD OF DRILLING (cir.	cle one)	3.		
BORED (or Augered) JETTED	Jetted & DRIVEN	3		3
	TARY (Hydraulic Rotary)	WRITE THE BOX NUMBER		S W B
37 CABLE REVerse-ROTary	DRive-POINT	FROM THE MAP HERE		$\equiv \omega \equiv$
other		\		(3)
REPLACEMENT OR DEEPENE	D WELLS	E /000	000	
(CIRCLE APPROPRIATE BO			000	
THIS WELL WILL NOT REPLACE AN EXISTING	WELL	N 620		
THIS WELL WILL REPLACE A WELL THAT WILL	∟ BE	DRAW A SKETCH BELOW	SHOWING LOCATION	OF WELL IN
ABANDONED AND SEALED		RELATION TO NEARBY TO		
S THIS WELL WILL REPLACE A WELL THAT WILL AS A STANDBY-CONTACT LOCAL APPROVING		DISTANCE FROM WELL TO	NEAREST ROAD JU	NCTION
FOR POLICY ON STANDBY WELLS	AUTHORIT	1 2	3	
D THIS WELL WILL DEEPEN AN EXISTING WELL		(2 -1	C	hurchville Rel
PERMIT NUMBER OF WELL TO BE REPLACED OR DI	EEPENED	N (Rt. 22)	1	The state of the s
(IF AVAILABLE) 41	52	14	7: 18	
Not to be filled in by driller (MDE OR COU	NTY USE ONLY)	A	3 100	proposed
		7	3 7	Chucks Grner
APPROP. PERMIT NUMBER	_G		3 X	Clevestry
I III C	25 1007		(X)	School School
PERMIT No. 71.70.71	10-1001	A		Jones
70 71 72 73	3 74 75 76 77 78 79	l.	-	
SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED =				⊕




			OTATE DEE	MIT NUMBER
B 1 2449 SEQUENCE NO.	STATE OF	MARYLAND	STATE PER	MIT NUMBER
I I I I I I I I I I I I I I I I I I I	PPLICATION FOR P	ERMIT TO DRILL WELL	1 HA - 90	5-1008
		se type	70	79
		T-T-T		rm completely
Date Received (APA)		B 3 HARRON	LOCATION OF WELL	
8 MM DD YY 13	IATION	8 COUNTY	1 - 3	<u> </u>
	chools	110 Shace	ks Carpi	
.,0.,,0.,	First Name 34	23 SUBDIVISION		42
102 S, Hickory St.	riist Name 34	23 300011131011	1 13	42
	55	SECTION	LOT 48 50 N	1F-DMW5
36 Street or RFD		44 40	11 48 50 77	July 3
DER HIR MA	2144	Churchy	1/10	
57 Town 70 State 72 DRILLER INFORMATION	Zip 76	52 NEAREST TOWN		71
1 / 100	. 7014	MILES FROM TOWN (ente	er 0 if in town)	M I
	W D 304	D 4	73	76 77 78
Driller's Name 76	License No. 81	B 4 1 2	107 50	.0. 00
Joses Well Villing Inc		DIRECTION OF WELL FROM	105 Jenus	45 /9.
Firm Name		TOWN (CIRCLE BOX)	11 NEAR WE	IAT ROAD 30
3700 Rush Pd. Janetsville	md 21084	NNN	ON WHICH SIDE O	
Address		N _W 8 N _E 8-9	(CIRCLE APPROPR	IATE BOX) WEEF
12000	-20-09	6		WESTSEAST
Signature	Date	(TOWN) E	34 /0	40 37 SOUTH
B 2 WELL INFORMATION APPROX. PUMPING RATE —	0	*		FROM ROAD
(GAL. PER MIN.) 8	12	S _W S _E S ₈₋₉	03586655 EN	ITER FT OR MI 38 39
AVERAGE DAILY QUANTITY NEEDED	0	8-9 S 8-9	TAX MAP: 42 BLK:	45 PARCEL 457
(GAL. PER DAY) 14	20	8		201152
USE FOR WATER (CIRCLE APPR	ROPRIATE BOX)		O BE FILLED IN BY D H DEPARTMENT APF	
DOMESTIC POTABLE SUPPLY & RESIDENTI	AL	1/4	II DEL'AITIMENT ALT	10
IRRIGATION		Hartord		12
F FARMING (LIVESTOCK WATERING & AGRICU	ULTURAL	COUNTY NAME		COUNTY NO.
IRRIGATION		STATE SIGNATURE		NSERT S
22 I INDUSTRIAL, COMMERICIAL, DEWATERING		DATE ISSUED	0 10	2/2//2009
P PUBLIC WATER SUPPLY WELL	,	12/29/2008	an & Bisco	3/01/2001
T TEST, OBSERVATION, MONITORING		43 MM DD YY 48	CO SIGNATURE	EXP. DATE
G GEO-THERMAL		NORTH 062 60	0 0 GRID	000
G GEO-THERMAL	<u> </u>	50	55 57	63
		SHOW MAJOR FEATURE	S OF	
APPROXIMATE DEPTH OF WELL 30	FEET	BOX & LOCATE WELL '-		
	28	SOURCES OF DRILLING	WATER	F-3
APPROXIMATE DIAMETER OF WELL	NEAREST INCH	1.	WAILI	
		2.		
METHOD OF DRILLING (c	ircle one)	3.		to to 1
BORED (or Augered) JETTED	Jetted & DRIVEN			N Ziń
30 AIR-ROTary AIR-PERcussion RC	OTARY (Hydraulic Rotary)	WRITE THE BOX NUMBE	R	· 经面。
37 CABLE REVerse-ROTary	DRive-POINT	FROM THE MAP HERE		7
other		+		encode .
	ED WELLS	E /000		* 3
REPLACEMENT OR DEEPEN (CIRCLE APPROPRIATE B			000	8 =
N THIS WELL WILL NOT REPLACE AN EXISTING		N 620		
THIS WELL WILL BEDLACE A WELL THAT WILL		DRAW A SKETCH BELOV	V SHOWING LOCATION OF	WELL IN MAP 18
ABANDONED AND SEALED	•		OWNS AND ROADS AND O	F10
S THIS WELL WILL REPLACE A WELL THAT WII		DISTANCE FROM WELL	TO NEAREST ROAD JUNCT	TION
39 AS A STANDBY-CONTACT LOCAL APPROVING	G AUTHORITY		8	
D THIS WELL WILL DEEPEN AN EXISTING WELL	Ľ.	4	Church	wille Rd
PERMIT NUMBER OF WELL TO BE REPLACED OR I		N R4.22		posed wells Corner School Site
(IF AVAILABLE) 41	52	N	- 1 7	
Not to be filled in but differ AIDE OR CO.	INTY LICE ONLY	A	Jil Prof	10364
Not to be filled in by driller (MDE OR COL	UNIT USE UNLY)		J1,00 5ch	wiles Corner
APPROP, PERMIT NUMBER	_G_		13 /2/2	CAUTAY School
1/0	01		JK 16,	Site
PERMIT No. HH -	75-1008		NISS	
70 71 72	73 74 75 76 77 78 79	1		
SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED =				€




EMERG	ENCY/TEMP NO. IF ANY
(MDE USE ONLY)	TE OF MARYLAND FOR PERMIT TO DRILL WELL please type STATE PERMIT NUMBER HA - 95-1009 70 fill in this form completely 79
Date Received (APA) 8 MM DD YY 13 Harford Co. Public Schools 15 Last Name Owner First Name 34	
10 2 5, Hickory St. 36 Street or RFD 55 Bel Him May 2/0/4 57 Town 70 State 72 Zip 76 DRILLER INFORMATION	52 NEAREST TOWN 71 MILES FROM TOWN (enter 0 if in town)
Driller's Name Toncs Well Drilling Inc. Firm Name 3700 Rush Rd Tayrellsville, and 2128	B 4 1 2 DIRECTION OF WELL FROM TOWN (CIRCLE BOX) 1 1 NEAR WHAT ROAD 30
Address Signature B 2 WELL INFORMATION APPROX. PUMPING RATE (GAL. PER MIN.) 8 12	ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX) W 34 347 37 SOUTH DISTANCE FROM ROAD SW 38 39
AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14 20 USE FOR WATER (CIRCLE APPROPRIATE BOX) D DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION F FARMING (LIVESTOCK WATERING & AGRICULTURAL IRRIGATION) 122 I INDUSTRIAL, COMMERICIAL, DEWATERING	NOT TO BE FILLED IN BY DRILLER HEALTH DEPARTMENT APPROVAL COUNTY NAME STATE SIGNATURE TAX MAP:
P PUBLIC WATER SUPPLY WELL TEST, OBSERVATION, MONITORING G GEO-THERMAL	DATE (SSUED 43 / 01/2009 43 / MM / DD YY 48 CO SIGNATURE EXP. DATE NORTH GRID 50 55 GRID 57 63
APPROXIMATE DIAMETER OF WELL METHOD OF DRILLING (circle one) BORED (or Augered) JETTED Jetted & DRIV AIR-ROTary AIR-PERcussion REVerse-ROTary DRive-PC	BOX & LOCATE WELL WITH AN X SOURCES OF DRILLING WATER 1. 2. 3. VEN WRITE THE BOX NUMBER
Not to be filled in by driller (MDE OR COUNTY USE ONLY)	DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN RELATION TO NEARBY TOWNS AND ROADS AND GIVE DISTANCE FROM WELL TO NEAREST ROAD JUNCTION RATE 22 N Proposed Schucks Corner
PERMIT NO. #4-95-1009 SPECIAL CONDITIONS	3 79 Clemtery school 51te




SEQUENCE NO. STATE OF	STATE PERMIT NUMBER
B 1 2432 (MDE USE ONLY)	MARYLAND ILA 95 1010
	THE PRINCE TO DRILL WELL FOR THE PRINCE TO T
pieas	fill in this form completely
Date Received (APA)	B 3 LOCATION OF WELL
8 MM DD YY 13	8 COUNTY 21
Harford Co. Public Salach	LIB Shorks Corner
15 Last Name Owner First Name 34	23 SUBDIVISION 42
102 Si Hickory St.	1 1
36 Street or RFD 55	SECTION LOT LOT LOT AF-TB7
Bel 412 Md 2/014	CD Della
57 Town 70 State 72 Zip 76	52 NEAREST TOWN 71
DRILLER INFORMATION	MILES FROM TOWN (enter 0 if in town)
David Kelly MWD 304	73 76 77 78
Driller's Name 76 License No. 81	B 4
Jones Well Drilling Inc.	DIRECTION OF WELL FROM 121 Schocks Pl.
Firm Name	TOWN (CIRCLE BOX) 11 NEAR WHAT ROAD 30
3700 Rush Rd. Jarrettsville, and 21084	ON WHICH SIDE OF ROAD NORTH
Address	ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX)
Jan 18ly 2-20-08	WEST S EAST
Signature Date	(TOWN) E 34 495 37 SOUTH
B 2 WELL INFORMATION APPROX. PUMPING RATE	B DISTANCE FROM ROAD RO
(GAL. PER MIN.) 8 12	I'W A I'E WAR ALL WAR
AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14 20	8-9 S 8-9 TAX MAP: 44 BLK: 715 PARCEL 757
USE FOR WATER (CIRCLE APPROPRIATE BOX)	NOT TO BE FILLED IN BY DRILLER
	HEALTH DEPARTMENT APPROVAL
D DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION	
FARMING /LIVESTOCK MATERING & AGRICULTURAL	COUNTY NAME COUNTY NO.
IRRIGATION	STATE
22 I INDUSTRIAL, COMMERICIAL, DEWATERING	SIGNATURE INSERT S 41
P PUBLIC WATER SUPPLY WELL	DATE ISSUED
T TEST, OBSERVATION, MONITORING	43 MM DD YY 48 CO SIGNATURE EXP. DATE
G GEO-THERMAL	NORTH EAST GRID 000
GEO-THERIWAL	50 55 57 63
	SHOW MAJOR FEATURES OF
APPROXIMATE DEPTH OF WELL	BOX & LOCATE WELL '———————————————————————————————————
24 28 NEAREST	SOURCES OF DRILLING WATER
APPROXIMATE DIAMETER OF WELL INCH	1. I I I I I I I I I I I I I I I I I I I
METHOD OF DRILLING (circle one)	2.
BORED (or Augered) JETTED Jetted & DRIVEN	3.
30	
27	WRITE THE BOX NUMBER
CABLE REVerse-ROTary DRive-POINT	FROM THE MAP HERE
other	E /000
REPLACEMENT OR DEEPENED WELLS (CIRCLE APPROPRIATE BOX)	000
THIS WELL WILL NOT REPLACE AN EXISTING WELL	N 620
THE THE WELL WILL SERVICE WELL THAT WILL BE	DRAW A SKETCH BELOW SHOWING LOCATION OF WELL IN
ABANDONED AND SEALED	RELATION TO NEARBY TOWNS AND ROADS AND GIVE
THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY CONTACT LOCAL APPROVING AUTHORITY	DISTANCE FROM WELL TO NEAREST ROAD JUNCTION
39 S AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY FOR POLICY ON STANDBY WELLS	
D THIS WELL WILL DEEPEN AN EXISTING WELL	
PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED	N Razz Churchville Rd
(IF AVAILABLE) 41	
Not to be filled in by driller (MDE OR COUNTY USE ONLY)	Proposed Schooks coeman Schooks coeman School site
	JE Proposition and
APPROP. PERMIT NUMBER	SCHUCKS ES ESTAD
495-1010	M & clemsary
PERMIT No. 70 71 72 73 74 75 76 77 78 79	500013110
SPECIAL CONDITIONS	A



2152 SEQUENCE NO.	07475.05	MARY AND	-	STATE PERMIT NUMBER
B / L 4 J J (MDF/HSF ONLY)		MARYLAND ERMIT TO DRILL WELL	11	1 05 1011
1 2 3		e type	70	79 -/011
D. J. D. J. C. (ADA)	entropy of the second s	metamorphic de la companya del companya del companya de la company		II in this form completely
Date Received (APA) OWNER INFOR	MATION	B 3 HARFOR	LOCATION	OF WELL
8 MM DD YY 13	INIATION	8 COUNTY	1	21
HARFORD CO. Publi	e Schools	1 40 Sho	1015	Corner
15 Last Name Owner	First Name 34	23 SUBDIVISION	,	42
102 S. Hickory St.		SECTION L	LOT L	O AE-TB &
36 Street or RFD	2 10 116	44 46	48	50 77 70 8
57 Town 70 State 7	2/0/4 72 Zip 76	52 NEAREST TOWN	11e	71
DRILLER INFORMATION	2.10 /0			>
David Kelly N	1 W D 354	MILES FROM TOWN (ent	er 0 if in town)	73 76 77 78
Driffer's Name 76		B 4	10	2 = 1 1
Jones Well Drilling Inc.		1 2 DIRECTION OF WELL FROM	1/2	5 Schucks Rd
Firm Name	11 0 00	TOWN (CIRCLE BOX)	11	NEAR WHAT ROAD 30
Address	11c, and 21084	N. B N.		CH SIDE OF ROAD NORTH
	2-20-08	NW 8 NE 8-9	(CIHCLE	APPROPRIATE BOX)
Signature	Date	TOWN E		34 56 37 SOUTH
B 2 WELL INFORMATION	0	4 1		DISTANCE FROM ROAD
1 2 APPROX. PUMPING RATE — (GAL. PER MIN.) 8	12	SW S 8-9	03386	ENTER FT OR MI 38 39
AVERAGE DAILY QUANTITY NEEDED	0	8-9 S 8-9	TAX MAP: _	42 BLK: 48 PARCEL 794
(GAL. PER DAY) 14 USE FOR WATER (CIRCLE APP	20	8 NOT TO	O BE EILLEI	D IN BY DRILLER
				MENT APPROVAL
D DOMESTIC POTABLE SUPPLY & RESIDENT	TIAL	Hartord		12
FARMING (LIVESTOCK WATERING & AGRIC	CULTURAL	COUNTY NAME		COUNTY NO.
IRRIGATION		STATE SIGNATURE		INSERT S
22 I INDUSTRIAL, COMMERICIAL, DEWATERIN	G	DATE/ISSUED	70.11	1 2 2/ /2019
P PUBLIC WATER SUPPLY WELL	*	2/29/2008 C	MAS	1scoe 3/01/2001
TEST, OBSERVATION, MONITORING		48 MM/ DD YY 48 NORTH	CO SIGN	ST /AA/
G GEO-THERMAL		GRID 00200	0 0 GRI	57 0 0 0 0
		SHOW MAJOR FEATURE	S OF	
APPROXIMATE DEPTH OF WELL	FEET	BOX & LOCATE WELL '-		The same of the sa
24	28	WITH AN X SOURCES OF DRILLING	WATER	
APPROXIMATE DIAMETER OF WELL	NEAREST INCH	1.	· · · · ·	等好 A 等。
METHOD OF DRILLING	/-il)	2.		X R BB
BORED (or Augered) JETTED	Jetted & DRIVEN	3.		28 % 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8
30	ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBE	:D	
37 CABLE REVerse-ROTary	DRive-POINT	FROM THE MAP HERE	n l	
other		₩		₩ ₩ ₫
REPLACEMENT OR DEEPE	NED WELLS	E /000	2	000
(CIRCLE APPROPRIATE	BOX)	N 62	0	000
THIS WELL WILL NOT REPLACE AN EXISTIN		IN		218
THIS WELL WILL REPLACE A WELL THAT WAS ABANDONED AND SEALED	VILL BE	DRAW A SKETCH BELOV RELATION TO NEARBY 1		
THIS WELL WILL REPLACE A WELL THAT W		DISTANCE FROM WELL	TO NEAREST F	ROAD JUNCTION
39 S AS A STANDBY-CONTACT LOCAL APPROVI	NG AUTHORITY		The -	
D THIS WELL WILL DEEPEN AN EXISTING WE	ELL	(Rt. 2	2)	Churchville Rd.
PERMIT NUMBER OF WELL TO BE REPLACED OF		N		1
(IF AVAILABLE) 41 — — —	52		7 4	proposed shocks Corner elentary school
Not to be filled in by driller (MDE OR CO	DUNTY USE ONLY)		4.	El shucks Corner
APPROP. PERMIT NUMBER	G	100	3	ale tary school
0	05 1211		7 -	1 conte
PERMIT No. 70 71 70	70 -/0//		~)	(8)
SPECIAL CONDITIONS	2 73 74 75 76 77 78 79		-	
NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED =				⊕




2155 SEQUENCE NO. STATE OF	AAA DVI AAID	STATE PERMIT NUMBER
(MDE USE ONLY)	MARYLAND	111 AF INIA
	ERMIT TO DRILL WELL	HH-90-1012
pleas	e type	fill in this form completely 79
Date Received (APA)	B 3 L0	OCATION OF WELL
OWNER INFORMATION	HARPORS	
8 MM DD YY 13	8 COUNTY	21
HARFORD Co. Public Schools	LO Shuck	S (orner
15 Last Name Owner First Name 34	23 SUBDIVISION	42
102 S, Hickory St.	SECTION L	LOT LOT LOT A STORY
36 Street or RFD 55	44 46	48 50 AF-TB 9
Bel tire and 21014	Churchy	110
57 Town 70 State 72 Zip 76	52 NEAREST TOWN	71
DRILLER INFORMATION	MILES FROM TOWN (enter 0	if in town Z M I
David Kelly MWD 304	MILES FROM TOWN (enter to	73 76 77 78
Driller's Name 76 License No. 81	B 4	
Jones Well Dr. May Inc.	1 2 DIRECTION OF WELL FROM	201 Schucks Rd.
Firm Name	TOWN (CIRCLE BOX)	11 NEAR WHAT ROAD 30
3700 Rush Rd Jarretts Ville, md 21064	N	ON WILLIAM SIDE OF BOAR NORTH
Address	N _W B N _E	ON WHICH SIDE OF ROAD (CIRCLE APPROPRIATE BOX)
David 18/14 2-20-08	8-9	WEST
Signature Date	(TOWN) E	34 26 4 37 SOUTH
B 2 WELL INFORMATION		DISTANCE FROM ROAD
1 2 APPROX. PUMPING RATE (GAL. PER MIN.) 8 12	E 0	3577526 ENTER FT OR MI 38 39
	Sw S S S S S S S S S S S S S S S S S S	AX MAP: 42 BLK: 48 PARCEL 454
AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14 20	8	AX MAP: BLK: PARCEL
USE FOR WATER (CIRCLE APPROPRIATE BOX)		BE FILLED IN BY DRILLER
DOMESTIC DOTABLE SUIDBLY & DESIDENTIAL	HEALTH I	DEPARTMENT APPROVAL
D DOMESTIC POTABLE SUPPLY & RESIDENTIAL IRRIGATION	of throng	12
F FARMING (LIVESTOCK WATERING & AGRICULTURAL	COUNTY NAME	COUNTY NO.
IRRIGATION	STATE SIGNATURE	INSERT S
22 I INDUSTRIAL, COMMERICIAL, DEWATERING	DATE/ISSUED /	1102111/5 1-41
P PUBLIC WATER SUPPLY WELL	2/29/08 (MU)	1 BURNE 2/01/2009
TEST, OBSERVATION, MONITORING	43 MM DD YY 48	CO SIGNATURE EXP. DATE
N /	NORTH 0626 00	0 GRID /00 000
G GEO-THERMAL	50	55 57 63
	SHOW MAJOR FEATURES C	DF 2
APPROXIMATE DEPTH OF WELL 30 FEET	BOX & LOCATE WELL '	
24 28	WITH AN X SOURCES OF DRILLING WA	TED (C)
APPROXIMATE DIAMETER OF WELL NEAREST INCH	1.	
2	2.	2 ° 28
METHOD OF DRILLING (circle one)	3.	
BORED (or Augered) JETTED Jetted & DRIVEN		SH W S
AIR-ROTary AIR-PERcussion ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBER	
37 CABLE REVerse-ROTary DRive-POINT	FROM THE MAP HERE	30 = 30 = 30 = 30 = 30 = 30 = 30 = 30 =
other		
REPLACEMENT OR DEEPENED WELLS	E /890	
(CIRCLE APPROPRIATE BOX)		000
N THIS WELL WILL NOT REPLACE AN EXISTING WELL	N 620	
THIS WELL WILL REPLACE A WELL THAT WILL BE	DRAW A SKETCH BELOW SI	HOWING LOCATION OF WELL IN MAP 18
ABANDONED AND SEALED	RELATION TO NEARBY TOW	
THIS WELL WILL REPLACE A WELL THAT WILL BE USED AS A STANDBY-CONTACT LOCAL APPROVING AUTHORITY	DISTANCE FROM WELL TO	- 1
FOR POLICY ON STANDBY WELLS		0 1 0 11 00
THIS WELL WILL DEEPEN AN EXISTING WELL	Rt. 22	Church lile to
PERMIT NUMBER OF WELL TO BE REPLACED OR DEEPENED	N	A
(IF AVAILABLE) 41	7	DI DIOPOSET
Not to be filled in by driller (MDE OR COUNTY USE ONLY)	A	Churchville Rd Proposed Schucks corner Schucks corner State Schucks school
		S W Server
APPROP. PERMIT NUMBER		of a element school
111 95 1212		VI SITE
PERMIT No. 70 71 72 73 74 75 76 77 78 79		(50)
70 71 72 73 74 75 76 77 78 79		
SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED =		₩



B 1 2454 SEQUENCE NO.	STATE OF	MARYLAND	STATE PERMIT NUMBER
(MIDE USE UNLT)	APPLICATION FOR PERMIT TO DRILL WELL		11 HA -95 - 11/2
1 2 3	please type		70 70
Data Barasia (ABA)			fill in this form completely
Date Received (APA) OWNER INFOR	MATION	B 3 Hargon	LOCATION OF WELL
8 MM DD YY 13	WATION	8 COUNTY	21
HARFORD CO. PUBLIC.	Schools	1 6/6 Sh	ucks (orner
15 Last Name Owner	First Name 34	23 SUBDIVISION	42
102 S, Hickory St.	1	SECTION L	LOTIPARA
36 Street or RFD	55	44 46	48 50 AF-DMW 10
Bel HIR Md	21014	Church	rlle
	⁷ 2 Zip 76	52 NEAREST TOWN	71
DRILLER INFORMATION		MILES FROM TOWN (en	ter 0 if in town) MI_J
	WD304		73 76 77 78
Driller's Name 76	License No. 81	B 4 1 2	650 C. 1 . 1 . 10
Jones Well Vrilling 1	nc	DIRECTION OF WELL FROM	Schools 14.
Firm Name	all " Dan CII	TOWN (CIRCLE BOX)	11 NEAR WHAT ROAD 30
Address (A)	THE MAR 21084	NW 8 NE	ON WHICH SIDE OF ROAD
Address D. W. V. Ole	22208	8-9 8-9	(CIRCLE APPROPRIATE BOX)
Signature	Date	TOWN E	WEST S EAST
B 2 WELL INFORMATION	0	6	DISTANCE FROM ROAD
1 2 APPROX. PUMPING RATE —			03386643 ENTER FT OR MI 38 39
(GAL. PER MIN.) 8	12	S _W S _E S _E	42 HB 2005 459
AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14	20	8	TAX MAP: BLK: PARCEL
USE FOR WATER (CIRCLE APP	PROPRIATE BOX)	NOT T	O BE FILLED IN BY DRILLER
DOMESTIC POTABLE SUPPLY & RESIDEN	TIAI	HEALT	TH DEPARTMENT APPROVAL
IRRIGATION		/ Hartord	12
F FARMING (LIVESTOCK WATERING & AGRIC	CULTURAL OV	COUNTY NAME	COUNTY NO.
IRRIGATION		STATE SIGNATURE	INSERT S
industrial, commericial, dewatering	G	DATE ISSUED /	1 1 Person 2/ /41
P PUBLIC WATER SUPPLY WELL		2/29/08	Car & BURCH 3/01/2007
TEST, OBSERVATION, MONITORING	/ 4 /	43 MM DD/ YY 48	CO SIGNATURE EXP. DATE
G GEO-THERMAL		GRID 50	0 0 0 GRID 700 0 0 63
ADDROVIMATE DEDTH OF WELL 30	. /	SHOW MAJOR FEATURE BOX & LOCATE WELL '.	
APPROXIMATE DEPTH OF WELL 24	FEET 28	WITH AN X	
APPROXIMATE DIAMETER OF WELL	NEAREST	SOURCES OF DRILLING	WATER
APPROXIMATE DIAMETER OF WELL	INCH	1. 2.	7 8 9 9
METHOD OF DRILLING	(circle one)	3.	
BORED (or Augered) JETTED	Jetted & DRIVEN	0.	
30 AIR-ROTary AIR-PERcussion F	ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBE	ER.
37 CABLE REVerse-ROTary	DRive-POINT	FROM THE MAP HERE	
other		+	W =
REPLACEMENT OR DEEPEL	NED WELLS	E /000	000
(CIRCLE APPROPRIATE		/ 122	000
THIS WELL WILL NOT REPLACE AN EXISTIN	IG WELL	N 620	
THIS WELL WILL REPLACE A WELL THAT W	/ILL BE		W SHOWING LOCATION OF WELL IN
ABANDONED AND SEALED	W. DE 1105D	TO ALL TO THE CONTROL OF THE CONTROL	TOWNS AND ROADS AND GIVE TO NEAREST ROAD JUNCTION
THIS WELL WILL REPLACE A WELL THAT WAS A STANDBY-CONTACT LOCAL APPROVING			E6
FOR POLICY ON STANDBY WELLS			Q .
THIS WELL WILL DEEPEN AN EXISTING WE		N Pt. 22	Churchylle fol
PERMIT NUMBER OF WELL TO BE REPLACED OR (IF AVAILABLE) 41	DEEPENED 52	N FF. ZC	1
704/- 7 4 77 - 74 - 77 - 74 - 77 - 74 - 77			u proposed
Not to be filled in by driller (MDE OR CO	DUNTY USE ONLY)	T	Shucks Corner School
APPROP. PERMIT NUMBER	G		3 st can tax school
AND THE INTERIOR OF THE INTERI	00 1010		of Sy evem land some
PERMIT No. HH-	75 - 1013		W & SITC
70 71 72	73 74 75 76 77 78 79	1	1) 0
SPECIAL CONDITIONS			A

DENV-Permit 97



1 2 3 (THIS NUMBER IS TO BE FIN COLS. 3-6 ON ALL CAR	(MDE USE ON	ILY)	STATE OF MARYLAND WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
ST/CO USE ONLY	DATE WELL (OMPL	PLEASE TYPE ETED Depth of Well	NUMBER
DATE Received MM DO YY	MM / DD	6	22 3 2 26	FROM "PERMIT NO.
OWNER Haveto	ond Car	CIT	(TO NEAREST FOOT)	28 29 30 31 32 33 34 35 36 37
STREET OR RFD	lest name 0.3	oc N	UNICS GOOD FOR DAME TOWN	Charles I alverts
SUBDIVISION	O SHUCKS	Co	SECTION	LOT 13
WELL Not required for			GROUTING RECORD YES NO	C 3 ME-UNIW 1
STATE THE KIND OF FORMA COLOR, DEPTH, THICKNESS	The state of the s	EIR G	WELL HAS BEEN GROUTED (Circle Appropriate Box) TYPE OF GROUTING MATERIAL (Circle one)	PUMPING TEST
DESCRIPTION (Use additional sheets if needed)	FEET C	heck water earing	CEMENT C M BENTONITE CLAY B C	HOURS PUMPED (nearest hour) 8 9
lagged			NO. OF BAGS NO. OF POUNDS 45 46 GALLONS OF WATER	PUMPING RATE (gal. per min.)
Lucerelle			DEPTH OF GROUT SEAL (to nearest foot) from	METHOD USED TO MEASURE PUMPING RATE
Emis removed		-	(enter 0 if from surface)	WATER LEVEL (distance from land surface) BEFORE PUMPING
The reage intent		and the same	types insert ST CO	17 20
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		- 1	appropriate code below P L O T	WHEN PUMPING 22 25 ft. TYPE OF PUMP USED (for test)
STUST DISUA	0 15	1	MAIN Nominal diameter Total depth	A air P piston T turbine
week continue.	10- 2- V	- 1	CASING top (main) casing of main casing TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary O other (describe
tase	15 20	-	60 61 63 64 66 70	J jet S submersible
			OTHER CASING (if used) C diameter depth (feet) H inch from to	27 27
				DRILLER INSTALLED PUMP YES NO (CIRCLE) (YES or NO)
		L		IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
		- 1	screen type or open hole ST BR HO	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX 29.
			appropriate Code BRONZE HOLE	CAPACITY: GALLONS PER MINISTE
			Delow PLASTIC OTHER	(to nearest gallon) 31 3s PUMP HORSE POWER
NUMBER OF UNSUCCESSFU	L WELLS: 10	_ 5	DEPTH (nearest ft.)	PUMP COLUMN LENGTH (nearest ft.)
WELL HYDROFRACTURED	yes TO	V A	8 9 11 15 17 21	CASING HEIGHT (circle appropriate box
CIRCLE APPROPRI	AND SEALED	H	23 24 26 30 32 26	and enter casing height) LAND SURFACE
E ELECTRIC LOG OBTAINED)	C	3 20 20 44	below (nearest) foot)
P TEST WELL CONVERTED		E	SLOT SIZE 1 2 3	A LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS WELL ACCORDANCE WITH COMAR 26.04.04 IN CONFORMANCE WITH ALL CONDIT CAPTIONED PROPERTY AND THAT THE	TIONS STATED IN THE ABO	ND VE	DIAMETER OF SCREEN (NEAREST INCH)	SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS AND JOR
HEREIN IS ACCURATE AND COMPL KNOWLEDGE.	LETE TO THE BEST OF	WY -	56 60 from to	LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
DRILLERS LIC. NO., M	(b)304	₫ IF	WELL DRILLED	warmen Christian Charles
DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON A	APPLICATION)	IN:	IS FLOWING WELL SERT F IN BOX 68 68 DE USE ONLY	3 3
LIC. NO.1		(1)	T (E.R.O.S.) W Q	al eye of
SITE SUPERVISOR (sign. of de	English or lower war.	71	72	●
responsible for sitework if differen	ent from permittee)		LESCOPE LOG 74 75 76 SING INDICATOR OTHER DATA	He pu plat
DENV-CR00			DRILLER	100 March 1996

C 1 (MDE USE ONLY)	WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED. COUNTY
IN COLS. 3-6 ON ALL CARDS) ST/CO USE ONLY DATE WELL COM	PLEASE TYPE	NUMBER PERMIT NO.
DATE Received MM DD YY MM DD.	22 29 26 20 (TO NEAREST FOOT)	FROM "PERMIT TO DRILL WELL" 28 29 30 31 32 33 34 35 36 3
OWNER How found County	Public Schools	
STREET OR RFD OS SOUCK	TOWN	LOT 13
WELL LOG	GROUTING RECORD Yes no	C3 ME-TB2
Not required for driven wells STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING	WELL HAS BEEN GROUTED (Circle Appropriate Box) TYPE OF GROUTING MATERIAL (Circle one)	1 2 PUMPING TEST
DESCRIPTION (Use FEET check if water	CEMENT CM BENTONITE CLAY BC	HOURS PUMPED (nearest hour)
Luciyad PHOM TO bearing	NO. OF BAGS NO. OF POUNDS 55 46 GALLONS OF WATER	PUMPING RATE (gal. per min.)
by !	DEPTH OF GROUT SEAL (to nearest foot) from ft. to ft.	METHOD USED TO MEASURE PUMPING RATE
Environmental	48 TOP 52 54 BOTTOM 58 (enter 0 if from surface)	WATER LEVEL (distance from land surface)
Management	casing types insert ST CO	BEFORE PUMPING 17 20 ft.
/w.	appropriate STEEL CONCRETE COMPLETE CONCRETE COMPLETE CONCRETE CON	WHEN PUMPING 22 15 ft.
dut 6	PLASTIC OTHER MAIN Nominal diameter Total depth	TYPE OF PUMP USED (for test) A air P piston T turbine
30f4 brown 1 12	CASING top (main) casing of main casing TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary O other (describe
med hard 13 29 V	60 61 63 64 66 70	J jet S submersible
tenlying 13 21 V	E OTHER CASING (if used) A diameter depth (feet)	27 27 27
	H inch from to	DRILLER INSTALLED PUMP YES NO
	Š — L — L — I	(CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION
	screen type SCREEN RECORD	MUST BE COMPLETED FOR ALL WELLS. TYPE OF PUMP INSTALLED PLACE (A.C.J.P.R.S.T.O) 29
	insert STEEL BRASS OPEN	PLACE (A,C,J,P,R,S,T,O) 29 IN BOX 29. CAPACITY:
	code below PL OT	GALLONS PER MINUTE (to nearest gallon) 31 35
	C 2 DEPTH (nearest ft.)	PUMP HORSE POWER 37 41
NUMBER OF UNSUCCESSFUL WELLS:	1 20/ 9 29	PUMP COLUMN LENGTH (nearest ft.)
WELL HYDROFRACTURED Yes N	E A 8 9 11 15 17 21 C	CASING HEIGHT (circle appropriate box and enter casing height)
CIRCLE APPROPRIATE LETTER A WELL WAS ABANDONED AND SEALED	H 2 23 24 26 30 32 36 S	49 LAND SURFACE
WHEN THIS WELL WAS COMPLETED ELECTRIC LOG OBTAINED TEST WELL CONVERTED TO PRODUCTION	C 3 R 38 39 41 45 47 51	below) (nearest) foot)
WELL HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN	E SLOT SIZE 1 2 3	A LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS
ACCORDANCE WITH COMAR 28.04.04 "WELL CONSTRUCTION" AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY KNOWLEDGE.	DIAMETER (NEAREST INCH)	BUILDING, SEPTIC TANKS, AND /OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
DRILLERS LIC. NO. 1 M L/D 2 4 1	GRAVEL PACK F WELL DAILLED WAS FLOWING WELL INSERT F IN BOX 68 68	Y Churchy, He of
(MUST MATCH SIGNATURE ON APPLICATION)	MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER)	4
How Morray	T (E.R.O.S.) W Q	2 908 × 80
SITE-SUPERVISOR (sign. of driller or journeyman responsible for sitework if different from permittee)	TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	As see aloten
DENV-CR00	ORILLER	T. S. C. A.

	DRILLER	
SITE SUPERVISOR (sign, of driller or journeyman responsible for sitework if different from permittee)	70 72 74 75 76 TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	3/2025 JU
Dain Morris	I (NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q	1 10 10 10 10 10 10 10 10 10 10 10 10 10
DRILLERS LIC. NO. 1 M D D D DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION)	I GRAVEL PACK I IF WELL DRILLED WAS FLOWING WELL INSERT FIN BOX 68 68	13/13/
ACCORDANCE WITH COMAR 28.04.04 "WELL CONSTRUCTION IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE CAPTIONED PERMIT, AND THAT THE INFORMATION PRES HEREIN IS ACCURATE AND COMPLETE TO THE BEST KNOWLEDGE.	OF SCREEN (NEAREST INCH) F MY from to	BUILDING, SEPTIC TANKS, AND /OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
E ELECTRIC LOG OBTAINED P TEST WELL CONVERTED TO PRODUCTION WELL I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCT	R 38 39 41 45 47 51 E SLOT SIZE 1 2 2 3	LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS
CIRCLE APPROPRIATE LETTER A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED	H ² 23 24 26 30 32 36 S C 3	49 LAND SURFACE
	E 8 9 11 15 17 21	CASING HEIGHT (circle appropriate box and enter casing height)
NUMBER OF UNSUCCESSFUL WELLS:	C 2 DEPTH (nearest ft.)	PUMP HORSE POWER PUMP COLUMN LENGTH (nearest ft.)
	appropriate code below PL PLASTIC OTHER	CAPACITY: GALLONS PER MINUTE (to nearest gallon) 31 35
	screen type or open hole insert STEEL BRASS OPEN	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX 29.
	S	(CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
	A diameter depth (feet) H inch from to	PUMP INSTALLED DRILLER INSTALLED PUMP YES NO
red hard 17 30 V	60 61 63 64 66 70 E OTHER CASING (if used)	27 27 27 27 27 27 27 27 27 27 27 27 27 2
of brown 1 17	MAIN Nominal diameter Total depth of main casing TYPE (nearest inch)! Total depth of main casing (nearest foot)	C centrifugal R rotary O (describ
116	appropriate code below PLASTIC OTHER	TYPE OF PUMP USED (for test) A air P piston T turbine
chargement of	casing types insert ST CO	BEFORE PUMPING 17 20 ft. WHEN PUMPING 17 tt.
haraste	from tt. to from surface) from tt. to ft. t	
additional sheets if needed) FROM TO be	NO. OF BAGS NO. OF POUNDS SEE NO. OF POUNDS NO. OF WATER	PUMPING RATE (gal. per min.) METHOD USED TO MEASURE PUMPING RATE
DESCRIPTION (Use	CEMENT CIM BENTONITE CLAY BC	HOURS PUMPED (nearest hour) 8 9
WELL LOG Not required for driven wells	WELL HAS BEEN GROUTED (Circle Appropriate Box)	C 3 (1) F-T B 3
SUBDIVISION_4/0 SCHUCKS	SECTION	LOT
OWNER TO TO STREET OR RFD / O Sept named	TUBLIC DANGAR TOWN	howehville
8 13 15	22 26 20 (TO NEAREST FOOT)	28 29 30 31 32 33 34 35 36 3
IN COLS. 3-6 ON ALL CARDS) ST/CO USE ONLY DATE Received DATE WELL C	PLEASE TYPE MPLETED Depth of Well	PERMIT NO. FROM "PERMIT TO DRILL WELL"
1 2 3 6 (THIS NUMBER IS TO BE PUNCHED	FILL IN THIS FORM COMPLETELY	COUNTY NUMBER
CII 3014 (MDE USE ONI	STATE OF MARTLAND	45 DAYS AFTER WELL IS COMPLETED.

C 1 9375 1 2 3 (THIS NUMBER IS TO BE P IN COLS. 3-6 ON ALL CAR	SEQUENCE NO. (MDE USE ONLY) 6 UNCHED DS)	STATE OF MARYLAND WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY PLEASE TYPE	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED. COUNTY NUMBER
ST/CO USE ONLY DATE Received MM DO YY 8 13	DATE WELL COMP		PERMIT NO. FROM "PERMIT TO DRILL WELL" 28 29 30 31 32 33 34 35 36 3
OWNER TO TO	rd Lount	YOU'C SETIONS	
STREET OR RFD	25 Schuck	NOAD first earne TOWN	horopalis
SUBDIVISION	DEMOCKS	COVINEY SECTION	LOT
WELL Not required to		GROUTING RECORD Yes no	C 3 ME-TRH
Not required fo		WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2
STATE THE KIND OF FORMAT COLOR, DEPTH, THICKNESS DESCRIPTION (Use additional sheets if needed)	FEET check	TYPE OF GROUTING MATERIAL (Circle one) CEMENT CM BENTONITE CLAY B C	HOURS PUMPED (nearest hour)
auditional sheets if needed)	FROM TO bearing	NO. OF BAGS NO. OF POUNDS 45 46 GALLONS OF WATER	PUMPING RATE (gal. per min.)
2019		DEPTH OF GROUT SEAL (to nearest foot)	METHOD USED TO MEASURE PUMPING RATE
lucted e		from tt. to 54 BOTTOM 58 ft. (enter 0 if from surface)	WATER LEVEL (distance from land surface)
LESS CARE	al	casing types insert ST CO	BEFORE PUMPING 17 20 ft.
Hearing Editor	time	appropriate code below P L O T	WHEN PUMPING 29 ft.
A, ET	01	MAIN Nominal diameter Total depth	TYPE OF PUMP USED (for test) A air P piston T turbine
soft Brown	1 16	CASING top (main) casing of main casing TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary O (describe
mal hard	16 30 V	80 61 63 64 66 70	J jet S submersible
1 200		A OTHER CASING (if used) A diameter depth (feet)	27 27
		C to	DRILLER INSTALLED PUMP YES NO
		G —	(CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
		screen type or open hole STBRHO	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) 29
		appropriate code BRONZE HOLE	IN BOX 29. CAPACITY: GALLONS PER MINUTE
		below PLASTIC OTHER	(to nearest gallon) 31 35 PUMP HORSE POWER
NUMBER OF UNSUCCESSFU	L WELLS:	C 2 DEPTH (nearest ft.)	PUMP COLUMN LENGTH (nearest ft.)
WELL HYDROFRACTURED	yes no	E 1 8 9 11 15 17 21 C	CASING HEIGHT (circle appropriate box
CIRCLE APPROPRI A WELL WAS ABANDONED WHEN THIS WELL WAS CO	AND SEALED	H ² 23 24 26 30 32 36 S	49 LAND SURFACE
E ELECTRIC LOG OBTAINED TEST WELL CONVERTED:		C 3 R 38 39 41 45 47 51 E	below) (nearest) foot)
WELL		E SLOT SIZE 1 2 3	LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS
CCORDANCE WITH COMAR 28.04.04 I CONFORMANCE WITH ALL CONDITATIONED PERMIT, AND THAT THE ERRIN IS ACCURATE AND COMPLINOWLEDGE.	TIONS STATED IN THE ABOVE	DIAMETER (NEAREST INCH)	LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES
DRILLERS LIC. NO.1, M	100204F	GRAVEL PACK SOLUTION TO	(MEASUREMENTS TO WELL)
DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON A	APPLICATION)	WAS FLOWING WELL INSERT F IN BOX 68 68	
		MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q	3
SITE SUPERVISOR (sign. of de	eleje v	70 72	3 - 1-23 €
esponsible for sitework if difference	ent from permittee)	TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	1 its per plast
DENV-CR00		DRILLER	

C 1 33/0 (MDE USE ON		THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
1 2 3 (THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)	FILL IN THIS FORM COMPLETELY PLEASE TYPE	COUNTY NUMBER
ST/CO USE ONLY DATE Received MM DO YY 8 13 15	DMPLETED Depth of Well 22 2 26 (TO NEAREST FOOT)	PERMIT NO. FROM "PERMIT TO DRILL WELL" 28 29 30 31 32 33 34 35 36 37
OWNER TO TO THE STREET OF PER	first name	V
STREET OR RFD 704 SC	COCDEW SECTION TOWN	LOT 121
WELL LOG	GROUTING RECORD Yes no	C3 ME-DOWS
Not required for driven wells	WELL HAS BEEN GROUTED (Circle Appropriate Box)	PUMPING TEST
STATE THE KIND OF FORMATIONS PENETRATED, THI COLOR, DEPTH, THICKNESS AND IF WATER BEARIN	TYPE OF GROUTING MATERIAL (Circle one)	HOURS PUMPED (nearest hour)
additional absolute if acceptant	PRINCE CEMENT C M BENTONITE CLAY B C NO. OF BAGS NO. OF POUNDS 45 46	PUMPING RATE (gal. per min.)
Logged by Chese cake Environmental	GALLONS OF WATER DEPTH OF GROUT SEAL (to nearest foot)	METHOD USED TO MEASURE PUMPING RATE
of realize	from 48 TOP 52 ft. to 54 BOTTOM 58 ft.	WATER LEVEL (distance from land surface)
Environmental	(enter 0 if from surface) CASING RECORD	BEFORE PUMPING 17 20 ft.
Pharagenest Int	types insert appropriate ST CO CONCRETE	WHEN PUMPING 22 25 ft.
dir. 7 01	code below PL OT PLASTIC OTHER	TYPE-OF PUMP USED (for test)
50ff prown 1 18 4	MAIN Nominal diameter Total depth	A air P piston T turbine
and host	CASING top (main) casing of main casing (nearest foot)	C centrifugal R rotary O other (describe below)
tau 18 23	60 61 63 64 66 70	J jet S submersible
	E OTHER CASING (if used) A diameter depth (feet) H inch from to	27 27
	H inch from to	DRILLER INSTALLED PUMP YES NO
	G	(CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION
	screen type SCREEN RECORD	MUST BE COMPLETED FOR ALL WELLS. TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) 29
	insert STEEL BRASS OPEN	IN BOX 29. CAPACITY:
	code below BRONZE HOLE OTT	GALLONS PER MINUTE (to nearest gallon) 31 35
	C 2 DEPTH (nearest ft.)	PUMP HORSE POWER 37 41
NUMBER OF UNSUCCESSFUL WELLS: yes /n	= 12/1 3 23	PUMP COLUMN LENGTH (nearest ft.)
WELL HYDROFRACTURED Y	A 8 9 11 15 17 21 C 2	CASING HEIGHT (circle appropriate box and enter casing height)
CIRCLE APPROPRIATE LETTER A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED	H 23 24 26 30 32 36	LAND SURFACE (nearest)
E ELECTRIC LOG OBTAINED	C 3 R 38 39 41 45 47 51	below (nearest) foot)
P TEST WELL CONVERTED TO PRODUCTION WELL I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTE	E SLOT SIZE 1 2 3	LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS
ACCORDANCE WITH COMAR 28.04.04 "WELL CONSTRUCTION" IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE AS CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENT HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF KNOWLEDGE.	ND DIAMETER (NEAREST INCH)	BUILDING, SEPTIC TANKS, AND /OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES
DRILLERS LIC. NO.1 M LD 2 C H	GRAVEL PACK	(MEASUREMENTS TO WELL)
DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION)	WAS FLOWING WELL INSERT F IN BOX 68 MDE USE ONLY	7 3
LIC. NO. 1 7 WD 3 7 6	(NOT TO BE EILLED IN BY DOLLED)	6
STE SUPERMORE MORRISA	70	140\$
SITE SUPERVISOR (sign, of driller or journeyman responsible for sitework if different from permittee)	TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	the de Whote
DENV-CR00	DRILLER	

SEQUENCE NO. THIS REPORT MUST BE SUBMITTED WITHIN STATE OF MARYLAND 1 (MDE USE ONLY) 45 DAYS AFTER WELL IS COMPLETED. WELL COMPLETION REPORT COUNTY FILL IN THIS FORM COMPLETELY (THIS NUMBER IS TO BE PUNCHED NUMBER PLEASE TYPE IN COLS. 3-6 ON ALL CARDS) PERMIT NO. ST/CO USE ONLY DATE WELL COMPLETED Depth of Well FROM "PERMIT TO DRILL WELL" DATE Received 18-95 -100 (TO NEAREST FOOT) 28 29 30 31 32 33 34 35 36 37 OWNER. TOWN STREET OR RFD. SUBDIVISION SECTION LOT GROUTING RECORD WELL LOG C 3 Not required for driven wells WELL HAS BEEN GROUTED (Circle Appropriate Box) PUMPING TEST STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING TYPE OF GROUTING MATERIAL (Circle one) HOURS PUMPED (nearest hour) check CEMENT CM BENTONITE CLAY | B | C FEET DESCRIPTION (Use additional sheets if needed) PUMPING RATE (gal. per min.) FROM TO NO. OF POUNDS 45, 46 bearing NO. OF BAGS GALLONS OF WATER_ METHOD USED TO MEASURE PUMPING RATE DEPTH OF GROUT SEAL (to nearest foot) WATER LEVEL (distance from land surface) (enter 0 if from surface) BEFORE PUMPING CASING RECORD casing types insert WHEN PUMPING appropriate code OIT PIL TYPE_OF PUMP USED (for test) below OTHER P piston turbine A 13 Total depth MĂIN Nominal diameter top (main) casing of main casing CASING other 12 (nearest inch)! (nearest foot) TYPE (describe centrifugal rotary below) 60 61 63 64 66 S J submersible OTHER CASING (if used) 27 depth (feet) diameter from inch to PUMP INSTALLED DRILLER INSTALLED PUMP (NO YES (CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS. SCREEN RECORD screen type or open hole TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) 29 BR HO SIT IN BOX 29. insert BRASS CAPACITY appropriate BRONZE HOLE GALLONS PER MINUTE code PIL OIT 35 helow (to nearest gallon) PUMP HORSE POWER 41 2 DEPTH (nearest ft.) PUMP COLUMN LENGTH NUMBER OF UNSUCCESSFUL WELLS: (nearest ft.) 43 47 CASING HEIGHT (circle appropriate box WELL HYDROFRACTURED 21 8 N and enter casing height) + above LAND SURFACE CIRCLE APPROPRIATE LETTER 24 30 32 36 26 A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED S (nearest) below C3 foot) ELECTRIC LOG OBTAINED 39 41 45 47 TEST WELL CONVERTED TO PRODUCTION LOCATION OF WELL ON LOT SLOT SIZE 1 WELL 3 SHOW PERMANENT STRUCTURE SUCH AS I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 28.04.04 "WELL CONSTRUCTION" AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY BUILDING, SEPTIC TANKS, AND JOR DIAMETER (NEAREST LANDMARKS AND INDICATE NOT LESS INCH) OF SCREEN 56 60 THAN TWO DISTANCES from to (MEASUREMENTS TO WELL) Calebrandows) DRILLERS LIC. NO.1 M ___ D GRAVEL PACK IF WELL DRILLED WAS FLOWING WELL 68 DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION) MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER) LIC. NO. 1 12 D 3261 T (E.R.O.S.) WQ 72 74 75 76 SITE SUPERVISOR (sign. of driller or journeyman LOG INDICATOR TELESCOPE responsible for sitework if different from permittee) OTHER DATA DENV-CR00



Schucks Rd - Schucks Corner

2 messages

Jones Well Drilling <water@joneswelldrilling.com>
To: "heidi.simmons@maryland.gov" <heidi.simmons@maryland.gov>

Wed, Jun 8, 2022 at 9:30 AM

Good Morning,

I have located the well completion s reports for HA-95-1004, 1005, 1006, 1007, 1008, 1009 and 1010. (attached).

HA-94-1011, 1012 and 1013 were not drilled and turned in.

If you have any questions let me know.

Sandy Roberts

Jones Well Drilling

water@joneswelldrilling.com

3700 Rush Road

Jarrettsville, MD 21084

410-692-6981



Heidi Simmons -MDH- <heidi.simmons@maryland.gov>
To: Jones Well Drilling <water@joneswelldrilling.com>

Wed, Jun 8, 2022 at 10:12 AM

Thank you!!!!

Heidi Simmons

Environmental Health

PIA - Property Records

MDH - HCHD

120 S. Hays Street

Bel Air, MD 21014

(T) 410-877-2347

heidi.simmons@maryland.gov



C1 93/9	(MDE USE	ONLY)	STATE OF MARYLAND WELL COMPLETION REPORT	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
1 2 3 (THIS NUMBER IS TO BE IN COLS. 3-6 ON ALL CA			FILL IN THIS FORM COMPLETELY PLEASE TYPE	COUNTY NUMBER
ST/CO USE ONLY DATE Received MM DD YY 8 13	DATE WELL	COMPL		PERMIT NO. FROM "PERMIT TO DRILL WELL" 28 29 30 31 32 33 34 35 36 33
OWNERSTREET OR RFD	last name	soly	Public Schools	Name of the second
SUBDIVISION	SCHUCK	s Ca	TOWN	LOT
WEL	L LOG	William Company	GROUTING RECORD yes no	C 3 A 5 TRA
	for driven wells		WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2 PUMPING TEST
STATE THE KIND OF FORM COLOR, DEPTH, THICKNE			TYPE OF GROUTING MATERIAL (Circle one)	HOURS PUMPED (nearest hour)
DESCRIPTION (Use additional sheets if needed)	FROM TO	if water bearing	NO. OF BAGS 46 NO. OF POUNDS 45 46	PUMPING RATE (gal. per min.)
legged			GALLONS OF WATER DEPTH OF GROUT SEAL (to nearest foot)	METHOD USED TO MEASURE PUMPING RATE
Therescale			from 48 TOP 52 ft. to 54 BOTTOM 58 ft.	WATER LEVEL (distance from land surface)
Eng rushent	at 1		(enter 0 if from surface) casing CASING RECORD	BEFORE PUMPING 17 20 ft.
Duraya mant	144000		types insert appropriate STEEL CONCRETE	WHEN PUMPING 29 ft.
5	01		code below PLASTIC OTHER	TYPE-OF PUMP USED (for test)
Golf brewn	1 11		MAIN Nominal diameter Total depth CASING top (main) casing of main casing	A sir P piston T turbine
mul there	11 23		TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary (describe below)
tain	11	1	60 61 63 64 66 70 E OTHER CASING (if used)	J jet S submersible
Mark house	23 30	1	diameter depth (feet)	9275-9387/03 Scott 1922
			C	DRILLER INSTALLED PUMP YES NO (CIRCLE) (YES or NO)
- 14			N	IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
Suite			screen type or open hole ST BR HO OPEN	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX 29.
after the second			appropriate code below BRONZE PL OT OTHER	CAPACITY: GALLONS PER MINUTE (to nearest gallon) PUMP HORSE POWER
NUMBER OF UNSUCCESS	FUL WELLS: /	>	C 2 DEPTH (nearest ft.)	PUMP COLUMN LENGTH 37 41
WELL HYDROFRACTURED	yes Y	no N	E 1 8 9 11 15 17 21	(nearest ft.) CASING HEIGHT (circle appropriate box
CIRCLE APPRO	PRIATE LETTER	IN	C 2	and enter casing height) LAND SURFACE
A WELL WAS ABANDON WHEN THIS WELL WAS	NED AND SEALED S COMPLETED		S C3	below (nearest)
P TEST WELL CONVERTI			R 38 39 41 45 47 51 E SLOT SIZE 1 2 3	A LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS W ACCORDANCE WITH COMAR 25-00 IN CONFORMANCE WITH ALL CO CAPTIONED PERMIT, AND THAT HEREIN IS ACCURATE AND CO KNOWLEDGE.	4.04 "WELL CONSTRUCTION NOTIONS STATED IN THE THE INFORMATION PRI	ON" AND E ABOVE	DIAMETER (NEAREST OF SCREEN 56 60 from to	SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND /OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
DRILLERS LIC. NO. 1	мДрзад	4.	GRAVEL PACK _ 8 1 30	(MEASUREMENTS TO WELL)
DRILLERS SIGNATURE (MUST MATCH SIGNATURE	ON APPLICATION		IF WELL DRILLED WAS FLOWING WELL INSERT F IN BOX 68 68	E
LIC. NO.1	Z D 3 7	6.	MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q	4-1-1-1-1-1
Stan 3	Morria		70 72	-10-€
SITE SUPERVISOR (sign. responsible for sitework if d	of driller or journeyma ifferent from permitte	an e)	TELESCOPE LOG 074 75 76 CASING INDICATOR OTHER DATA	As per plat
DENV.	-12		DRILLER	100 m



14315 Jarrettsville Pike P.O. Box 249 Phoenix, MD 21131-0249 (410) 683-3388 (410) 683-3389 Fax

LETTER OF TRANSMITTAL

To:		y Health Department		Date:	January 16, 2009
	119 S. Hays St	reet		SRI Project #:	08035
	Bel Air, Maryl	and 21014		SRI Billing Group:	A.1
				SRI Phase:	
Attn:	Gary Browning			SICI I nase:	DD
Re:	Campus Hills I	Elementary School Ground	lwater Appropri	iation Permit Applica	ution
We are ser		☐ Shop Drawings ☐ Electronic Files	☐ Prints ☐ Report	☐ Specifications ☐ As Noted Below	☐ Plans
COPIES 1	A 1: .:		DESCRIPTION	N	
1	Project Location	ppropriate and Use Waters of the	e State		
	Troject Education	rian			
These are to	canemittad.				
These are to	ransmitted:	☐ Approved As Submitte ☐ Approved As Noted ☑ For Review & Comme	Returne	ed for Corrections	For Your Use As Requested
These are to	ransmitted:	☐ Approved As Noted	Returne	ed for Corrections	
Remarks: Gary – Pleas ewer Plan. Kempt from	e feel free to contac We are correspond listing their project	☐ Approved As Noted	Returne Resubm	ed for Corrections [nit cluded on Harford County ne. They have indicated.	As Requested y's Master Water and
Remarks: Gary – Pleas ewer Plan. Kempt from	e feel free to contac We are correspond listing their project	Approved As Noted For Review & Comme of the regarding this project. The regarding this project. The regarding with Harford County Public to on the W&S plan. Station, it will need to be forward.	Returne Resubm is project is not ince Schools at this tire ded to MDE. Pleas Signed:	ed for Corrections cluded on Harford County ne. They have indicated se let me know if you will	As Requested y's Master Water and to us that they are I do that or if we will d
Remarks: Gary – Pleas ewer Plan. Kempt from fter you hav	e feel free to contact We are correspond listing their project we signed the application.	Approved As Noted For Review & Comme of the regarding this project. Thing with Harford County Public ts on the W&S plan. Exation, it will need to be forward	Returne Resubm is project is not ince Schools at this tire ded to MDE. Pleas Signed:	ed for Corrections [nit cluded on Harford County ne. They have indicated.	As Requested y's Master Water and to us that they are do that or if we will define the control of the control

CONFIDENTIALITY NOTICE: The information herein is confidential and is intended for the use of the individual to whom this cover is addressed. Any use of this information by other than the addressee is prohibited. If you receive this transmission in error, please contact us immediately to arrange the return of this material.

MARYLAND DEPARTMENT OF THE ENVIRONMENT

Water Management Administration - Water Rights Division 1800 Washington Blvd. • Baltimore, Maryland 21230 (410) 537-3591 • 1-800-633-6101 • http://www.mde.state.md

APPLICATION TO APPROPRIATE AND USE WATERS OF THE STATE

——————————————————————————————————————	Appl	ication Number
APPLICATION		
Harford County Public Schools		410.809.6124
(Owners Name) 102 South Hickory Avenue	Bel Air	(Douting Dk., Alexander)
(Mailing Address) (Street)	(City)	(State) (Zip Code)
WITHDRAWAL of GROUNDWATER Appropriate and use an annual average of 15,520 Gallons per day, and (Total Annual Use / 365)	Appropriate and us	RAWAL of SURFACE WATER se an annual average of gallons per day, and a maximum use 65)
19,400 gallons per day during (Highest Monthly Use / 30) month of maximum use, from 2 wells, having a	of	gallons in any one day, from
diameter of 6 inches, and a depth of 200 feet		(Name of Stream or Waterway)
. (Estimate) (Estimate)		(Exact Location of Intake)
100-400 block Schucks Road Bel A (STREET ADDRESS - MAP DIRECTIONS - AE County HA Subdivision or Town Bel Air Name and Type of Business Educational Institu SUBDIVISIONS MUST INCLUDE PLAT - ALL	DC PAGE/GRID - TAX M/ 	AP PAGE/GRID/PARCEL) Phone Number
SUBDIVISIONS MUST INCLUDE PLAT - ALL		
The water will be used for: Community Water Supply Non-Potable Supply (sanitary non Drinking Water) Potable Supply Cooling Water Irrigation Process Water Signature of the suppression of the supple s	☐ Public Sewer ☐ Groundwater ☐ Subsurface ☐ Spray Irrigal	(Nome of the co
Ronald Kauffman Facilities Planner PRINT (NAME) (TITLE)	1013.09 PRO	IIS APPLICATION WILL NOTBE CESSED WITHOUT A SIGNATURE AND LOCATION MAP
REVIEW BY COUNTY ENVIRONMENTA	AL HEALTH OR D	ESIGNATED ACENOV
THIS SECTION NOT TO BE	COMPLETED BY APP	LICANT
	AN AND LOCAL DEALISM	
PROJECT CONSISTANT WITH THE COUNTY WATER AND SEWER PL	AN AND LOCAL PLANNI	ng and zoning?
PROJECT CONSISTANT WITH THE COUNTY WATER AND SEWER PL	AN AND LOCAL PLANNII	NG AND ZONING?



MARYLAND DEPARTMENT OF THE ENVIRONMENT
Water-Management Administration - Water Rights Division
1800 Washington Blvd. • Baltimore, Maryland 21230
(410) 537-3591 • 1-800-633-6101 • http://www.mde.state.md

New Application ☐ Change in Existing Permit	E AND USE WATERS OF THE STATE Application Number				
APPLICATION					
Harford County Public Schools (Owners Name)	410.809.6124				
102 South Hickory Avenue	Bel Air MD 21014				
(Mailing Address) (Street)	(City) (State) (Zip Code)				
WITHDRAWAL of GROUNDWATER Appropriate and use an annual average of 15,520 Gallons per day, and (Total Annual Use / 365)	WITHDRAWAL of SURFACE WATER Appropriate and use an annual average of				
19,400 gallons per day during (Highest Monthly Use / 30)	gallons per day, and a maximum use (Total Annual Use / 365) ofgallons in any one day, from				
month of maximum use, from 2 wells, having a diameter of 6 inches, and a depth of 200 feet	(Name of Stream or Waterway)				
PROJECT LOCATION (Estimate)	(Exact Location of Intake)				
100-400 block Schucks Road Bel Air, MD 21015 (ADC PG.18, Grid E6) (STREET ADDRESS - MAP DIRECTIONS - ADC PAGE/GRID - TAX MAP PAGE/GRID/PARCEL) County HA Subdivision or Town Bel Air Phone Number Name and Type of Business Educational Institution					
SUBDIVISIONS MUST INCLUDE PLAT - ALL	PROJECTS MUST INCLUDE LOCATION MAP				
PURPOSE The water will be used for: □ Community Water Supply □ Non-Potable Supply (sanitary non Drinking Water) Ă Potable Supply □ Cooling Water □ Irrigation	WASTEWATER TREATMENT AND DISPOSAL □ Public Sewer □ Groundwater □ Subsurface (Tilefield, Seepage Pit etc.) □ Spray Irrigation □ Other, Explain				
Process Water Firesuppression Other, explain water storage tank	Surface Water				
Other, explain water storage tank					
Other, explain water storage tank SIGNATURE Music Survivor, agen Ronald Kauffman Facilities Planner PRINT (NAME) (TITLE)	COATE) (Name of stream) THIS APPLICATION WILL NOTBE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP				
Other, explain water storage tank SIGNATURE Music Survinton, agen Ronald Kauffman Facilities Planner PRINT (NAME) REVIEW BY COUNTY ENVIRONMENTA	(Name of stream) THIS APPLICATION WILL NOTBE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP ALL HEALTH OR DESIGNATED AGENCY				
Other, explain water storage tank SIGNATURE August August Agen Ronald Kauffman Facilities Planner PRINT (NAME) REVIEW BY COUNTY ENVIRONMENTA THIS SECTION NOT TO BE CO	(Name of stream) THIS APPLICATION WILL NOTBE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP AL HEALTH OR DESIGNATED AGENCY COMPLETED BY APPLICANT				
Other, explain water storage tank SIGNATURE Music Survivation, agen Ronald Kauffman Facilities Planner PRINT (NAME) REVIEW BY COUNTY ENVIRONMENTA	(Name of stream) THIS APPLICATION WILL NOTBE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP AL HEALTH OR DESIGNATED AGENCY COMPLETED BY APPLICANT				

(Signature)

(Title)



(Date)

MARYLAND DEPARTMENT OF THE ENVIRONMENT
Water Management Administration - Water Rights Division
1800 Washington Blvd. • Baltimore, Maryland 21230
(410) 537-3591 • 1-800-633-6101 • http://www.mde.state.md

== = = = = = = = = = = = = = = = = = =	E AND USE WATERS OF THE STATE Application Number
APPLICATION	
Harford County Public Schools (Owners Name)	410.809.6124
102 South Hickory Avenue	Bel Air MD 21014
(Mailing Address) (Street)	(City) (State) (Zip Code)
WITHDRAWAL of GROUNDWATER Appropriate and use an annual average of 15,520 Gallons per day, and (Total Annual Use / 365) 19,400 GHighest Monthly Use / 30) Gallons per day during	WITHDRAWAL of SURFACE WATER Appropriate and use an annual average of gallons per day, and a maximum use (Total Annual Use / 365)
month of maximum use, from 2 wells, having a	ofgallons in any one day, from
diameter of 6 inches, and a depth of 200 feet	(Name of Stream or Waterway)
(Estimate) (Estimate) PROJECT LOCATION	(Exact Location of Intake)
(STREET ADDRESS - MAP DIRECTIONS - ADDRESS - MAP	Phone Number
SUBDIVISIONS MUST INCLUDE PLAT - ALL F	
The water will be used for:	WASTEWATER TREATMENT AND DISPOSAL □ Public Sewer
□ Non-Potable Supply (sanitary non Drinking Water) □ Potable Supply □ Cooling Water □ Irrigation □ Process Water Firesuppression □ Other explain water storage tank	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain ☐ Surface Water
□ Non-Potable Supply (sanitary non Drinking Water) □ Potable Supply □ Cooling Water □ Irrigation □ Process Water Firesuppression □ Other, explain water storage tank	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain
□ Non-Potable Supply (sanitary non Drinking Water) □ Potable Supply □ Cooling Water □ Irrigation □ Process Water Firesuppression ☑ Other, explain water storage tank □ SIGNATURE □ Ronald Kauffman Facilities Planner I	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain ☐ Surface Water ☐ Surface Water ☐ INTERIOR OF STREAM ☐ THIS APPLICATION WILL NOT BE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP
Non-Potable Supply (sanitary non Drinking Water) Potable Supply Cooling Water Irrigation Process Water Firesuppression Other, explain water storage tank SIGNATURE Ronald Kauffman Facilities Planner 1 PRINT (NAME) (TITLE) REVIEW BY COUNTY ENVIRONMENTAL	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain_ ☐ Surface Water
Non-Potable Supply (sanitary non Drinking Water) Potable Supply Cooling Water Irrigation Process Water Firesuppression Other, explain water storage tank SIGNATURE Ronald Kauffman Facilities Planner 1 PRINT (NAME) (TITLE) REVIEW BY COUNTY ENVIRONMENTAL THIS SECTION NOT TO BE CO	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain ☐ Surface Water ☐ INTERIOR OF STREAM ☐ THIS APPLICATION WILL NOT BE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP ☐ AND LOCATION MAP ☐ LHEALTH OR DESIGNATED AGENCY ☐ DMPLETED BY APPLICANT
Non-Potable Supply (sanitary non Drinking Water) Potable Supply Cooling Water Irrigation Process Water Firesuppression Other, explain water storage tank SIGNATURE Ronald Kauffman Facilities Planner 1 PRINT (NAME) REVIEW BY COUNTY ENVIRONMENTAL THIS SECTION NOT TO BE CO	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain ☐ Surface Water ☐ INTERIOR OF STREAM ☐ THIS APPLICATION WILL NOT BE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP ☐ AND LOCATION MAP ☐ LHEALTH OR DESIGNATED AGENCY ☐ DMPLETED BY APPLICANT
Non-Potable Supply (sanitary non Drinking Water) Potable Supply Cooling Water Irrigation Process Water Firesuppression Other, explain_water storage tank SIGNATURE Ronald Kauffman Facilities Planner 1 PRINT (NAME) (TITLE) REVIEW BY COUNTY ENVIRONMENTAL	☐ Groundwater ☐ Subsurface (Tilefield, Seepage Pit etc.) ☐ Spray Irrigation ☐ Other, Explain ☐ Surface Water ☐ DISCHARGE PERMIT # THIS APPLICATION WILL NOT BE PROCESSED WITHOUT A SIGNATURE AND LOCATION MAP L HEALTH OR DESIGNATED AGENCY DMPLETED BY APPLICANT

(Signature)


(Title)



(Date)

410 537 3157


TD: 4106383165



NOTICE OF EXEMPTION TO APPROPRIATE AND USE GROUND WATER

'See Instructions on Page 2 to complete this form' New Exemption Change Existing Permit to an Examption (Provide permit # Provide Name of Existing Fermit Holder: HARFORD CONTACT INFORMATION CO. PUBLIC SCHOOLS JFFMAN Konald. Karffmanishous lor (Name) (E-mail Address) 2101 WITHDRAWAL of GROUNDWATER WELL INFORMATION Quantity to be Used Planned or existing Wells to be used (Number) (1) 4(400 (1) gallons per day based on an annual average (Total Annual Use + 365) Diameter of Well(s) (Inches) gallons per day during month of maximum upo (highest monthly total + 30) Depth of Well(s) (Feet) Tag Number(s) of Well(s) (Number) Quantities should reflect highest sittle pated demand. Aquiter to be used if known (Name) LOCATION'S MAP of WITHDRAWAL WELL(S) ATTREET ADDRESS ADO PAGE/GRID - TAX MAP PAGE/GRID/PARCEL County Subdivision or Town Name and Type of Business -25 ELEMENT PURPOSE CHECK APPLICABLE BOX The water will be used for:
Potable Sapply
Cooling Water Check if: The proposed water withdrawal Contact Non-Contact Irrigation | Check If: ___ Lawn __ Garden _ Will Will Not Process Water
Non-Potable Supply (senitary non-Drinking Water)
Other, explain occur within a Water Management Strategy Area. To the best of iny knowledge, the information submitted on this form is true, accurate, and complete. I am aware that submitting false, inoccurate or incomplete information may subject me to paneths showed under Mayton (specifical). NOTE: THIS NOTICE OF EXEMPTION WILL NOT SIGNATURE BE ACCEPTED WITHOUT A PRINT (Nem SIGNATURE AND

Form Number MDE/WMA/PER.077-2 Revision Date 12/19/2007 TTY Users 1-800-735-2258



_					OTATE DEDAUT AUGUSED
	B 1 6252 SEQUENCE NO.	STATE OF I	MARYLAND		STATE PERMIT NUMBER
Ľ	(msz ssz sitzi)	APPLICATION FOR PE	ERMIT TO DRILL WELL	14	4-95 - 1542
	1 2 3 6	pleas	e type	70	ill in this form completely 79
L			D O		I OF WELL
ı	Date Received (APA)	DMATION	B 3 HARFOR	D	I OI WELL
ı	8 MM DD YY 13 OWNER INFO	HIVIATION	8 COUNTY		21
١	HARROLD Court PIB	LIC SCHOOLS	1 AND OF B	Term	
ı	15 Last Name Owner	First Name 34	23 SUBDIVISION	,	A 1 42
ı	127 South Heckory	tue.	CECTION I	LOT L	Proposed 50 Campus Hills Elem. School
ı	102 South Hickory Street or RPD	55	SECTION 44 46	48	50 Campus Hills
ı	20 Air mo	7/1/4	Charlyste		Elein. Shoo
ı	57 Town 70 State	72 Zip 76	52 NEAREST TOWN		71
t	DRILLER INFORMATION		MILES FROM TOWN (enter	0 if in town)	1 Z M II
ı		MW D 304	MILES FROM TOWN (enter	o ii iii towii)	73 76 77 78
ı	Offilier's Name	M W D 30 4 76 License No. 81	B 4		4
ı	Total Dellar	The	1 2 DIRECTION OF WELL FROM	12	5 Shucks Pd
ı	Firm Name		TOWN (CIRCLE BOX)	11	NEAR WHAT ROAD 30
ı	3 700 Rush Pd. Jarrettsu	1/2 MD 2584	_ N	ON WH	ICH SIDE OF ROAD
ı	Address 104	ucjuy -usj	NW 8 NE		E APPROPRIATE BOX)
ı	Dan Kolly	9/17/09	8-9		WEST CLEAST
ı	Signature	Date	(W) TOWN E	2 296	50 B4 58 37 SOUTH
I	B 2 WELL INFORMATION	٥		03	DISTANCE FROM ROAD
ı	1 2 APPROX. PUMPING RATE - (GAL. PER MIN.)	8 12	IS S		ENTER FT OR MI 38 39
ı		0	W S 8-9	TAY MAD	42 BLK: 74 PARCEL 331
ı	AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14	20	8		
I	USE FOR WATER (CIRCLE A	PPROPRIATE BOX)			D IN BY DRILLER
1	DOMESTIC POTABLE SUPPLY & RESIDE	ENITIAL	HEALIF	DEPART	MENT APPROVAL
ı	D DOMESTIC POTABLE SUPPLY & RESIDE	INTIAL	Hartord		12
	- FARMING / IVESTOCK WATERING & AG	RICULTURAL	COUNTY NAME		COUNTY NO.
1	IRRIGATION		STATE SIGNATURE		INSERT S
١	22 I INDUSTRIAL, COMMERICIAL, DEWATER	ING	DATE ISSUED . A	1	41
١	P PUBLIC WATER SUPPLY WELL		10-20-09	au A	Surve 10-20-09
١	TEST OBSERVATION, MONITORING		43 MM DD YY 48		NATURE EXP. DATE
	9		NORTH 625 0	0 0 GI	AST /001 000
	G GEO-THERMAL		50	55	57 63
ı			SHOW MAJOR FEATURES	S OF	
	APPROXIMATE DEPTH OF WELL 45	FEET	BOX & LOCATE WELL ' _ WITH AN X		
	APPROXIMATE BEFTITO WELL 24	28	SOURCES OF DRILLING	MATED	
ı	APPROXIMATE DIAMETER OF WELL	6 NEAREST INCH	1.	WAILH	
	AFT HOAIMATE BINNETER OF WEEL	INOTI	2.		X
	METHOD OF DRILLING	G (circle one)	3.		
	BORED (or Augered) JETTED	Jetted & DRIVEN			
	30 AIR-ROTary AIR-PERcussion	ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBER	R	
	37 CABLE REVerse-ROTary	DRive-POINT	FROM THE MAP HERE		
	other		+		
		DENED WELLS	E 1000		000
	REPLACEMENT OR DEEF (CIRCLE APPROPRIAT		,		000
	N THIS WELL WILL NOT REPLACE AN EXIS	The State of the S	N 620		
	THIS WELL WILL BERLACE A WELL THAT		DRAW A SKETCH BELOW		
	ABANDONED AND SEALED		RELATION TO NEARBY T		
	THIS WELL WILL REPLACE A WELL THAT		DISTANCE FROM WELL		
	as a standby-contact local appro	VING AUTHORITY		1CT	22
	D THIS WELL WILL DEEPEN AN EXISTING	WELL		4	
۱	PERMIT NUMBER OF WELL TO BE REPLACED		N 81	Cas	
	(IF AVAILABLE) 41 H 1 - 93	- 0 7 5 452	7	1/4	
	Not to be filled in by driller (MDE OR	COUNTY USE ONLY)	\$	1.	
	Total and many dimensional	in the same of the	7	1.	
	APPROP. PERMIT NUMBER	G		V	
	11.	0- 1-10	A	(X)	
	PERMIT No.	$\frac{-95}{72}$ $\frac{-1592}{78}$			
	70 71	12 13 14 15 16 11 18 19	11 21	00	
	SPECIAL CONDITIONS NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED	File under	Campus Hills	6.5	

All Williams or halfs on his his his					
c1 2864		QUENC DE USE		STATE OF MARYLAND	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
1 2 3 (THIS NUMBER IS TO BE	6 E PLINCHED			WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY	COUNTY
IN COLS. 3-6 ON ALL C.	ARDS)	E MELI	COMPL	PLEASE TYPE ETED Depth of Well	NUMBER PERMIT NO.
DATE Received	DAT	M VVELI	00 1	² 9 22 500 26	FROM "PERMIT TO DRILL WELL"
8 13	15			(TO NEAREST FOOT)	28 29 30 31 32 33 34 35 36
OWN THE T	HARPON 18 2 same	ep (pointy		Rel AIR
STREET OR RFD_ SUBDIVISION	ind of		wins	Chery Ave NESTION TOWN_B	LOT _3
	LL LOG		\$1. 12 · 1	GROUTING RECORD YES NO	C 3
The second secon	d for driven w	and the sales and	THEIR	WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2 PUMPING TEST
STATE THE KIND OF FOR COLOR, DEPTH, THICKN	The state of the s	ET BE	check	TYPE OF GROUTING MATERIAL (Circle one) CEMENT BENTONITE CLAY BC	HOURS PUMPED (nearest hour)
DESCRIPTION (Use additional sheets if needed)	FROM	то	if water bearing	NO. OF BAGS 46 8 NO. OF POUNDS 45 46	PUMPING RATE (gal. per min.) 30 • 6
dint	0	1		GALLONS OF WATER 90 V	METHOD USED TO
50ff brown	1	20		from O ft. to SOUTON 58 ft.	MEASURE PUMPING RATE _ Timen
hard tan	20	50		48 TOP 52 54 BOTTOM 58 (enter 0 if from surface)	WATER LEVEL (distance from land surface)
safe brown	30	55		casing types CASING RECORD	BEFORE PUMPING 17 20 ft.
hardter/9124	, 55	73		insert appropriate STEEL CONCRETE	WHEN PUMPING /29 ft.
100				code below PLASTIC OTHER	TYPE OF PUMP USED (for test)
m. hard brown wichips	73	80		MAIN Nominal diameter Total depth	A air P piston T turbine
4000 can 100	2 80	145		CASING top (main) casing of main casing TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary O other (describ
100129.29	145	150	-	PL 63 64 63 70	27 27 below)
Med gray roc	L 150	230		E OTHER CASING (if used)	J jet S submersible
hard gray rock	230	240	-	diameter depth (feet) H inch from to	PUMP INSTALLED .
had day rock	240	455		A S	DRILLER INSTALLED PUMP YES (NO (CIRCLE) (YES or NO).
6. Al green 10	455	470	-	G	IF DRILLER INSTALLS PUMP, THIS SECTION
16180 116 9.01	6470	500		screen type SCREEN RECORD	MUST BE COMPLETED FOR ALL WELLS. TYPE OF PUMP INSTALLED
lang loca	(720			or open hole ST BR HO	PLACE (A,C,J,P,R,S,T,O) 29 IN BOX 29.
				(appropriate code BRONZE HOLE	CAPACITY: GALLONS PER MINUTE
				below PLASTIC OTHER	(to nearest gallon) 31 34 PUMP HORSE POWER
				C 2 DEPTH (nearest ft.)	PUMP COLUMN LENGTH
NUMBER OF UNSUCCES		-		1.PL 60 100	(nearest ft.)
WELL HYDROFRACTUR		Y	(W)	A 8 9 11 15 17 21	CASING HEIGHT (circle appropriate box and enter casing height)
CIRCLE APPR				H 2 23 24 26 30 32 36	LAND SURFACE
WHEN THIS WELL W	AS COMPLET			S C 3 R 38 39 41 45 47 51	below (nearest foot)
P TEST WELL CONVER		DUCTION		E SLOT SIZE 1 .020 2 3	A LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION" AND			TION" AND	N DIAMETER (NEAREST	SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND /OR
IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY			RESENTED ST OF MY	OF SCREEN OF SCREEN INCH)	LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES THAN TWO DISTANCES
KNOWLEDGE.				from to	(MEASUREMENTS TO WELL)
DRILLERS LIC. NO.1 M W D 3 & 4 1			I 1	GRAVEL PACK IF WELL DRILLED WAS FLOWING WELL	
DRILLERS SIGNATURE (MUST MATCH SIGNATURE	RE ON APPLICA	TION)	N CAN	INSERT F IN BOX 68 68 MDE USE ONLY	30'
	MWD	527 B	4.	(NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q	
Mast 1	1			70 72	15 38 38 LA®
SITE SUPERVISOR (sign responsible for sitework in				TELESCOPE LOG 74 75 76	2 章章
Toopension for sitework I	amorett non	pormitt		CASING INDICATOR OTHER DATA	1.4

	04004	. :			TATE PERMIT NUMBER
	B = 1 = 0.1821 = 0.00 SEQUENCE NO. (MDE USE ONLY)		MARYLAND	1/4	01 20/18
	1 2 3 6		ERMIT TO DRILL WELL	<u>H</u> 17	<u> </u>
		pieas	e type		n this form completely "
801	Date Received (APA) B MM DD YY 13 OWNER INFOR	MATION /	B 3 HARFOR	LOCATION O	F WELL
8 -	15 Last Name Owner	First Name 34	23 SUBDIVISION	BLEV	11/5
38	15 PROSPECT Mill	R.		LOT 1 4	4
22	36 Street or RFD	55	SECTION 44 46	LOT 48	50
	BEL Air Md. 2	1015	Fulfo	PRA	
	DRILLER INFORMATION	72 Zip 76	52 NEAREST TOWN		71 J
	OU PUIC TONES N	WD 047	MILES FROM TOWN (ente		76 77 78
	Driller's Name	License No. 81	B 4	311 4	
	Firm Name	Peilling ING	DIRECTION OF WELL FROM TOWN (CIRCLE BOX)		NEAR WHAT ROAD 30
	1220 TROSPECT MILL P.A. Address	DEL/HIL/14/ 210/5	N NE 8-9	ON WHICH (CIRCLEIAI	SIDE OF ROAD PROPRIATE BOX) 13337960 WEEL
	Signature 80	Date	W TOWN E	Baros CD	34 62 37 SOUTH
	B 2 WELL WFORMATION 1 2 APPROX. PUMPING RATE —	.5		blen tox.	ISTANCE FROM ROAD
	(GAL. PER MIN.) 8	471 A		im 4	2 ENTER FT OR MI 38 39 33/
	AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14	20		TAX MAP: 4	BLK: TP PARCEL DI
	USE FOR WATER (CIRCLE APP	PROPRIATE BOX)			IN BY DRILLER INT APPROVAL
	DOMESTIC POTABLE SUPPLY & RESIDEN	TIAL	Harko	ed	17
	F FARMING (LIVESTOCK WATERING & AGRI	CULTURAL	COUNTY NAME		COUNTY NO.
	IRRIGATION 22 INDUSTRIAL COMMERICIAL DEWATERIN	e	STATE SIGNATURE	A-1-	INSERT S
	P PUBLIC WATER SUPPLY WELL	o .	DATE ISSUED	oodylli	Eliano 8/10/01
	T TEST, OBSERVATION, MONITORING		43 AM DD YY 48	CØ SIGNAT	
	G GEO-THERMAL		NORTH 6240	0_0 EAST GRID	/000 0 0 0
			50	22	57 63
	APPROXIMATE DEPTH OF WELL 200	J FEET 28	SHOW MAJOR FEATURES BOX & LOCATE WELL WITH AN X	-	
	APPROXIMATE DIAMETER OF WELL	NEAREST INCH	SOURCES OF DRILLING V	1	
	METHOD OF DRILLING	/airala ana)	2.	/	<
	BORED (or Augered) JETTED	Jetted & DRIVEN	3 .		
	20	ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBER	3	
	37 CABLE REVerse-ROTary	DRive-POINT	FROM THE MAP HERE		
	other		= 1000		
	REPLACEMENT OR DEEPEI (CIRCLE APPROPRIATE		= 100.0		000
	N THIS WELL WILL NOT REPLACE AN EXISTIF	•	N 620	 -	
	THIS WELL WILL REPLACE A WELL THAT V	VILL BE	DRAW A SKETCH BELOW RELATION TO NEARBY TO		
	ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT V	VILL BE USED	DISTANCE FROM WELL T		
	S AS A STANDBY-CONTACT LOCAL APPROVII FOR POLICY ON STANDBY WELLS	NG AUTHORITY		urch vi	ur Rd
	THIS WELL WILL DEEPEN AN EXISTING WE	ELL		uren VI	ue rai
	PERMIT NUMBER OF WELL TO BE REPLACED OF (IF AVAILABLE) 41 -	R DEEPENED 52	N	2	
	Not to be filled in by driller (MDE OR CO		A	Shucks	
				7	
	APPROP. PERMIT NUMBER	G A P 63		Z	\ x
	PERMIT No. HA -	94 - 3848		9.	
		2 73 74 75 76 77 78 79	<u>'</u>		
	SPECIAL CONDITIONS				₩

C 1 8348 SEQUENCE NO. (MDE USE ONLY)	STATE OF MARYLAND	THIS REPORT MUST BE SUBMITTED AFTER WELL IS COMPLETED.
1 2 3 6	WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY	COUNTY 12
ST/CO USE ONLY DATE WELL COMPL	PLEASE TYPE ETED Depth of Well	PERMIT NO.
DATE Received	22 <u>200</u> 26	FROM "PERMIT TO DRILL WELL" HA-94 - 3848
13 15	20 (TO NEAREST FOOT)	28 29 30 31 32 33 34 35 36 37
OWNER PETERS, KICHA	first name	
STREET OR RFD SUBDIVISION LAND OF RLEVIA	VS TOWN	LOT 4
WELL LOG	GROUTING RECORD Yes no	[C]3
Not required for driven wells	WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2 PUMPING TEST
STATE THE KIND OF FORMATIONS PENETRATED. THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING	TYPE OF GROUTING MATERIAL (Circle one)	HOURS PUMPED (nearest hour) 3
DESCRIPTION (Use additional sheets if needed) DESCRIPTION (Use if water bearing to be a constitution of the be	CEMENT CM BENTONITE CLAY B C	8 9
	NO. OF BAGS 15 NO. OF POUNDS 1410	PUMPING RATE (gal. per min.)
BROWN SANDY 0 8	DEPTH OF GROUT SEAL (to nearest foot)	METHOD USED TO MEASURE PUMPING RATE _ BUCKET
SOFT GOETH	from 0 ft. to 48 TOP 52 ft. to 54 BOTTOM 58	WATER LEVEL (distance from land surface)
MENTHERED 8 30	(enter 0 if from surface)	BEFORE PUMPING 28 ft.
ROCK	types	17 20
BROWN WEATHERED 20 29	(appropriate) STEEL CONCHETE	WHEN PUMPING $\frac{68}{22}$ ft.
Rock	below PLASTIC OTHER	TYPE OF PUMP USED (for test)
WEATHERED 29 45	MAIN Nominal diameter Total depth	A air P piston T turbine
VOCK 12	CASING top (main) casing of main casing TYPE (nearest inch)l (nearest foot)	C centrilugal R rotary O (describe
HARO GRAY +	60 61 63 64 66 70	27 27 below)
GREEN GRANTE 45 200	E OTHER CASING (if used)	jet submersible
	C diameter depth (feet)	
WATERBEARING AT:	C	PUMP INSTALLED DRILLER INSTALLED PUMP YES
		(CIRCLE) (YES or NO)
120', 152, 169'	CORECT PEROPE	IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
	screen type or open hole STBR HO	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) 29
	INSERT STEEL BRASS OPEN	IN BOX 29. CAPACITY:
	code below BRONZE HOLE	GALLONS PER MINUTE (to nearest gallon) 31 35
	PLASTIC OTHER	PUMP HORSE POWER
NUMBER OF UNSUCCESSFUL WELLS: O	C 2 DEPTH (nearest ft.)	PUMP COLUMN LENGTH 37 41
yes no	1 HO 48 200	(nearest ft.) 43 CASING HEIGHT (circle appropriate box
WELL HYDROFRACTURED Y	.A B 9 11 15 17 21 1	CASING HEIGHT (circle appropriate box and enter casing height)
CIRCLE APPROPRIATE LETTER A WELL WAS ABANDONED AND SEALED	H ² 23 24 26 30 32 36	19 LAND SURFACE
WHEN THIS WELL WAS COMPLETED E ELECTRIC LOG OBTAINED	S C 3 R 38 39 41 45 47 51	below below (nearest)
P TEST WELL CONVERTED TO PRODUCTION WELL	E	A LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION" AND	SLOT SIZE 1 2 3 N DIAMETER (NEAREST	T SHOW PERMANENT STRUCTURES AND INDICATE NOT LESS THAN
IN COMFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY	OF SCREEN INCH)	TWO DISTANCES
KNOWLEDGE.	from to	(MEASUREMENTS TO WELL)
DRILLERS LIC. NO. 1 MWDD 47 1	GRAVEL PACK	\$ \\ G.
DRILLERS SIGNATURE	WAS FLOWING WELL INSERT F IN BOX 68 68	SHUC
(MUST MATCH SIGNATURE ON APPLICATION)	MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER)	3
LIC. NO. 1 M 5 D 1 3 7 1	T (E.R.O.S.) W Q	& 18 WELL
SITE SUPERVISOR (sign. of drillador journeyman	70	[~ [
responsible for sitework if different from permittee)	TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	

SEQUENCE NO.	CTATE OF	MARYLAND	STATE	PERMIT NUMBER
B 1 6256 (MDE USE ONLY)		ERMIT TO DRILL WELL	HA 0	15 - 15/24
1 2 3 6		e type	70	79
	prodo			form completely
Date Received (APA)		B 3 there and	LOCATION OF WE	LL
8 MM DD YY 13	RMATION	8 COUNTY		21 . 0
itage 13 0 811-	Sel-le.	Selection	Cornen LL	= 1dot Blevins
15 Last Name Owner	First Name 34	23 SUBDIVISION	4	42
152 South History	a Ar	OSOTION I	100/07	roposed TW-2
36 Street or RFD	55	SECTION 44 46	48 50 C	ampus Hills
Bel Are me	2/0/4	Churchyl	10 8	lem School
57 Town 70 State	72 Zip 76	52 NEAREST TOWN	7	71
DRILLER INFORMATION		MILES FROM TOWN (enter	O if in town)	Z M II
I wil KELLY	1 W D 3 04	MILES FROM TOWN (enter	73	76 77 78
	6 License No. 81	B 4		
Toves were Desume 1	we	1 2 DIRECTION OF WELL FROM	12215 E.C	homelwhe Kel.
Firm Name		TOWN (CIRCLE BOX)	11 NEAR	WHAT ROAD 30
3700 Rush Rd. Jarratine	le MD 21084		ON WHICH SIDE	OF ROAD NORTH
Address		8-9 1 E	(CIRCLE APPRO	PRIATE BOX)
Jave dly	10/15/09		2273150	WEST SEAST
B 2 WELL INFORMATION	Date	TOWN E	DISTAN	ICE FROM ROAD
B 2 WELL INFORMATION APPROX. PUMPING RATE —	0		DISTAI	ENTER FT OR MI 38 39
(GAL. PER MIN.)	8 12	S _W S _E	42	
AVERAGE DAILY QUANTITY NEEDED (GAL. PER DAY) 14	20	8-9 S 8-9	TAX MAP: 7 B	LK: 4B PARCEL 454
USE FOR WATER (CIRCLE AP		NOT TO	BE FILLED IN B	Y DRILLER
			DEPARTMENT A	
D DOMESTIC POTABLE SUPPLY & RESIDEN	NTIAL	Hartoral		12
EADMING ILIVESTOCK WATERING & AGR	ICULTURAL	COUNTY NAME		COUNTY NO.
IRRIGATION A PARTIE A		STATE SIGNATURE		INSERTS - AND
22 INDUSTRIAL, COMMERICIAL, DEWATERIN	NG	DATE ISSUED	1 1 1	INSERT S
P PUBLIC WATER SUPPLY WELL		10-21-09	Paul A Bus	NAC 10-21-01
TEST OBSERVATION, MONITORING		43 MM DD YY 48	CO SIGNATURE	EXP. DATE
			0 0 GRID	1000 000
G GEO-THERMAL		50	55 57	63
		SHOW MAJOR FEATURES	OF	
APPROXIMATE DEPTH OF WELL	FEET	BOX & LOCATE WELL '_	-	
24	28	SOURCES OF DRILLING W	VATER	
APPROXIMATE DIAMETER OF WELL	NEAREST INCH	1.	X	
METUOD OF DRIVING		2.	,	
METHOD OF DRILLING		3.		
BORED (or Augered) JETTED 30 AUD DOT	Jetted & DRIVEN		1,24	prophhe
AIH-HOTary AIH-PERcussion	ROTARY (Hydraulic Rotary)	WRITE THE BOX NUMBER	Cer	1
CABLE HEVERSE-HOTARY	DRive-POINT	FROM THE MAP HERE	NOX B	bood
other		E /000	109	propoline schoolistd
REPLACEMENT OR DEEPE (CIRCLE APPROPRIATE		E /600	660	
THIS WELL WILL NOT REPLACE AN EXISTI		N 620	- 000	
THE WELL WILL BERLAGE A WELL THAT		DRAW A SKETCH BELOW	SHOWING LOCATION	OF WELL IN
ABANDONED AND SEALED		RELATION TO NEARBY TO	OWNS AND ROADS AN	ID GIVE
S THIS WELL WILL REPLACE A WELL THAT Y		DISTANCE FROM WELL TO	O NEAREST ROAD JU	NCTION
AS A STANDBY-CONTACT LOCAL APPROV	ING AUTHOHITY		1010	11.
D THIS WELL WILL DEEPEN AN EXISTING W	ELL 4		Church	nile .
PERMIT NUMBER OF WELL TO BE REPLACED OF		N	si A	
(IF AVAILABLE) 41	52		7 9	
Not to be filled in by driller (MDE OR C	OUNTY USE ONLY)	4	2 3	
THEORY OBAL TRUET	TALE C		31 A.	
APPROP. PERMIT NUMBER	,		4 X	
JA -	-95 - 15104		41	
PERMIT No. 70 71 7	2 73 74 75 76 77 78 79			
SPECIAL CONDITIONS	1111	CS. file		A
NOTE - APPROVING AUTHORITIES SHOULD USE SEPARATE SHEET IF NEEDED	mous Alls	. J. 41/e		❸

c1 2861	SEQUENCE NO. (MDE USE ONLY)	STATE OF MARYLAND	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
1 2 3 6 (THIS NUMBER IS TO BE PUNC IN COLS. 3-6 ON ALL CARDS)	CHED	WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY PLEASE TYPE	COUNTY NUMBER
ST/CO USE ONLY DATE Received	DATE WELL COMPL	ETED Depth of Well	PERMIT NO. FROM "PERMIT TO DRILL WELL"
8 2-P2 11 YY	7 31 0	22 500 26 (TO NEAREST FOOT)	HA - 95 - 1564 28 29 30 31 32 33 34 35 36 37
OWNER C	Hits 1		lads
STREET OR RFD	sst name 2215 E.		hircharle
SUBDIVISION WELL LO		GROUTING RECORD	C 3
Not required for dr		WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2 PUMPING TEST
STATE THE KIND OF FORMATION COLOR, DEPTH, THICKNESS AN	IS PENETRATED, THEIR ID IF WATER BEARING	TYPE OF GROUTING MATERIAL (Circle one)	HOURS PUMPED (nearest hour)
DESCRIPTION (Use additional sheets if needed)	FEET check if water bearing	CEMENT C M BENTONITE CLAY B C	2.0
dist	0 1	NO. OF BAGS 46 NO. OF POUNDS 5749 GALLONS OF WATER 38	PUMPING RATE (gal. per min.) 11 15 METHOD USED TO
Soft brown	1 20	DEPTH OF GROUT SEAL (to nearest foot)	MEASURE PUMPING RATE Times
he do can rock	20 27	from 6 ft. to 54 BOTTOM 58 ft.	WATER LEVEL (distance from land surface)
hard gray rock thardten rock	2 52	(enter 0 if from surface) CASING RECORD	BEFORE PUMPING 30 ft.
hard gray rock 3 hard tan rock 5	52 54	types insert ST CO	WHEN PUMPING 300 ft.
hard gray rock 5	4 64	appropriate code pelow PL OT	TYPE OF PUMP USED (for test)
hard gray rock	64 76	PLASTIC OTHER	A ai P piston T turbine
hard then rech	76 78	MÅIN Nominal diameter Total depth CASING top (main) casing of main casing TYPF (nearest inch)! (nearest foot)	27 27 other
parte !	18 80	TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary (describe below)
hard or out &		60 61 63 64 66 70	jet S submersible
hard gray rock 8	26 88 V	C OTHER CASING (if used) A diameter depth (feet) inch from to	21 21
MILLIAN IN			DRILLER INSTALLED PUMP YES NO
hard gray sode &	100	S I N	(CIRCLE) (YES or NO)
m. hard gray but 3		G	IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
hard grayrold 3	55 500	screen type or open hole STBR HO	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) 29
		insert STEEL BRASS OPEN	IN BOX 29. CAPACITY:
		code below BRONZE HOLE	GALLONS PER MINUTE (to nearest gallon) 31 35
		PLASTIC OTHER	PUMP HORSE POWER 37 41
NUMBER OF UNSUCCESSFUL	WELLS:	DEPTH (nearest ft.)	PUMP COLUMN LENGTH (nearest ft.)
WELL HYDROFRACTURED	yes	E 1 HO 25 500	CASING HEIGHT (circle appropriate box
	Y	Ĉ,	above) and enter casing height)
A WELL WAS ABANDONED	AND SEALED	H 23 24 26 30 32 36 S	LAND SURFACE (nearest)
E ELECTRIC LOG OBTAINED		C 3 R 38 39 41 45 47 51	below) (Hearesty foot)
P TEST WELL CONVERTED TO		E SLOT SIZE 1 2 3	LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS
I HEREBY CERTIFY THAT THIS WELL H ACCORDANCE WITH COMAR 26.04.04 "\ IN CONFORMANCE WITH ALL CONDITION	WELL CONSTRUCTION" AND ONS STATED IN THE ABOVE	DIAMETER (NEAREST OF SCREEN INCH)	BUILDING, SEPTIC TANKS, AND /OR LANDMARKS AND INDICATE NOT/LESS
CAPTIONED PERMIT, AND THAT THE HEREIN IS ACCURATE AND COMPLE KNOWLEDGE.	TE TO THE BEST OF MY	56 60 from to	THAN TWO DISTANCES (MEASUREMENTS TO WELL)
DRILLERS LIC NO.1 M.	WD 304,	GRAVEL PACK	LPL 1-31-2011
Stave K	de	IF WELL DRILLED WAS FLOWING WELL INSERT F IN BOX 68 68	M Ta
DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON A		MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER)	6
LIC. NO. 1	20910.	T (E.R.O.S.) W Q	1071 8
for the		70	€ € ®
SITE SUPERVISOR (sign of dri responsible for sitework if differe	nt from permittee)	TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	i i
NO DESCRIPTION OF THE PROPERTY		OPICINAL	

		STATE OF MARYLAND	45 S AFTER WELL IS COMPLETED.
	FIED	FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE	NUMBER 1
	DATE WELL COMPLE	TED Depth of Well	PERMIT NO. FROM "PERMIT TO DRILL WELL"
B424 573	122393	22 5 0 26 (TO NEAREST FOOT)	HH - 93 - 02 06 28 29 30 31 32 33 34 35 36 37
WNER	Long, Tom		22 23 33 31 42 33 33 33 33
TREET OR RFD	last name 117 5-	Le seles state first name TOWN	Churchville
UBDIVISION	LL LOG	SECTION 12-42 333/	LOT 2
Not required	for driven wells	WELL HAS BEEN GROUTED (Circle Appropriate Box)	C 3
	IEIR COLOR, DEPTH,	(Circle Appropriate Box) TYPE OF GROUTING MATERIAL	PUMPING TEST
ESCRIPTION (Use	FEET Check if wate bearing	CEMENT C M BENTONITE CLAY B C	HOURS PUMPED (nearest hour)
dditional sheets if need		NO. OF BAGS NO. OF POUNDS	PUMPING RATE (gal. per min. 11 15
Red Clay	0 15	GALLONS OF WATER DEPTH OF GROUT SEAL (to nearest foot)	METHOD USED TO MEASURE PUMPING RATE 1 HDSub
501		from 48 TOP 52 ft. to 49 ft.	WATER LEVEL (distance from land surface)
		(enter 0 if from surface)	BEFORE PUMPING 17 20
2	1 15 40	types insert ST CO	WHEN PUMPING 53
Brown SAM	7	(appropriate) STEEL CONCRETE	TYPE OF PUMP USED (for test)
5011	18 8 9 1	code below PLASTIC OTHER	A air P piston T turbine
1	139	MAIN Nominal diameter Total depth	C centrifugal R rotary O (describe
Bray Gran	7e 40 150	GASING top (main) casing of main casing TYPE (nearest inch) (nearest foot)	27 27 below)
ROCK		PP BI SOLIT	jet submersible
		60 61 63 64 66 70	
	1 001	OTHER CASING (if used) G diameter depth (feet)	PUMP INSTALLED
		inch from to	DRILLER WILL INSTALL PUMP YES (NO
No Gra	XVa3		(CIRCLE) (YES or NO) #F DRILLER INSTALLS PUMP, THIS SECTION
11 (2)	123/1	screen type SCREEN RECORD	MUST BE COMPLETED FOR ALL WELLS EXCEPT HOME USE
11000	17 JUM	screen type or open hole ST BR HO	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O)
NOK	11/0000	Appropriate STEEL BRASS OPEN	IN BOX - SEE ABOVE: 29 CAPACITY:
000	100 1 1	code below BRONZE HOLE	GALLONS PER MINUTE
		PLASTIC OTHER	(to nearest gallon) PUMP HORSE POWER
		1/2	PUMP COLUMN LENGTH 37 41 (nearest ft.)
		DEPTH (nearest ft.)	CASING HEIGHT (circle appropriate box
		6 8 9 11 15 17 21	and enter casing height)
Amala		82 11 11 11 11	LAND SURFACE (nearest
	OPRIATE LETTER	R T T T T T T T T T T T T T T T T T T T	49 50 51 100t)
	L WAS COMPLETED	E 3 41 45 47 51	LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS
E ELECTRIC LOG O	BTAINED VERTED TO PRODUCTION	SLOT SIZE 123	BUILDING, SEPTIC TANKS, AND/OR N LANDMARKS AND INDICATE NOT LESS
P WELL		OF SCREEN INCH)	THAN TWO DISTANCES (MEASUREMENTS TO WELL)
CORDANCE WITH COMAR NO IN CONFORMANCE WITH	WELL HAS BEEN CONSTRUCTED IN 26.04.04 "WELL CONSTRUCTION ALL CONDITIONS STATEDAIN THE	from to	
BOVE CAPTIONED PERMIT, A ENTED HEREIN IS ACCURATE Y KNOWLEDGE.	26.04.04 "WELL CONSTRUCTION ALL CONDITIONS STATED IN THE AND THAT THE INFORMATION ENE E AND COMPLETE TO THE BEST O	GRAVELL BRILLED WAS	
PRILLERS IDENT. NO.	368	FLOWING WELL INSERT	
The Control of the Co	· Franke	OFP USE ONLY (NOT TO BE FILLED IN BY DRILLER)	
PRILLERS SIGNATURE	URE ON APPLICATION)	T (E.R.O.S.) W Q	the state of the s
WOOT WATCH SIGNAL	(Day I'm	70 72 74 75 76	75 75
SITE SUPERVISOR (Sig	n. of driller or journeyman if different from permittee)	TELESCOPE LOG OTHER DATA CASING INDICATOR	
Septimine IOI SHEWOLK	(in different from permittee)	COLINTY	3 Chacks Rd

SEQUENCE NO. THIS REPORT MUST BE SUBMITTED WITHIN STATE OF MARYLAND (MDE USE ONLY 45 DAYS AFTER WELL IS COMPLETED. WELL COMPLETION REPORT COUNTY **FILL IN THIS FORM COMPLETELY** (THIS NUMBER IS TO BE PUNCHED NUMBER IN COLS. 3-6 ON ALL CARDS) **PLEASE TYPE** ST/CO USE ONLY DATE WELL COMPLETED Depth of Well FROM "PERMIT TO DRILL WELL" **DATE Received** 400 tA-93-0206 (TO NEAREST FOOT) 28 29 30 31 32 33 34 35 36 37 4 ANFOND Public Schools County OWNER South Hickory Auctirst name TOWN STREET OR RFD. SECTION Map 301 Landes of Blowins LOT **SUBDIVISION GROUTING RECORD WELL LOG** 3 Not required for driven wells WELL HAS BEEN GROUTED (Circle Appropriate Box) **PUMPING TEST** STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING TYPE OF GROUTING MATERIAL (Circle one) HOURS PUMPED (nearest hour) CEMENT CM check if water bearing BENTONITE CLAY BC FEET DESCRIPTION (Use additional sheets if needed) FROM TO NO. OF BAGS NO. OF POUNDS PUMPING RATE (gal. per min.) . GALLONS OF WATER METHOD USED TO Timen DEPTH OF GROUT SEAL (to nearest foot) MEASURE PUMPING RATE L TOP 52 ft. to _____ WATER LEVEL (distance from land surface) (enter 0 if from surface) **BEFORE PUMPING** hardgray rock 150 180 200 m. hard gray rock 180 200 hard gray rock 200 220 m. hard gray rock 220 240 CASING RECORD casing types CO ST insert WHEN PUMPING CONCRETE appropriate code OT TYPE OF PUMP USED (for test) below PLASTIC OTHER T turbine Nominal diameter Total depth MĂIN top (main) casing CASING of main casing other (nearest inch)! (nearest foot) TYPE (describe centrifugal rotary 0 below) 400 60 63 64 61 66 70 S J jet submersible OTHER CASING (if used) depth (feet) diameter from inch **PUMP INSTALLED** DRILLER INSTALLED PUMP YES NO (CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS. SCREEN RECORD screen type or open hole TYPE OF PUMP INSTALLED 29 PLACE (A,C,J,P,R,S,T,O) SIT BR HØ IN BOX 29. insert CAPACITY appropriate **BRONZE** HOLE **GALLONS PER MINUTE** code PL OT 35 (to nearest gallon) below PLASTIC **PUMP HORSE POWER** 37 41 C 2 DEPTH (nearest ft.) PUMP COLUMN LENGTH NUMBER OF UNSUCCESSFUL WELLS: (nearest ft.) 43 CASING HEIGHT (circle appropriate box WELL HYDROFRACTURED 8 9 11 15 17 21 and enter casing height) N above LAND SURFACE CIRCLE APPROPRIATE LETTER 36 23 24 26 30 32 A WELL WAS ABANDONED AND SEALED (nearest) WHEN THIS WELL WAS COMPLETED below foot) 41 50 51 **ELECTRIC LOG OBTAINED** 39 45 47 51 38 TEST WELL CONVERTED TO PRODUCTION P LOCATION OF WELL ON LOT SLOT SIZE 1 WELL SHOW PERMANENT STRUCTURE SUCH AS I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION" AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY BUILDING, SEPTIC TANKS, AND /OR (NEAREST DIAMETER LANDMARKS AND INDICATE NOT LESS OF SCREEN INCH) 56 60 THAN TWO DISTANCES (MEASUREMENTS TO WELL) KNOWLEDGE from drill existing well DRILLERS LIC. NO. 1 MW D 3 5 4 GRAVEL PACK IF WELL DRILLED deepen WAS FLOWING WELL 68 DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION) MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER) LIC. NO. 1 MW D 564 (E.R.O.S.) WQ (3) 70 72 SITE SUPERVISOR (sign. of driller or journeyman 74 75 76 LOG TELESCOPE responsible for sitework if different from permittee) INDICATOR OTHER DATA CASING

DENV-CR00

	,			
c1 6800	SEQUENCE N		STATE OF MARYLAND	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
1 2 3 (THIS NUMBER IS TO BE IN COLS. 3-6 ON ALL CAR	_ (DENV USE OF PUNCHĚD RDS)	NLY)	WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY PLEASE PRINT OR TYPE	COUNTY /~
ST/CO USE ONLY	· · · · · · · · · · · · · · · · · · ·			PERMIT NO.
DATE Received	DATE WELL CO	MPLETE		FROM "PERMIT TO DRILL WELL"
AUG x 4 1994	<u>6</u> 181013	19141	22 / 5 0 26 (TO NEAREST FOOT)	1/1 - 19 3 - 0 7 5 4 28 29 30 31 32 33 34 35 36 37
OWNER 13 L	(rehtru	. 1	Bower	
STREET OR RFD	last name			riford
	of 5 1/11		evilis SECTION MA 42 , B4, 83	<u>3</u> /
WELL		7. 72.	CROUTING RECORD	C 3
Not required for	r driven wells		WELL HAS BEEN GROUTED	<u>C 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3</u>
STATE THE KIND OF PENETRATED, THEIR			(Circle Appropriate Dox)	PUMPING TEST
THICKNESS AND IF			TYPE OF GROUTING MATERIAL CEMENT C M BENTONITE CLAY B C	HOURS PUMPED (nearest hour)
DESCRIPTION (Use	FEET	Check if water	\	PUMPING RATE (gal. per min.
additional sheets if needed)	FROM TO	bearing	NO. OF BAGS 18 NO. OF POUNDS 1692	to nearest gal.)
0			GALLONS OF WATER	METHOD USED TO BUCKET + WATE
BROWN]]		from 0 ft. to 6 3 ft.	MEASURE PUMPING RATE L VOTHCA WATER LEVEL (distance from land surface)
SANAY CLAY SOIL	}		48 TOP 52 54 BOTTOM 58	BEFORE PUMPING //8 III
1/2 1/	.		(enter 0 if from surface) casing CASING RECORD	BEFORE PUMPING
) 01L	0 15			WHEN PUMPING 56
			insert STEL CONCRETE	22 ' 25 TYPE OF PUMP USED (for test)
			appropriate STEEL CONCRETE CODE	
SOFT BROWN WEATHERED	15 50		below PLASTIC OTHER	A air P piston T turbine
3077	15 50		V	other
WEATHERED			MAIN Nominal diameter Total depth CASING top (main) casing of main casing	C centrifugal R rotary O (describe below)
SAND ROCK			TYPE (nearest inch) (nearest foot)	
'				jet Submersible
1-2 /	1		60 81 63 84 66 70	<u>.</u>
FRACIUNES	50 60		E OTHER CASING (if used)	
FRACTURED SAND ROCK			A diameter depth (feet) H inch from to	PUMP INSTALLED
1				DRILLER WILL INSTALL PUMP YES (NO)
			C C	(CIRCLE) (YES or NO) IF DRILLER INSTALLS PUMP, THIS SECTION
1/10/10	60 150	4	N	MUST BE COMPLETED FOR ALL WELLS
HARA GRAY	60 150		screen type SCREEN RECORD	EXCEPT HOME USE TYPE OF PUMP INSTALLED
GRANITE			or open hole ST BR HO	PLACE (A,C,J,P,R,S,T,O)
0101/101/1			/ appropriate \ STEEL BRASS OPEN	IN BOX - SEE ABOVE:
1			code BRONZE HOLE	CAPACITY: GALLONS PER MINUTE
			below PLASTIC OTHER	(to nearest gallon)
	<u></u>	L	C 2	PUMP HORSE POWER 137 41
IN HARD ROCK AREAS, IDI			1 2 6	PUMP COLUMN LENGTH (nearest ft.)
WHERE SATURATED FRAC	TURES WERE OBS	SERVED.	DEPTH (nearest ft.)	CASING HEIGHT (circle appropriate box
	yes	00		and enter casing height)
WELL HYDROFRACT		(N)		LAND SURFACE
			§ 23 24 26 30 32 36	below (nearest foot)
CIRCLE APPROP		. = =		49 50 51
A A WELL WAS ABAN			E 3 3 41 45 47 51	LOCATION OF WELL ON LOT A SHOW PERMANENT STRUCTURE SUCH AS
E ELECTRIC LOG OBT				BUILDING, SEPTIC TANKS, AND/OR
TEST WELL CONVE		CTION	SLOT SIZE 1 2 3 DIAMETER	N LANDMARKS AND INDICATE NOT LESS
P WELL		011011	OF SCREEN (NCH)	THAN TWO DISTANCES (MEASUREMENTS TO WELL)
THEREBY CERTIFY THAT THIS WE ACCORDANCE WITH COMAR 26	TOWARD CONST	DI ICTION"	from to	L LOT LINE
AND IN CONFORMANCE WITH A ABOVE CAPTIONED PERMIT, AND	LL CONDITIONS STATE THAT THE INFORMAT	D IN THE	GRAVEL PACK	120
SENTED HEREIN IS ACCURATE AT MY KNOWLEDGE.	ND COMPLETE TO THE	BEST OF	IF WELL DRILLED WAS FLOWING WELL INSERT	S SXU
	47		F IN BOX 68 68	Shuck So. Well
DRILLERS IDENT. NO.		_	MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER)	2
DRILLERS SIGNATURE	Mohn.	<u>.</u>	T (E.R.O.S.) W.Q.	〜
(MUST MATCH SIGNATUR	RE ON APPLICATIO	ON)	74 75 76	<u> </u>
			70 72	1 2
SITE SUPERVISOR (sign.	of driller or journe	yman	TELESCOPE LOG OTHER DATA	
responsible for sitework if	different from per	mittee)	CASING INDICATOR	·

C 1 2862 SEQUENCE NO. (MDE USE ONLY	STATE OF MARYLAND WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED. COUNTY
(THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS) ST/CO USE ONLY DATE WELL COMPL	PLEĀSE TYPE	NUMBER PERMIT NO.
DATE Received MM PD	22 265 26	FROM "PERMIT TO DRILL WELL" - 9 3 - 75 4 - 28 29 30 31 32 33 34 35 36 37
OWNER HARFORD COUNTY STREET OR RFD Last name / 02 Sou	Ty Public Schools the Hickory Auffrat name TOWN	Bel AIR
SUBDIVISION Land of Blave		
WELL LOG Not required for driven wells	GROUTING RECORD Yes no WELL HAS BEEN GROUTED (Circle Appropriate Box)	C 3
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING	(Circle Appropriate Box) TYPE OF GROUTING MATERIAL (Circle one)	PUMPING TEST HOURS PUMPED (nearest hour)
DESCRIPTION (Use additional sheets if needed) FROM TO bearing	CEMENT C M BENTONITE CLAY B C 45 46	8 9
Deepercal existing	NO. OF BAGS NO. OF POUNDS 45 46 GALLONS OF WATER DEPTH OF GROUT SEAL (to nearest foot)	PUMPING RATE (gal. per min.) 11 15 METHOD USED TO MEASURE PUMPING RATE
existing	from 48 TOP 52 ft. to 54 BOTTOM 58 ft.	WATER LEVEL (distance from land surface)
well	(enter 0 if from surface) CASING RECORD	BEFORE PUMPING /6 ft.
hard gray rock 150 236	types insert appropriate STEEL CONCRETE	WHEN PUMPING 265 ft.
M. hard gray rock 236 240 M. hard gray rock 240 263 M. hard gray rock 263 265	below PLASTIC OTHER MAIN Nominal diameter Total depth	TYPE OF PUMP USED (for test) P piston T turbine
m. hard gray rock 263 265	CASING top (main) casing of main casing TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary O other (describe below)
h	60 61 63 64 66 70 E OTHER CASING (if used)	J jet S submersible
6" hammer	A diameter depth (feet) H inch from to	
shanked off In the bottom	C As	DRILLER INSTALLED PUMP (CIRCLE) (YES or NO)
of the hole	N C C C C C C C C C C C C C C C C C C C	IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
7.	screen type or open hole ST BR HO OPEN	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX 29.
	(appropriate code below) BRONZE HOLE P L O T	CAPACITY: GALLONS PER MINUTE (to nearest gallon) 31 35
	C 2 DEPTH (nearest ft.)	PUMP HORSE POWER 37 41
NUMBER OF UNSUCCESSFUL WELLS:	1 2 1	PUMP COLUMN LENGTH (nearest ft.)
WELL HYDROFRACTURED Yes NO	E 1 8 9 11 15 17 21 C 2	CASING HEIGHT (circle appropriate box and enter casing height) 49 LAND SURFACE
A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED E ELECTRIC LOG OBTAINED TEST WELL CONVERTED TO PRODUCTION WELL	C 3 R 38 39 41 45 47 51 E SLOT SIZE 1 2 3	below LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION" AND IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY KNOWLEDGE.	DIAMETER (NEAREST INCH) 56 60 from to	SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND /OR LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)
DRILLERS LIC. NO. 1 M U D 3 2 4 1 DRILLERS SIGNATURE (MUST MATCH SIGNATURE ON APPLICATION)	GRAVEL PACK IF WELL DRILLED WAS FLOWING WELL INSERT F IN BOX 68 MDE USE ONLY	25'
LIC. NO. 1 M UD 5-64 1 Mad Moffett	(NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q	£ 737 &
SITE SUPERVISOR (sign, of driller or journeyman responsible for sitework if different from permittee)	70	drueway
DENV-CR00	COUNTY	

I	B 1 3625 SEQUENCE NO.	STATE OF	MARYLAND	STATE PERM	IT NUMBER
1	B 1 3625 (MDE USE ONLY)		ERMIT TO DRILL WELL	HA- 94	-5276
ı	, , ,		e type	70 fill in this form	n completely 79
ŀ	Date Received (APA)			LQCATION OF WELL	" completely
	8 19 02 OWNER INFO	RMATION	B 3 HAR FOR	EGUATION OF WELL	
	8 MM DD YY 13	Λ	8 COUNTY	21	
1	BLEWINS FAMILY	YARTNER ShiD	1		
I	15 Last Name Shuck Owner	First Name 34	23 SUBDIVISION		42
ł	1-107 Streets RAV		SECTION LJ	LOT L	
I	36 RFI A' Street or AFD	D (A) (- 55	44 46	48 50	
1	DEL HIR, MA	<u> 2/0/5</u>	- Churchi	46lt	
ł	DRILLER INFORMATION		52 NEAREST TOWN	1	/ 1
ļ	/ · · · · · · · · · · · · · · · · · · ·	· Wanus	MILES FROM TOWN (enter	0 if in town) $\lfloor \frac{1}{73} \rfloor = -$	<u>M</u> I J 76 77 78
ł	Duller's Name	76 License No 81	B 4	5 hucks	: 1
ł	GUDING THUES WELL	DR. 11: W. THE	1 2	10/ Strecks	P.M.
ı	Firm Name	A The state of the	DIRECTION OF WELL FROM TOWN (CIRCLE BOX)	11 NEAR WHA	T ROAD 30
ı	1220 PROSPECT MILL RA	BELATIC MC		ON WHICH SIDE OF	BOAD NORTH
ı	Address	2/6/5		(CIRCLE APPROPRIA	
	Hurry John 8-1	9-02		- 2 F	wEST S EAST
	Signature B 2 WELL INFORMATION	Date	(TOWN) E	34 2 <i>1)</i> DISTÂNCE F	•
	B 2 WELL MYFORMATION 1 2 APPROX PUMPING RATE -	5	M_/ T\ ` \	. ~ ! — ~ ~ ~	ER FT OR MI 38 39
1	(GAL PER MIN.)	8 12		42	10 -1
	AVERAGE DAILY QUANTITY NEEDED	500	8-6 [5] 8-6	TAX MAP: BLK	15 PARCEL 33/
	USE FOR WATER (CIRCLE A	PPROPRIATE BOX)		BE FILLED IN BY DE	
	DOMESTIC POTABLE SUPPLY & RESIDE	ENTIAL	HEALTH	I DEPARTMENT APPE	ROVAL
1	D BRIGATION	INTIAL	Hartord	'	12
ì	FARMING (LIVESTOCK WATERING & AGE	RICULTURAL	COUNTY NAME		COUNTY NO
	IRRIGATION 22 I INDUSTRIAL COMMERICIAL DEWATERS		STATE SIGNATURE	IN	SERT S
1	I MOODITING COMMENTS NOW A DEVINE	ING	DATE ISSUED	2010 -	the Analas
Į	P PUBLIC WATER SUPPLY WELL		43 MM DD YY 48	CO SIGNATURE	21 0121/95 EXP DATE
1	T TEST, OBSERVATION, MONITORING		NORTH (-26	00 EAST /OC	3 000
1	G GEO-THERMAL		GRID 50	55 GRID 57	63
1			SHOW MAJOR FEATURES	OF	-
-	APPROXIMATE DEPTH OF WELL 1_24	Û FEE1	BOX & LOCATE WELL ' WITH AN X		
1	24		SOURCES OF DRILLING W	VATER X	
1	APPROXIMATE DIAMETER OF WELL	NEAREST INCH	1.	,	
ł	METHOD OF DRIVING		2.		
ļ	METHOD OF DRILLING BORED (or Augered) JETTED	Jetted & DRIVEN	3.	ļ	
	30 AIR ROTary (AIR-PERcussion)	ROTARY (Hydraulic Rolary)	WOITE THE DOV NUMBER	,	
	37 CABLE REVerse-ROTary	DRIve-POINT	WRITE THE BOX NUMBER FROM THE MAP HERE	}	
	other		THOM THE MAN THEME		
	REPLACEMENT OR DEEP	PENED WELLS -	E 1000	000	
	(CIRCLE APPROPRIAT		/- 20	000	
	N THIS WELL WILL NOT REPLACE AN EXIST	TING WELL	N _ Q X U		
1	THIS WELL WILL REPLACE A WELL THAT	WILL BE		SHOWING LOCATION OF V DWNS AND ROADS AND GI	_
1	ABANDONED AND SEALED THIS WELL WILL REPLACE A WELL THAT	WILL BE LISED	1	O NEAREST ROAD JUNCTH	
1	34 FEIN AS A STANDBY CONTACT LOCAL APPRO	VING AUTHORITY	100	Churchvill	I RA
	FOR POLICY ON STANDBY WELLS THIS WELL WILL DEEPEN AN EXISTING V	NELL + PARCELY	I'	1	L_ / -//-
	PERMIT NUMBER OF WELL TO BE REPLACED (I Ax	\$ l	
	(IF AVAILABLE) 41	- - - - - - 5 2	N O	*	
	Not to be filled in by driller (MDE OR	COUNTY USE ONLY)		<u> </u>	
	, , , , ,	•	1 1 2	[
į	APPROP PERMIT NUMBER			<u>'</u>	
	HA	-94-5276	1 2	20	
	PERMIT No 11/1 T	72 73 74 75 76 77 78 79			
	SPECIAL CONDITIONS NOTE: SAMPLE VALUE AND THE RESERVE COLOR OF SAMPLE DELL'S AND EDUCATION OF				⊕

c 12988	St (M)	QUENC DE USE		. State of Maryland	THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.
(THIS NUMBER IS TO BE PER IN COLS. 3-6 ON ALL CARD	UNCHED			WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY PLEASE TYPE	COUNTY TAX # NUMBER 12 03177939
ST/CO USE ONLY DATE Received	DAT		COMPL		PERMIT NO. FROM "PERMIT TO DRILL WELL"
8 C C V 18		24 .	21 0	22 \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	HA - 94 - 50 76 28 29 30 31 32 33 34 35 36 37
OWNERS	evi	<u> </u>	Fa	mily Partnership	
STREET OR RFD	20/-	3ch	<u>uc</u> 1	55 Pd TOWN	Churchville
WELL WELL	LOG		<u> </u>	GROUTING RECORD YES NO	LOT
Not required for	r driven v	e!ls		WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2
STATE THE KIND OF FORMAT COLOR, DEPTH, TH:CKNESS	TONS PENE	ETRATED, ATER BEA	THEIR IRING	TYPE OF GROUTING MATERIAL (Circle ons)	PUMPING TEST HOURS PUMPED (necreat hour) 3
DESCRIPTION (Uco additional sheets if necessar)	FE FROM	ET TO	check if water		0 0
BROWN SOIL	O C	2.1	bearing	NO. OF BAGS 20 NO. OF POUNDS 1880	PUMPING RATE (gcl. par min.) 5 0
		21		GALLONS OF WATER 120	METHOD USED TO MEASURE PUMPING RATE BUCKET
WEATHERED GRAY ROLK	٦١	40		from O ft. to 63 ft. 48 TOP 52 ft. to 54 BOTTOM 58 ft. (enter 0 if from surface)	WATER LEVEL (distance from land surface)
				casing CASING RECORD	BEFORE PUMPING 32 ft.
HARO GRAY ROCK	(%0)	400		types insert STT CO STEEL CONCRETE	WHEN PUMPING 122 25 ft.
				code PI. OT PLASTIC OTHER	TYPE OF PUMP USED (for test)
WATERBEARING	AT:			MAIN Nominal diameter Total depth CASING top (main) casing of main casing	A air P piston T turbina
75 + 340	ļ.			TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary (describs bslow)
15, 240				60 61 63 64 65 70	J jet S submersible
11 } 				E OTHER CASING (if used) A diameter depth (feet)	<u> </u>
2000				inch from to	PUMP INSTALLED DRILLER INSTALLED PUMP YES (NO.)
					(CIRCLE) (YES or NO)
				SCIERO NOR SCREEN RECORD	IF DRILLER INSTALLS PUMP, THIS SECTION MUST BE COMPLETED FOR ALL WELLS.
				or open hole SIT BIE MO	TYPE OF PUMP INSTALLED PLACE (A,C,J,P,R,S,T,O) IN BOX 29.
				appropriate BRONZE HOLE	CAPACITY: GALLONS PER MINUTE
				balow PLASTIC OTHER	(to nearest gallon) 31 35 PUMP HORSE POWER
	<u> </u>			C 2 DEPTH (noarest ft.)	PUMP COLUMN LENGTH
NUMBER OF UNSUCCESSE		s:Q yes	no	1 HO 43 400	(nearest ft.) 43 47
WELL HYDROFRACTURED		Ÿ	N)	A 6 9 11 15 17 21	CASING HEIGHT (circle appropriate box and enter casing height)
CIRCLE APPROP A A WELL WAS ABANDON			ì	H 23 24 26 30 32 36	LAND SURFACE
WHEN THIS WELL WAS E ELECTRIC LOG OBTAINS		ED		C 3 R 38 39 41 45 47 51	below) (nearest)
P TEST WELL CONVERTED		DUCTION		E SLOT SIZE 1 2 3	A LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS WELL	34 "WELL CO	DNSTRUCT	ION" AND	N DIAMETER (NEAREST	SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND /OR
IN CONFORMANCE WITH ALL CONFORMANCE PERMIT. AND THAT THEREIN IS ACCUPATE AND CONFORMANCEDES.	HE INFORM	IATION PR	ESENTED	OF SCREEN (NCH)	LANDMARKS AND INDICATE NOT LESS THAN TWO DISTANCES
	лW D	η Δ	7.	from to	(MEASUREMENTS TO WELL)
Stam In	hh~	 -	/- '	IF WELL DRILLED WAS FLOWING WELL	٥
DRILLERS SIGNATURE OF	N APPLICA	TION)		INSERT F IN BOX 68 68 MDE USE ONLY	c
LIC. NO. 1	<u>5</u> D	ŤŦ;	1.	(NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W.Q.	E LANE
time	A.	Jon	ا ہد	70 72	HOUSE HOUSE
SITE SUPERVISOR (sign. of responsible for sitework if diff				TELESCOPE LOG 74 75 76 CASING INDICATOR OTHER DATA	

***	MARYLAND DEPARTMENT OF THE ENVIRONME 2500 BROENING HIGHWAY, BALTIMOR	NT, WATER MAN	AGEMENT ADMINISTRA 1224, (410) 631-3784	TION
***	WATER WELL ABANDONMEN	T-SEALING REPO	ORT FORM	1. 200-
SUB!	MIT COPIES OF COMPLETED FORM TO: COUNTY ENVIRONMENT AGENCY (contact MDE, WMA if ad WELL OWNER MDE, WATER MANAGEMENT ADMINISTRATION, WELL PR	50	*******	ica nd water
DAT	r/-/-/1	day/year)		The second secon
*	PERMIT NUMBER OF ABANDONED WELL (if any)	\triangle	JA	107/
*	PERMIT NUMBER OF REPLACEMENT WELL		HA - 94-	5216
•	PERSON ABANDONING WELL: George Thomas &	SWELL DR		
*	OWNER'S NAME: Blavins Family Limited Partner	ship		RCLE: MWD/MSD/MGD
	WELL LOCATION:	Chan	SITE LOCATION MAI	2
	NEAREST TOWN: Fulford TAX MAP 42 BLOCK 4B PARCEL 331 SUBDIVISION: LOT: LOT: NEAREST ROAD: 2215 Churchville Rd TAX # 03177939		House House	ļ
			Enchs Pd.	
*	TYPE OF WELL BEING ABANDONED:			
	DRILLEDJETTEDBORED/AUGEREDHAND DUGOTHER (specify)		LOG OF SEAL	FEET TO
	USE CODE		Cash-	FROM TO
	DOMESTICMUNICIPAL/PUBLICIRRIGATIONINDUSTRIALGEOTHERMAL		Crush- n-Run	
	TYPE OF CASING:			
	STEEL PLASTIC OTHER (specify)		,	
*	SIZE OF CASING: 42 INCHES IN DIAMETER		VOLUME OF M	ATERIAL USED
	DEPTH OF WELL: 20 FEET DEEP		00 1	
*	WAS ANY CASING REMOVED? YES NO/ if yes, length removed, in feet:		12/10	on>
. –	WAS CASING RIPPED OR PERFORATED? YES NO)	MWD/MSD/MGD	
	TURE-MASTER WELL DRILLER OR SUPERVISING SANITARIA	AN LICENSE		DATE
DENV	828 JULY 1997	MDF		⊗

n MDF

SEQUENCE NO.		THE PERSON AND ALBERTA MARKET
C1 4800 (MDE USE ONLY)	STATE OF MARYLAND	THIS REPORT MUST BE SUBMITTED WITHIN DAYS AFTER WELL IS COMPLETED.
1 2 3 6 (THIS NUMBER IS TO BE PUNCHED	WELL COMPLETION REPORT FILL IN THIS FORM COMPLETELY	OUNTY
IN COLS. 3-6 ON ALL CARDS)	PLEASE TYPE	NUMBER / 2
ST/CO USE ONLY DATE WELL COMPL	ETED Depth of Well	PERMIT NO. FROM "PERMIT TO DRILL WELL"
MM DD YY MM 1988	9 22 600 26	HA- 95-1458
8 13 15	(TO NEAREST FOOT)	28 29 30 31 32 33 34 35 36 37
OWNER Harford County	Public Schools	,
STREET OR RFD last name 2215 E.	Churchaile Rd. first name TOWN_	Churchville
SUBDIVISION Schucks Corne	or LLC SECTION_	LOT 7 W-1
WELL LOG	GROUTING RECORD Yes) no	C 3
Not required for driven wells	WELL HAS BEEN GROUTED (Circle Appropriate Box)	1 2 PUMPING TEST
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING	TYPE OF GROUTING MATERIAL (Circle one)	
FEET check	CEMENT CM BENTONITE CLAY BC	HOURS PUMPED (nearest hour)
additional sheets if needed) FROM TO bearing	NO. OF BAGS NO. OF POUNDS 35 464	PUMPING RATE (gal. per min.)
Sint 0 1	GALLONS OF WATER 30	11 15
	DEPTH OF GROUT SEAL (to nearest foot)	METHOD USED TO MEASURE PUMPING RATE
Soft brown 1 20	from 6 ft. to 25 ft.	
her crass rock 20 78	48 TOP 52 54 BOTTOM 58 (enter 0 if from surface)	WATER LEVEL (distance from land surface)
12 de rock 78 81	casing CASING RECORD	BEFORE PUMPING 28 ft.
MARIN TON	types CIT	
hardgray rock 81 88	appropriate STEEL CONCRETE	WHEN PUMPING 600 ft.
m. hard ton " 88 891 1	code below PL OT	TYPE-OF PUMP USED (for test)
	PLASTIC OTHER	A air P piston T turbine
hard gray " 89 460	MAIN Nominal diameter Total depth CASING top (main) casing of main casing	27 27
	CASING top (main) casing of main casing TYPE (nearest inch)! (nearest foot)	C centrifugal R rotary O other (describe
M. nara ging	PL 6 25	27 below)
hard gray " 462 559 /	60 61 63 64 66 70	J jet S submersible
" herderay " 559 560 "	E OTHER CASING (if used)	27 27
101, 11,000	A diameter depth (feet) H inch from to	
hard gray rock 560 600'		DRILLER INSTALLED PUMP YES NO
	Ŝ	(CIRCLE) (YES or NO)
	N	IF DRILLER INSTALLS PUMP, THIS SECTION
	screen type SCREEN RECORD	MUST BE COMPLETED FOR ALL WELLS. TYPE OF PUMP INSTALLED
	or open hele	PLACE (A,C,J,P,R,S,T,O) 29
	insert STEEL BRASS OPEN	IN BOX 29.
	appropriate BRONZE HOLE	CAPACITY: GALLONS PER MINUTE
	below / PL OT	(to nearest gallon) 31 35
	PLASTIC OTHER	PUMP HORSE POWER
American Company	C 2 DEPTH (nearest ft.)	PUMP COLUMN LENGTH 37 41
NUMBER OF UNSUCCESSFUL WELLS:	12 Ho 25 600	(nearest ft.)
WELL HYDROFRACTURED YES NO	E 8 9 11 15 17 21	CASING HEIGHT (circle appropriate box
WELL HYDROFRACTURED Y N	A C T T T T T T T T T T T T T T T T T T	and enter casing height)
CIRCLE APPROPRIATE LETTER	H 2 23 24 26 30 32 36	LAND SURFACE
A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED	S C3	below (nearest)
E ELECTRIC LOG OBTAINED	R 38 39 41 45 47 51	49 7 50 51 1000)
P TEST WELL CONVERTED TO PRODUCTION WELL	E SLOT SIZE 1 2 3	LOCATION OF WELL ON LOT
I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 "WELL CONSTRUCTION" AND	N DIAMETER (NEAREST	SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND JOR
IN CONFORMANCE WITH ALL CONDITIONS STATED IN THE ABOVE CAPTIONED PERMIT, AND THAT THE INFORMATION PRESENTED	OF SCREEN INCH)	LANDMARKS AND INDICATE NOT LESS
HEREIN IS ACCURATE AND COMPLETE TO THE BEST OF MY KNOWLEDGE.	56 60 from to	THAN TWO DISTANCES (MEASUREMENTS TO WELL)
and the second s	THE PROPERTY OF THE PARTY OF TH	1 EPE
DRILLERS LIC. NO. 1 M W D 3 6 4 1	GRAVEL PACK IF WELL DRILLED	/ []
DRILLERS SIGNATURE	WAS FLOWING WELL INSERT F IN BOX 68 68	N 12
(MUST MATCH SIGNATURE ON APPLICATION)	MDE USE ONLY	1 1
LIC. NO.1 4WD9101	(NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q	C
1700		500
SITE SUPERVISOR (sign, of driller or journeyman	70 72 74 75 76	122' 6
responsible for sitework if different from permittee)	TELESCOPE LOG CASING INDICATOR OTHER DATA	R Well abandoned 2-117013
	O Commo	
DENV-CR00	COUNTY	

WATER WELL ABANDONMENT-SEALING REPORT FORM

SUBMIT (COPIES	OF	COMPLETED	FORM	TO:
----------	--------	----	-----------	-------------	-----

- COUNTY ENVIRONMENT AGENCY (contact MDE, WMA if address needed)
- WELL OWNER
- MDE, WATER MANAGEMENT ADMINISTRATION, WELL PROGRAM

DATE	WELL	ABANDONED:		Dec.	30	09	(month/day/year)
			Gestler				(

PERMIT NUMBER OF ABANDONED WELL (if any)	MA	73	14	5
	1			
PERMIT NUMBER OF REPLACEMENT WELL	None			

PERSON ABANDONING WELL: WELL DRILLERS LICENSE NUMBER:

CIRCLE: MWD/MSD/MGD

OWNER'S NAME: Harford Co. Public Schools SITE LOCATION MAP

WELL LOCATION	HARPORD
	Churchylle
	BLOCK 4B PARCEL 454
SUBDIVISION:	chuck, Corner UC
SECTION:	LOT:
NEAREST ROAD:_	2215 F. Checkalle Rd

- September 1990 - September 1990	Churchville Rd. (R4, 22)
ž,	8
ks	1 X MAP

TYPE OF WELL BEING ABANDONED:

DRILLED	JETTED
BORED/AUGERED	HAND DUG
OTHER (specify)	
USE CODE:	

DOMESTIC	MUNICIPAL/PUBLIC	
 IRRIGATION	INDUSTRIAL	
 TEST/OBSERVATION	GEOTHERMAL	

STEEL	PLASTIC
CONCRETE	OTHER (specify)

SIZE OF CASING: _____ INCHES IN DIAMETER

DEPTH OF WELL: 600 FEET DEEP

WAS ANY CASING REMOVED? ____ YES if yes, length removed, in feet:

WAS CASING RIPPED OR PERFORATED? ____ YES _____ NO

LOG OF SEALING MATERIAL

MATERIAL	FEET	
· ·	FROM	ТО
bestonite hok plug	0	50
clean fill	50	600


VOLUME OF MATERIAL USED

10 cu.ft. bentonit


SIGNATURE-MASTER WELL DRILLER OR SUPERVISING SANITARIAN


LICENSE #


MWD/MSD/MGD CIRCLE ONE



Zhuka Rd Elementary School Dwg/Groundwater_Appropriation_Permit_Plan.dwg, 7772009 4;49.22 Ph







Ro Dementary School Day Groundwater, Appropriation, Demit, Plan dwg, 1132209 2:A256 PM, jh



MAP LEGEND


Area of Interest (AOI)

Area of Interest (AOI)

Soils

Soil Map Unit Polygons

Soil Map Unit Points



Special Point Features

Blowout ဖ

Borrow Pit

Clay Spot

Closed Depression

Gravel Pit

Gravelly Spot

Landfill

Lava Flow

Marsh or swamp

Mine or Quarry

Miscellaneous Water

Perennial Water

Rock Outcrop

Saline Spot

Sandy Spot

Severely Eroded Spot

Sinkhole

Slide or Slip

Sodic Spot

å

Spoil Area Stony Spot



Very Stony Spot



Wet Spot Other



Special Line Features

Water Features

Streams and Canals

Transportation

Rails ---

Interstate Highways

US Routes

Major Roads

Local Roads 00

Background

Aerial Photography

MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:15.800.

Warning: Soil Map may not be valid at this scale.

Enlargement of maps beyond the scale of mapping can cause misunderstanding of the detail of mapping and accuracy of soil line placement. The maps do not show the small areas of contrasting soils that could have been shown at a more detailed scale.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service

Web Soil Survey URL:

Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: Harford County Area, Maryland Survey Area Data: Version 15, Aug 26, 2021

Soil map units are labeled (as space allows) for map scales 1:50.000 or larger.

Date(s) aerial images were photographed: Sep 23, 2020—Nov 20. 2020

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

Map Unit Legend

Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
AdB	Aldino silt loam, 3 to 8 percent slopes	22.0	41.4%
CcB2	Chester silt loam, 3 to 8 percent slopes	12.5	23.5%
GcB2	Glenelg loam, 3 to 8 percent slopes	1.6	3.1%
GcC	Glenelg loam, 8 to 15 percent slopes	2.4	4.6%
GcD	Glenelg loam, 15 to 25 percent slopes	1.1	2.2%
Hb	Hatboro silt loam	5.0	9.4%
WaA	Watchung silt loam, 0 to 3 percent slopes	8.5	15.9%
Totals for Area of Interest		53.3	100.0%

Map Unit Descriptions

The map units delineated on the detailed soil maps in a soil survey represent the soils or miscellaneous areas in the survey area. The map unit descriptions, along with the maps, can be used to determine the composition and properties of a unit.

A map unit delineation on a soil map represents an area dominated by one or more major kinds of soil or miscellaneous areas. A map unit is identified and named according to the taxonomic classification of the dominant soils. Within a taxonomic class there are precisely defined limits for the properties of the soils. On the landscape, however, the soils are natural phenomena, and they have the characteristic variability of all natural phenomena. Thus, the range of some observed properties may extend beyond the limits defined for a taxonomic class. Areas of soils of a single taxonomic class rarely, if ever, can be mapped without including areas of other taxonomic classes. Consequently, every map unit is made up of the soils or miscellaneous areas for which it is named and some minor components that belong to taxonomic classes other than those of the major soils.

Most minor soils have properties similar to those of the dominant soil or soils in the map unit, and thus they do not affect use and management. These are called noncontrasting, or similar, components. They may or may not be mentioned in a particular map unit description. Other minor components, however, have properties and behavioral characteristics divergent enough to affect use or to require different management. These are called contrasting, or dissimilar, components. They generally are in small areas and could not be mapped separately because of the scale used. Some small areas of strongly contrasting soils or miscellaneous areas are identified by a special symbol on the maps. If included in the database for a given area, the contrasting minor components are identified in the map unit descriptions along with some characteristics of each. A few areas of minor

Kaitlin Geary

From: Amy M. Parrish

Sent: Wednesday, July 13, 2022 4:34 PM

To: Kaitlin Geary

Subject: FW: 22015 [External] JAS Site Planning Info Follow-up

Answer on Archer school only their students use the pool, but we waiting on how many

Amy M. Parrish, P.G., LEHS

Senior Managing Hydrogeologist Environmental

Barton&Loguidice

Office: 410.795.4626 Mobile: 410.371.2586

Email: aparrish@bartonandloguidice.com Website | LinkedIn | Twitter | Facebook | Vimeo

From: Peter Soprano [mailto:psoprano@siteresourcesinc.com]

Sent: Wednesday, July 13, 2022 2:36 PM **To:** Zachary Klee <zklee@gparch.com>

Cc: Scott Eschbach <seschbach@gparch.com>; Kate Heil <kheil@siteresourcesinc.com>; Jennifer Harrington

<jharrington@siteresourcesinc.com>; Amy M. Parrish <aparrish@bartonandloguidice.com>

Subject: RE: 22015 [External] JAS Site Planning Info Follow-up

ATTENTION --> This email came from an external source. Do not open attachments or click on links from unknown senders or unexpected emails.

Hi Zak,

I believe the therapy pool is just for the student population moving over from John Archer. Can you please confirm?

Best,

Peter Soprano, PE

SITE RESOURCES, INC.

DD 443.689.0438

www.siteresourcesinc.com

This email and any files transmitted with it are confidential and intended solely for the addressee. If you are not the named addressee you should not distribute, copy or alter this email.

From: Zachary Klee < zklee@gparch.com>
Sent: Wednesday, June 22, 2022 2:06 PM

To: Peter Soprano psoprano@siteresourcesinc.com>

Cc: Scott Eschbach <seschbach@gparch.com>

Subject: FW: [External] JAS Site Planning Info Follow-up

Peter,

Please see response from HCPS below. There are still a couple of outstanding questions that their looking into.

Zak

Zachary A. Klee AIA, NCARB, LEED AP BD+C

Senior Associate

d <u>240.965.0742</u> | o <u>301.595.1000</u>

11720 Beltsville Drive, Suite 600

Calverton, MD 20705

zklee@gparch.com | grimmandparker.com

Calverton | Tysons | Charlottesville



----- Original message -----

From: "Miller, Harry" < Harry.Miller@hcps.org>

Date: 6/22/22 10:12 AM (GMT-05:00) To: Zachary Klee <<u>zklee@gparch.com</u>>

Cc: Scott Eschbach <seschbach@gparch.com>, "Valentino, Missy" <Mary.Valentino@hcps.org>

Subject: RE: [External] JAS Site Planning Info Follow-up

See below.

Harry Miller Assistant Supervisor Planning & Construction



2209 Conowingo Rd. Bel Air, MD 21015 410-809-6120

www.HCPS.org

From: Zachary Klee < zklee@gparch.com
Sent: Tuesday, June 21, 2022 9:53 AM
To: Miller, Harry < Harry.Miller@hcps.org
Cc: Scott Eschbach < seschbach@gparch.com
Subject: [External] JAS Site Planning Info Follow-up

Harry,

Good talking with you yesterday.

Here'e the summary of outstanding info we're either looking for or looking to confirm. As discussed yesterday, you may not have all the answers yet but hopefully we can agree on some reasonable assumptions so we can proceed with the preliminary planning studies including sizing/locating the waste treatment facility and septic field, traffic analysis, etc.

Just to keep things together, I noted previous responses in red.

- Percent impervious acres estimate, if available
 - o For another HCPS school project of a similar size, our total proposed impervious was about 38% of the total site/study area. This equated to about 9-10 acres of impervious. Until we have more detailed concepts to share with them, I intend to provide this number unless you disagree. This sounds okay to me as a starting point to make sure we are within target parameters for the site and proposed usage/population.
- Flow meter data from John Archer, if available -
 - Can you please request this from HCPS? If they monitor their water meter data, this info is hopefully easy to obtain and would help with design estimates. Water use data has been provided in Excel format.
- Population (estimated student enrollment) and Water use information, if available
 - o From the RFP, the most conservative population number I'm seeing for JAS is the state rated capacity of 264. Could you please confirm for JAS and the new ES? I believe they are just looking for a conservative number at this point so they can estimate. Missy is working on this (with G+P and our stakeholders).
 - o Assuming there will be showers with the therapy pool? Showers will be included.
 - Full food prep and cooking Kitchen or warming kitchen only? This is a warming kitchen. This is also an
 interesting question. In our warming kitchens, we handle lots of raw items, and prepare essentially
 ready to eat items. So, other than making bulk items from scratch, these kitchens look virtually similar.
 - Not sure if BKM could provide a conservative estimate on overall plumbing demands at this point?
- Turf / Ball playing fields management, if available
 - Do we know if HCPS intends to have the site/fields irrigated? Impacts well design/capacity. No irrigation.
 - Do we know if HCPS plans to use fertilizer/pesticides in the play field areas? Impacts service areas.
 Fertilizer and herbicide treatment info has been provided.
- Traffic Group has the current JAS population at 58 staff and 136 students for a total of 194. Based on our conversation yesterday, that number may be high. Please confirm. I just talked to the AP. They had 138 students, 100 staff, 36 in the infants and toddlers program, and 64 itinerants.
- For planning purposes, what's a reasonable growth factor? I rounded what we think is the current population up to 200 and then put 25% on it, which got me to 250. Based on our conversation yesterday and another I had with Kieran, that may be too much. I am going to have to defer to Missy on this one.
- Best guess on the ES population is 700 including students and staff. Does that sound about right? Again, this is for planning purposes, so a high estimate is better than a low one. That is the number I have heard for conversation purposed.
- Please confirm current JAS schedule is 8:40 to 3:00. Busses arrive at 8:40, and dismissal starts at 2:45. Also, let us know if you think that may change. No clue. I know AACPS just changed the start/end times for all their schools based on grade level. How they expect working parents to get middle schoolers on the bus for a 9:15 start is beyond me.

- Do you all expect the ES and JAS to run on the same schedule or will they have staggered start/dismissal times? Maybe it's too early to know for sure but what's the best guess? JAS is already different from elementary which is 9-3:30.
- How many busses currently service JAS. 15

Thanks Harry, Zak

Zachary A. Klee AIA, NCARB, LEED AP BD+C

Senior Associate

d 240.965.0742 | o 301.595.1000 11720 Beltsville Drive, Suite 600 Calverton, MD 20705 zklee@gparch.com | grimmandparker.com Calverton | Tysons | Charlottesville



Kaitlin Geary

From: Amy M. Parrish

Sent: Friday, June 17, 2022 4:54 PM **To:** Peter Soprano; Kaitlin Geary

Subject: RE: [External] Archer Site and Traffic Questions

Very good thank you. We are reviewing and will circle back here as well.

Amy M. Parrish, P.G., LEHS

Senior Managing Hydrogeologist Environmental

Barton&Loguidice

Office: 410.795.4626 Mobile: 410.371.2586

Email: aparrish@bartonandloguidice.com Website | LinkedIn | Twitter | Facebook | Vimeo

From: Peter Soprano [mailto:psoprano@siteresourcesinc.com]

Sent: Thursday, June 16, 2022 5:00 PM

To: Amy M. Parrish <aparrish@bartonandloguidice.com>; Kaitlin Geary <kgeary@bartonandloguidice.com>

Subject: FW: [External] Archer Site and Traffic Questions

ATTENTION --> This email came from an external source. Do not open attachments or click on links from unknown senders or unexpected emails.

Amy and Kaitlin,

Please see below.

Best.

Peter Soprano, PE

SITE RESOURCES, INC.

DD 443.689.0438

www.siteresourcesinc.com

This email and any files transmitted with it are confidential and intended solely for the addressee. If you are not the named addressee you should not distribute, copy or alter this email.

From: Zachary Klee < <u>zklee@gparch.com</u>> Sent: Tuesday, June 14, 2022 4:27 PM

To: Peter Soprano
psoprano@siteresourcesinc.com **Subject:** FW: [External] Archer Site and Traffic Questions

Peter.

Please see below regarding the ball field fertilizer and chemical treatments. Still working on the rest of the questions.

Zachary A. Klee AIA, NCARB, LEED AP BD+C

Senior Associate

d <u>240.965.0742</u> | o <u>301.595.1000</u> 11720 Beltsville Drive, Suite 600 Calverton, MD 20705 <u>zklee@gparch.com</u> | grimmandparker.com

Calverton | Tysons | Charlottesville

CELEBRATING 50 YEARS

----- Original message -----

From: "Morton, Chris" < Chris. Morton@hcps.org>

Date: 6/14/22 3:43 PM (GMT-05:00) To: Zachary Klee <<u>zklee@gparch.com</u>>

Cc: Scott Eschbach < seschbach@gparch.com >, "Miller, Harry" < Harry.Miller@hcps.org >, "Valentino, Missy"

< <u>Mary.Valentino@hcps.org</u>>, "Hanzevack, Richard" < <u>Richard.Hanzevack@hcps.org</u>>, "Beard, Patti Jo"

< PattiJo.Beard@hcps.org>, "Earle, Kenneth" < Kenneth.Earle@hcps.org>

Subject: FW: [External] Archer Site and Traffic Questions

Hi Zak,

Here is information regarding the turf/ball fields.

Chris

From: Hanzevack, Richard < Richard. Hanzevack@hcps.org>

Sent: Tuesday, June 14, 2022 3:40 PM

To: Morton, Chris < Chris.Morton@hcps.org; Valentino, Missy < Mary.Valentino@hcps.org; Miller, Harry

<Harry.Miller@hcps.org>; Beard, Patti Jo <PattiJo.Beard@hcps.org>

Cc: Earle, Kenneth < Kenneth. Earle@hcps.org >

Subject: FW: [External] Archer Site and Traffic Questions

Please see about herbicide Pesticides below. Thanks.

Rich Hanzevack Assistant Supervisor Facilities Management Environmental Services



Harford County Public Schools

Facilities Management Department 2209 Conowingo Road Bel Air, Maryland 21015 Phone: 410.638.4087 Fax: 410.638.4205

From: Earle, Kenneth < Kenneth. Earle@hcps.org >

Sent: Wednesday, June 8, 2022 11:20 AM

To: Beard, Patti Jo < PattiJo.Beard@hcps.org; Hanzevack, Richard < Richard.Hanzevack@hcps.org; Paligo, Laura

<<u>Laura.Paligo@hcps.org</u>>

Subject: RE: [External] Archer Site and Traffic Questions

Good morning,

Please find my response regarding herbicide and pesticide use in blue.

Turf / Ball playing fields management, if available

- Do we know if HCPS intends to have the site/fields irrigated? Impacts well design/capacity.
- Do we know if HCPS plans to use fertilizer/pesticides in the play field areas? Impacts service areas.

-Athletic fields are fertilized yearly with a preemergent weed and feed. Note: currently only two primary sites have playing fields that are fertilized RFES & HIES.

-Herbicide weed killer is used at the JAES's current location at an average rate of 10 gallons per year.

Please make me aware if more detail is needed and how I can support.

Regards,

Ken Earle Custodial Services Coordinator Facilities Management

HARFORD COUNTY
PUBLIC SCHOOLS

Facilities Management Department 2209 Conowingo Road Bel Air, Maryland 21015 (410) 638-4088

From: Beard, Patti Jo <PattiJo.Beard@hcps.org>

Sent: Monday, June 6, 2022 8:15 AM

To: Hanzevack, Richard <Richard.Hanzevack@hcps.org>; Paligo, Laura <Laura.Paligo@hcps.org>; Earle, Kenneth

< Kenneth. Earle@hcps.org >

Subject: FW: [External] Archer Site and Traffic Questions

Please see the information requested below

From: Morton, Chris < Chris. Morton@hcps.org>

Sent: Friday, June 3, 2022 9:43 AM

To: Beard, Patti Jo < PattiJo.Beard@hcps.org>

Cc: Valentino, Missy < Mary. Valentino@hcps.org >; Miller, Harry < Harry. Miller@hcps.org >

Subject: FW: [External] Archer Site and Traffic Questions

Good morning, PJ,

The design team has some questions regarding the John Archer/New Elementary School Project. Some of the information we can provide and some information we will need to get from you folks. I know you are off today, but if we could discuss next week and pull this together, I would appreciate it. Thanks!

Chris

From: Zachary Klee <<u>zklee@gparch.com</u>>

Sent: Friday, June 3, 2022 8:54 AM

To: Morton, Chris < Chris.Morton@hcps.org Cc: Scott Eschbach seschbach@gparch.com <a href="mail

Subject: [External] Archer Site and Traffic Questions

Good morning Chris. Thanks for offering to help me out with these SRI and Traffic Group questions while Harry's away. BTW, it was nice to hear your and Karen's voices on the phone. You both sound relaxed and happy. I guess it is Friday!

Here's what I got from SRI:

Good morning Zak,

Our well and septic design consultant is asking the below questions. They have been working through the health department records we received and have requested additional information from HCHD to help determine what other areas onsite may be feasible as septic areas. In the interim, can you please help me answer the below? I'm available to discuss if helpful.

Well and Septic Design Consultant Questions:

- Percent impervious acres estimate, if available -
 - For another HCPS school project of a similar size, our total proposed impervious was about 38% of the total site/study area. This equated to about 9-10 acres of impervious. Until we have more detailed concepts to share with them, I intend to provide this number unless you disagree.
- Flow meter data from John Archer, if available -
 - Can you please request this from HCPS? If they monitor their water meter data, this info is hopefully easy to obtain and would help with design estimates.
- Population (estimated student enrollment) and Water use information, if available
 - From the RFP, the most conservative population number I'm seeing for JAS is the state rated capacity of 264. Could you please confirm for JAS and the new ES? I believe they are just looking for a conservative number at this point so they can estimate.
 - Assuming there will be showers with the therapy pool?
 - Full food prep and cooking Kitchen or warming kitchen only?
 - Not sure if BKM could provide a conservative estimate on overall plumbing demands at this point?
- Turf / Ball playing fields management, if available

- Do we know if HCPS intends to have the site/fields irrigated? Impacts well design/capacity.
- o Do we know if HCPS plans to use fertilizer/pesticides in the play field areas? Impacts service areas.

And this was the request from Traffic Group:

I am looking to confirm/obtain some information on the current and proposed future John Archer School:

Current Faculty / Staff: **58** Current Enrollment: **136**

Current Bell Schedule: 8:40-3:00

Current Number of Buses: Please Provide

Please confirm the above numbers are correct. In addition, please provide information on the future proposed conditions so we can incorporate into our report.

Those numbers obviously don't include the elementary school and they are current numbers, not future. Still, it's helpful to know if they're accurate and whether or not they will increase. We're currently expecting that they will increase.

Talking with Laura in my office, we're thinking the ES will have a total population of about 700 and Archer will be around 250. Can you verify or clarify those numbers? Maybe a breakdown of students and staff and/or bus and car for the two programs? If they're on the same bell schedule combined numbers will be fine. If they're different bell schedules, we'll want to have numbers and times for each.

Thanks, Zak

Zachary A. Klee AIA, NCARB, LEED AP BD+C
Senior Associate
d 240.965.0742 | o 301.595.1000
11720 Beltsville Drive, Suite 600
Calverton, MD 20705
zklee@gparch.com | grimmandparker.com
Calverton | Tysons | Charlottesville



Jennifer L. Harrington

From:

John S. Easterling [jeasterling@GWWOINC.com]

Sent:

Thursday, January 08, 2009 4:51 PM

To:

Jennifer L. Harrington

Cc:

Steve Crowe; Bob Morelock; jhau@chesenv.com; Brian D. Eschman; Admin

Subject: FW: 0901Campus Hills ES Groundwater Appropriation and Use Permit

Jennifer,

Please see the anticipated water use averages below from Kibart.

Let me know if you need any other information.

Thanks, John

John Easterling, AIA, LEED™ AP Senior Associate GWWO, Inc./Architects 800 Wyman Park Dr. Suite 300 Baltimore, MD 21211 P: 410.332.1009 ext. 1130 F: 410.332.0038 jeasterling@gwwoinc.com

*** Visit our new website at www.gwwoinc.com.

From: Farshad Kassiri [mailto:fk@kibart.com] Sent: Thursday, January 08, 2009 4:52 PM

To: John S. Easterling Cc: Steve Brzezenski

Subject: RE: 0901Campus Hills ES Groundwater Appropriation and Use Permit

John.

The following are the anticipated water use averages:

15,520 Gallons per day (for annual average, based on 20 GPD/person) 19,400 Gallons per day (for highest monthly use, based on 25 GPD/person)

Thanks, Farshad

Farshad Kassiri, P.E.

Vice President - Principal

Kibart, Inc.
Consulting Engineers
901 Dulaney Valley Rd, Suite 301
Towson, Maryland 21204
410.494.1111 (Phone)
410.494.1112 (Fax)
www.kibart.com

From: John S. Easterling [mailto:jeasterling@GWWOINC.com]

Sent: Wednesday, January 07, 2009 3:56 PM

To: Farshad Kassiri

Cc: Brian D. Eschman; Admin

Subject: FW: 0901 Campus Hills ES Groundwater Appropriation and Use Permit

Farshad,

Can you help me answer Site Resources' question below? Note that the state rated capacity is still 696 students plus 80 staff.

Thanks, John

John Easterling, AIA, LEED™ AP Senior Associate GWWO, Inc./Architects 800 Wyman Park Dr. Suite 300 Baltimore, MD 21211 P: 410.332.1009 ext. 1130 F: 410.332.0038 jeasterling@gwwoinc.com

*** Visit our new website at www.gwwoinc.com.

From: Jennifer L. Harrington [mailto:jharrington@siteresourcesinc.com]

Sent: Wednesday, January 07, 2009 2:46 PM

To: John S. Easterling

Cc: Steve Crowe; Bob Morelock; Joe Hau

Subject: 08035 Campus Hills ES Groundwater Appropriation and Use Permit

John -- We are preparing the permit application for GW appropriation for this project. Joe Hau, of CEM, has indicated to me that the two existing wells north of the proposed site have a yield of 15 and 17 gpm. Joe recommends that we try to use these wells. We may be able to transfer the permits on these wells and as long as water quality testing results are acceptable; these wells should be fine. We will also include in the permit that we are proposing a new well. For the permit, I need the anticipated average annual use in gallons per day and the estimated highest monthly use in gallons per day? Do you have this information?

thank you,

Jennifer Harrington, P.E.

Project Engineer

Site Resources, Inc.

14315 Jarrettsville Pike Phoenix, Maryland 21131-0249 iharrington@siteresourcesinc.com

ph. 410.683.3388 fx. 410.683.3389

Jennifer L. Harrington

From:

Craig Williams [CWilliams@mde.state.md.us]

Sent:

Thursday, February 12, 2009 1:20 PM

To:

Joseph Hau

Cc:

Kevin Barnaba; Jennifer L. Harrington

Subject:

Campus Hills Elem MW locations

Joe.

Elaborating on the voice message I just left you, I discussed the MW location map with Dr. Tien. He suggests upslope wells intended as permanent sampling stations be at least 50 feet from the related OSDS. Two are needed.

By that measure, the location of MW 1 looks OK, at least in Jennifer's larger scale exhibit. On your smaller scale exhibit (the one we would publish), it looks like it could be directly on the neighboring property line (10 feet to property line being the applicable standard.)

MWs 2 and 3 are the other potential candidates for upslope wells. Use of either as a water quality sampling location would require some carving of the potential OSDS area.

The adjustment relative to MW 2 would be to establish reasonable separation; the adjustment for MW 3 would be for reasonable landscape position.

Carving the OSDS to make room for either of these wells is potentially viable but would entail both generation and review of a revised OSDS exhibit. Designating a new upslope MW location would seem the simpler and more expedient solution.

As to downslope MW locations, MW 6 looks fine; we've already agreed one more location needs to be designated "somewhere" downslope of R1. It does not necessarily have to be 50' from the OSDS, but keeping it at or very close to the 350' contour interval would maximize flexibility for OSDS installation.

In light of these comments, I look forward to receiving from either you or Jennifer, a revised (8 1/2" by 11") exhibit of the potential OSDS area and the existing and/or intended locations of just those 4 monitoring wells intended for permanent water quality sampling points.

At that pont I can turn over the Discharge Permit Application to Dr. Tien for initial processing. Note that in this initial processing phase, a determination is made as to whether or not the application is eligible to move forward on the criteria of its consistency with the County Master Water and Sewer Plan. (Anticipate two to three week turn-around time on just this and any related administrative points of which I am not aware.)

Once that determination is made, receipt of the application can be published.

At that point, finally (Jennifer et al), I believe it is reasonable to consider the projected timelines for permit processing as being applicable here.

Thanks,

Craig Williams, Regional Consultant On-site Systems Division Wastewater Permits Program 410-537-3783 office 410-537-3163 fax

